

DEASE LAKE, BC, Canada

WMO: 719580

Lat: 58.422N

Lon: 130.031W

Elev: 807

StdP: 92.00

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.3	-32.7	-40.4	0.1	-36.1	-37.0	0.1	-32.9	6.1	-10.6	5.4	-14.4	1.8	50	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	25.4	13.8	23.0	12.8	20.7	12.0	15.0	22.6	13.9	20.6	12.9	18.9	2.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	9.7	16.0	11.1	9.1	15.1	10.2	8.5	14.3	44.5	22.7	41.3	20.7	38.6	19.0	20.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.4	4.7	-39.4	28.9	2.8	1.7	-41.4	30.1	-43.1	31.1	-44.6	32.0	-46.7	33.2		
(5)			-39.2	17.2	2.8	1.2	-41.2	18.0	-42.8	18.7	-44.4	19.4	-46.5	20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.4	-15.8	-12.0	-6.8	1.0	7.0	11.3	13.1	11.9	7.2	0.9	-8.6	-14.5
	DBStd	11.69	9.20	7.47	6.98	3.92	3.60	3.17	2.69	3.01	2.90	3.88	6.26	8.24
	HDD10.0	4039	798	617	521	270	106	20	4	13	91	282	559	758
	HDD18.3	6833	1057	850	779	520	351	213	164	200	333	541	809	1017
	CDD10.0	251	0	0	0	0	14	58	99	72	8	0	0	0
	CDD18.3	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH23.3	174	0	0	0	0	7	57	57	52	1	0	0	0
	CDH26.7	28	0	0	0	0	1	11	9	7	0	0	0	0
(14) Wind	WSAvg	1.7	1.7	1.8	2.2	2.0	2.1	1.9	1.7	1.6	1.5	1.5	1.4	1.5
(15) Precipitation	PrecAvg	452	33	26	22	15	32	45	62	55	52	40	35	35
	PrecMax	589	112	72	55	38	68	98	138	114	88	130	96	85
	PrecMin	350	5	1	3	4	2	3	16	19	23	16	7	7
	PrecStd	69	21	19	13	8	16	21	30	21	17	25	22	19
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.3	5.2	9.5	16.3	24.0	28.4	27.7	27.8	21.0	13.0	5.9	4.6
		MCWB	0.7	1.5	3.2	6.7	10.8	14.5	15.2	15.4	12.0	8.0	2.6	1.5
	2%	DB	0.2	1.5	6.2	12.2	20.9	24.8	24.7	24.7	17.0	9.7	2.6	1.1
		MCWB	-0.4	-0.6	1.5	4.8	9.8	13.1	13.9	14.4	9.8	5.7	0.7	-0.7
	5%	DB	-1.8	-0.3	4.2	9.9	18.1	21.8	22.5	21.5	14.7	7.9	0.6	-0.8
		MCWB	-2.2	-1.5	0.4	3.5	8.8	12.0	13.1	13.2	9.2	4.6	-0.3	-1.6
	10%	DB	-4.2	-2.2	2.5	7.9	15.5	19.0	20.0	18.7	12.8	6.1	-0.8	-3.1
		MCWB	-4.6	-3.2	-0.7	2.4	7.7	10.8	12.6	12.2	8.5	3.7	-1.4	-3.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.3	2.0	3.7	7.3	11.7	15.7	16.3	16.2	13.1	8.8	3.2	1.4
		MCDB	2.7	4.5	8.4	14.6	20.0	25.3	24.8	24.7	19.1	12.3	5.5	3.4
	2%	WB	-0.2	-0.2	2.0	5.3	10.2	13.8	14.9	15.0	11.3	6.6	1.2	-0.4
		MCDB	0.6	1.2	5.6	11.2	19.2	22.1	22.0	22.9	15.4	8.9	2.3	0.4
	5%	WB	-2.0	-1.6	0.8	3.9	9.2	12.6	14.0	13.7	10.1	5.2	-0.1	-2.0
		MCDB	-1.5	-0.5	3.8	8.9	17.0	20.1	20.3	20.0	13.5	7.2	0.6	-0.9
	10%	WB	-4.3	-3.1	-0.4	2.7	8.2	11.5	13.0	12.6	9.0	3.9	-1.4	-4.1
		MCDB	-3.9	-2.2	2.0	7.3	14.6	17.7	18.9	17.7	11.8	5.9	-0.7	-3.4
(35) Mean Daily Temperature Range	MDBR		7.9	11.0	12.7	11.6	13.2	12.5	11.5	11.6	10.3	7.8	7.5	7.6
	5% DB	MCDBR	8.7	11.2	12.3	14.5	18.2	17.9	17.1	17.5	14.2	10.4	7.9	8.4
		MCWBR	7.8	9.0	8.2	8.1	9.0	8.5	8.0	8.7	8.0	6.7	6.5	7.1
	5% WB	MCDBR	8.5	10.5	11.5	13.1	16.0	15.6	14.2	15.2	12.3	9.8	7.5	8.2
		MCWBR	7.7	8.6	7.7	7.6	8.1	7.7	7.3	7.9	7.3	6.6	6.2	7.1
(40) Clear-Sky Solar Irradiance	taub		0.239	0.252	0.276	0.356	0.363	0.366	0.353	0.342	0.308	0.283	0.233	0.209
	taud		2.132	2.277	2.232	1.991	2.187	2.358	2.434	2.492	2.570	2.443	2.164	2.063
	Ebn at Noon		602	801	876	837	865	869	874	862	847	758	605	512
	Edh at Noon		48	69	96	147	130	112	102	90	71	59	45	36
(44) All-Sky Solar Radiation	RadAvg		0.47	1.26	2.66	4.38	5.50	5.24	4.74	3.94	2.48	1.30	0.56	0.32
	RadStd		0.04	0.14	0.25	0.24	0.37	0.40	0.49	0.29	0.23	0.12	0.06	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page