

CHETICAMP CS, NS, Canada

WMO: 719590

Lat: 46.650N

Lon: 60.950W

Elev: 144

StdP: 14.62

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.3	7.3	-3.1	4.7	4.8	0.8	5.7	8.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	81.2	69.7	78.6	68.3	76.2	67.3	72.0	78.5	70.5	76.2	69.0	74.4	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	109.3	76.3	68.2	104.3	74.8	66.7	98.9	73.2	35.8	78.9	34.5	76.2	33.2	74.3	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-2.2	86.7	5.2	2.3	-6.0	88.3	-9.0	89.6	-11.9	90.9	-15.7	92.6		
(5)			-2.7	74.7	5.1	1.4	-6.4	75.7	-9.3	76.5	-12.2	77.3	-15.9	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	25.6	23.5	29.2	38.4	48.4	57.5	66.1	65.9	59.0	49.5	41.5	32.4		
	DBStd	16.40	8.93	9.27	8.74	7.81	7.57	7.26	5.49	4.86	6.62	6.69	7.89	7.73		
	HDD50	3564	757	741	646	360	124	15	0	0	5	92	277	547		
	HDD65	7550	1220	1161	1111	798	516	244	54	48	202	481	704	1011		
	CDD50	1696	1	0	1	12	75	239	499	491	276	77	24	1		
	CDD65	206	0	0	0	0	2	19	87	74	23	1	0	0		
	CDH74	1026	0	0	0	0	10	113	465	352	81	5	0	0		
	CDH80	118	0	0	0	0	0	11	60	41	6	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	55.9	5.6	4.3	4.1	3.7	3.4	3.4	3.4	4.4	4.4	5.9	5.5	6.6		
	PrecMax	65.2	8.3	7.0	7.0	6.7	5.7	7.2	6.3	8.4	11.0	9.0	8.1	14.6		
	PrecMin	39.4	3.2	1.7	1.6	2.1	1.1	1.7	1.3	2.2	0.6	2.4	3.8	2.8		
	PrecStd	5.9	1.5	1.5	1.3	1.3	1.1	1.3	1.3	1.7	2.6	1.7	1.2	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	54.6	57.6	68.5	75.5	81.2	84.6	84.0	80.2	73.1	67.9	60.0		
		MCWB	55.9	49.5	52.0	57.5	61.8	68.7	72.5	70.9	70.8	65.3	62.6	55.9		
	2%	DB	50.4	47.6	51.5	61.6	70.7	77.3	81.6	80.7	76.2	68.0	64.1	54.2		
		MCWB	47.5	44.2	45.7	54.3	59.6	65.8	70.2	69.5	68.4	62.4	59.6	50.9		
	5%	DB	41.9	41.0	46.3	56.3	66.5	73.8	78.9	77.9	73.2	64.4	60.1	48.2		
		MCWB	39.5	37.7	41.9	50.3	56.4	63.8	68.6	68.4	66.9	59.6	55.9	45.5		
	10%	DB	37.1	36.2	41.4	51.1	62.4	70.5	76.4	75.3	70.5	60.4	54.7	43.2		
		MCWB	35.1	33.7	37.5	45.6	54.4	61.9	67.7	67.5	64.7	56.1	50.9	40.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	50.2	52.3	59.6	64.8	71.4	74.2	73.7	72.5	67.1	62.9	56.3		
		MCDB	60.4	53.1	56.0	65.7	71.8	78.8	82.6	81.2	78.6	71.0	67.3	59.7		
	2%	WB	48.0	44.1	46.8	55.4	61.8	68.6	72.4	71.5	69.8	63.2	59.7	50.9		
		MCDB	50.4	46.8	50.4	60.8	68.1	74.6	79.3	77.7	74.7	67.3	63.7	53.9		
	5%	WB	39.6	37.4	42.1	51.2	58.5	65.9	70.8	70.0	67.7	59.9	55.8	45.4		
		MCDB	41.7	40.0	45.8	55.9	64.6	71.5	76.7	75.6	72.4	63.7	59.5	47.9		
	10%	WB	35.2	33.5	37.6	46.0	54.8	62.9	69.2	68.4	65.3	56.3	50.7	40.9		
		MCDB	37.0	35.4	41.2	50.9	61.1	69.1	74.5	73.9	69.7	60.0	53.9	43.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	14.2	14.7	14.7	17.2	17.1	16.3	15.6	15.9	13.3	12.1	10.3		
		MCDBR	21.9	22.2	21.9	23.4	23.6	21.7	19.6	18.9	18.3	18.7	19.7	19.3		
	5% WB	MCWBR	20.4	19.5	17.9	17.1	14.5	12.9	10.9	10.6	12.0	14.6	18.0	18.2		
		MCWBR	22.0	22.2	21.0	22.0	20.2	17.9	16.1	15.8	16.8	17.8	19.6	19.1		
(40) Clear-Sky Solar Irradiance	taub		0.303	0.295	0.329	0.355	0.370	0.389	0.416	0.395	0.363	0.348	0.326	0.306		
	taud		2.320	2.302	2.272	2.375	2.418	2.378	2.357	2.420	2.481	2.476	2.450	2.375		
	Ebn at Noon		247	278	283	286	284	278	268	270	270	256	239	233		
	Edh at Noon		24	30	36	36	36	37	38	34	29	25	22	21		
(44) All-Sky Solar Radiation	RadAvg		297	542	945	1328	1614	1740	1748	1541	1172	714	360	226		
	RadStd		23	75	103	114	132	159	117	99	96	67	43	19		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A	N/A

Nomenclature: See separate page