

MAYO, YT, Canada

WMO: 719650

Lat: 63.616N

Lon: 135.880W

Elev: 1653

StdP: 13.84

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -53.3	(c) -47.0	(d) -45.9	(e) 0.4	(f) -38.4	(g) -39.6	(h) 0.6	(i) -33.1	(j) 17.3	(k) 6.4	(l) 15.5	(m) 6.6	(n) 0.2	(o) 30	(p) 0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	80.8	59.4	77.2	57.8	73.8	56.5	61.2	76.0	59.5	72.7	58.2	70.1	5.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.4	72.1	62.5	54.7	67.5	61.5	53.0	63.5	60.9	28.0	76.4	26.8	73.0	25.9	70.1	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	13.8	12.1	-54.3	85.2	6.4	3.7	-58.9	87.9	-62.6	90.0	-66.2	92.0	-70.8	94.7
			-41.9	64.5	5.2	2.2	-45.6	66.0	-48.6	67.3	-51.5	68.5	-55.2	70.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	-8.4	0.5	13.9	34.2	48.4	58.5	60.8	55.8	44.6	28.2	4.5	-3.0
	DBStd	28.00	22.05	18.00	15.51	9.33	7.79	5.81	4.48	6.04	6.81	10.04	17.01	19.45
	HDD50	8802	1811	1386	1118	476	126	3	1	13	184	676	1365	1643
	HDD65	13425	2276	1806	1583	924	516	210	142	293	612	1140	1815	2108
	CDD50	889	0	0	0	2	76	258	336	194	22	1	0	0
	CDD65	38	0	0	0	0	2	15	13	8	0	0	0	0
	CDH74	714	0	0	0	0	49	236	267	161	1	0	0	0
	CDH80	131	0	0	0	0	6	49	39	37	0	0	0	0
Wind	WSAvg	4.2	3.1	3.7	5.7	5.7	5.1	4.2	3.4	3.3	3.9	4.8	3.8	3.5
Precipitation	PrecAvg	12.9	0.7	0.6	0.4	0.4	0.9	1.6	2.2	1.7	1.5	1.2	0.9	0.8
	PrecMax	17.6	1.6	1.7	1.3	1.3	1.8	3.4	4.4	4.1	3.2	2.7	1.6	1.8
	PrecMin	5.9	0.1	0.1	0.0	0.0	0.2	0.4	0.5	0.5	0.5	0.3	0.1	0.2
	PrecStd	2.4	0.4	0.4	0.3	0.3	0.4	0.7	0.9	0.8	0.7	0.6	0.3	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.0	40.4	49.7	63.5	79.6	85.8	84.5	84.6	68.4	55.1	43.7	39.0
		MCWB	34.7	34.1	40.0	47.9	56.2	62.1	60.9	62.2	53.6	46.5	36.6	34.1
	2%	DB	32.5	34.4	43.4	57.2	73.4	80.1	80.0	78.6	63.1	47.8	34.4	32.6
		MCWB	30.2	31.0	35.1	43.6	53.5	58.6	59.0	59.9	50.9	41.0	31.8	30.3
	5%	DB	26.5	30.0	39.4	52.7	68.7	76.1	76.9	73.1	59.9	43.9	30.0	28.2
		MCWB	24.9	27.5	33.1	40.7	51.0	56.4	58.4	57.3	49.3	39.0	28.3	26.3
	10%	DB	20.0	25.3	35.1	48.9	64.4	72.4	73.6	68.6	56.9	40.5	26.0	22.7
		MCWB	18.8	23.2	30.3	38.4	48.9	54.9	57.3	55.7	47.8	36.7	24.6	21.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.6	34.6	40.2	48.2	57.6	63.1	63.5	63.6	55.5	46.8	37.2	34.7
		MCDB	39.5	39.1	48.6	62.6	76.2	81.6	77.8	81.3	64.3	54.1	41.9	38.0
	2%	WB	30.8	31.2	35.7	44.1	54.3	60.3	61.0	60.9	52.6	41.9	32.2	30.9
		MCDB	33.5	34.5	41.8	55.9	70.7	75.9	74.1	76.3	60.6	46.4	34.5	33.4
	5%	WB	26.0	27.8	33.2	41.2	52.0	58.1	59.7	58.7	50.4	39.4	28.5	26.8
		MCDB	27.8	30.3	39.2	51.4	66.4	71.3	72.4	70.5	58.0	43.2	30.2	28.7
	10%	WB	20.2	23.6	30.7	38.9	49.9	56.3	58.5	56.8	48.7	36.9	24.8	22.1
		MCDB	21.4	25.8	35.3	47.9	62.8	69.0	70.5	66.1	55.3	40.2	26.1	23.5
Mean Daily Temperature Range	5% DB	MDBR	16.1	19.6	22.8	20.7	22.3	22.5	21.5	20.7	18.6	12.6	13.8	16.2
		MCDBR	18.9	18.1	20.5	24.6	28.1	28.3	28.9	28.8	23.5	16.3	15.3	20.2
		MCWBR	17.1	15.6	14.2	14.1	13.1	12.1	12.3	13.1	13.4	11.0	13.6	18.4
	5% WB	MCDBR	17.9	17.8	19.7	23.0	25.8	24.4	24.3	25.3	20.3	14.7	14.6	20.0
		MCWBR	16.1	15.4	14.0	13.6	12.6	11.3	11.1	12.1	12.0	10.3	13.2	18.2
Clear-Sky Solar Irradiance	taub	0.195	0.240	0.258	0.337	0.367	0.376	0.384	0.383	0.308	0.264	0.186	0.173	
	taud	1.973	2.237	2.269	2.099	2.299	2.343	2.334	2.340	2.540	2.432	1.984	1.923	
	Ebn at Noon	132	228	271	263	267	267	260	249	253	219	133	68	
	Edh at Noon	9	18	26	39	36	35	34	31	21	15	9	4	
All-Sky Solar Radiation	RadAvg	70	317	875	1506	1716	1783	1549	1219	758	314	93	27	
	RadStd	4	22	50	80	86	108	104	123	80	45	11	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+3.89	-5.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	+3.78	N/A	N/A	N/A	N/A	N/A	N/A	+94	N/A

Nomenclature: See separate page