

DAWSON, YT, Canada

WMO: 719660

Lat: 64.0446N

Lon: 139.1268W

Elev: 1214

StdP: 14.06

Time Zone: -8.00 (NAP)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-53.6	-48.9	-63.0	0.1	-53.5	-57.5	0.2	-48.6	11.0	8.4	9.4	5.1	0.2	60	0.691

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.4	80.9	58.8	77.3	57.5	74.1	56.2	61.7	75.3	60.0	72.4	58.4	69.8	5.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.9	72.3	63.7	55.1	67.5	62.5	53.3	63.3	61.5	28.1	75.6	26.9	72.4	25.8	70.0	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.5	9.0	DB	-52.2	86.6	6.1	3.5	-56.6	89.1	-60.2	91.2	-63.6	93.1	-68.1	95.7	(4)
(5)			WB	-52.0	65.2	6.0	1.9	-56.4	66.5	-59.9	67.6	-63.3	68.6	-67.7	70.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	-14.2	-4.9	9.0	32.1	47.4	57.6	60.2	54.3	43.3	25.0	-0.2	-8.8	(6)
(7)		DBStd	29.42	20.02	16.34	15.41	10.11	7.37	5.23	4.25	5.78	6.86	11.07	16.36	17.02	(7)
(8)		HDD50	9820	1991	1537	1272	536	139	5	1	22	214	774	1505	1824	(8)
(9)		HDD65	14532	2456	1957	1737	986	545	228	156	333	651	1239	1955	2289	(9)
(10)		CDD50	778	0	0	0	0	59	233	317	156	13	0	0	0	(10)
(11)		CDD65	16	0	0	0	0	0	7	7	2	0	0	0	0	(11)
(12)		CDH74	732	0	0	0	0	57	260	288	127	0	0	0	0	(12)
(13)		CDH80	132	0	0	0	0	5	52	45	30	0	0	0	0	(13)
(14)	Wind	WSAvg	2.7	1.3	1.7	2.7	3.8	4.2	3.7	3.4	3.1	3.1	2.4	1.9	1.4	(14)
(15)	Precipitation	PrecAvg	12.8	0.7	0.6	0.4	0.4	0.9	1.5	1.9	1.6	1.4	1.3	1.0	0.9	(15)
(16)		PrecMax	17.2	1.6	1.4	1.6	1.0	2.2	2.0	3.7	3.3	2.8	2.8	2.2	1.9	(16)
(17)		PrecMin	9.7	0.1	0.1	0.0	0.0	0.2	0.4	0.7	0.4	0.2	0.5	0.4	0.2	(17)
(18)		PrecStd	2.4	0.4	0.4	0.4	0.3	0.6	0.5	0.8	0.7	0.8	0.7	0.5	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	36.4	46.9	64.0	80.0	86.0	84.7	84.0	67.3	53.1	33.1	32.1	(19)
MCWB			31.3	31.8	36.6	46.4	55.1	61.6	60.3	61.2	52.8	44.2	31.2	29.7	(20)	
2%		DB	23.2	27.0	41.7	57.4	74.5	80.5	80.4	77.4	63.2	46.0	27.4	22.0	(21)	
		MCWB	22.4	25.3	34.2	42.7	53.3	58.1	59.0	59.2	50.3	39.6	26.4	21.2	(22)	
5%		DB	16.0	20.9	36.6	53.2	70.0	76.6	77.2	72.1	60.0	41.1	23.4	17.4	(23)	
		MCWB	15.2	19.9	30.9	40.2	50.9	56.2	58.5	57.0	48.7	36.9	22.3	16.6	(24)	
10%		DB	10.7	15.8	31.7	49.4	65.0	73.2	73.9	67.7	56.6	37.3	19.8	12.8	(25)	
		MCWB	10.0	14.7	27.9	38.2	48.5	54.7	57.4	55.1	47.3	34.6	18.9	12.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.0	32.2	38.2	47.3	57.6	64.2	63.8	63.5	54.3	45.7	31.7	29.9	(27)
MCD B			32.4	36.3	44.5	63.3	74.2	79.4	77.8	78.3	63.2	50.7	32.8	31.7	(28)	
2%		WB	22.4	25.5	34.7	43.1	54.6	60.7	61.7	61.0	52.0	40.4	26.5	21.3	(29)	
		MCD B	23.3	27.2	40.8	55.5	71.2	74.9	74.9	74.2	60.1	44.6	27.4	22.0	(30)	
5%		WB	15.2	19.8	31.5	40.9	52.1	58.5	60.3	58.5	50.2	37.4	22.4	16.7	(31)	
		MCD B	16.0	21.0	36.2	51.5	66.9	71.4	72.6	68.8	58.0	40.6	23.3	17.3	(32)	
10%		WB	10.0	14.8	27.9	38.7	49.7	56.6	59.0	56.5	48.4	34.8	18.9	12.2	(33)	
		MCD B	10.7	15.7	31.8	48.4	63.1	69.3	70.6	65.3	55.0	37.1	19.7	12.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.8	19.1	29.6	26.3	26.3	26.4	24.4	23.8	21.7	14.7	13.3	13.4	(35)
MCD BR			17.2	22.9	28.9	29.8	34.6	34.3	32.6	31.9	27.7	18.5	13.9	16.7	(36)	
MCWBR			16.6	21.1	22.1	17.0	17.5	16.4	16.0	16.8	16.5	13.1	13.2	16.1	(37)	
5% WB		MCD BR	17.5	22.8	26.9	27.3	31.0	29.3	27.2	27.2	24.1	16.5	13.5	16.9	(38)	
		MCWBR	16.9	21.1	20.7	16.0	16.4	14.8	14.1	15.2	15.1	12.1	12.8	16.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.201	0.244	0.260	0.349	0.368	0.385	0.399	0.380	0.316	0.262	0.181	0.175	(40)	
taud		1.939	2.219	2.266	2.079	2.317	2.310	2.294	2.353	2.517	2.456	1.973	1.923	(41)		
Ebn at Noon		117	221	268	258	266	263	255	249	249	218	127	56	(42)		
Edh at Noon		9	17	26	40	35	36	36	30	21	14	8	3	(43)		
(44)	All-Sky Solar Radiation	RadAvg	64	310	880	1534	1747	1778	1531	1218	763	315	92	23	(44)	
(45)		RadStd	4	18	43	67	99	128	115	107	64	41	10	1	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+4.95	+5.71	N/A	N/A	N/A	N/A	N/A	+99	N/A
(47) Regional (3 neighbors)		N/A	+4.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page