

SHINGLE POINT, YT, Canada

WMO: 719680

Lat: 68.923N

Lon: 137.261W

Elev: 162

StdP: 14.61

Time Zone: -8.00 (NAP)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.1	-34.7	-40.8	0.5	-33.7	-39.7	0.6	-33.3	51.9	1.7	47.8	3.2	5.2	270	1.010

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	72.6	60.0	68.0	58.5	63.8	56.1	60.5	68.9	58.5	66.2	56.5	63.0	15.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.6	68.6	63.6	54.6	63.7	61.8	52.7	59.4	60.3	26.8	68.9	25.5	66.3	24.2	63.1	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.0	35.0	28.6	-42.0	79.3	4.4	3.7	-45.2	82.0	-47.8	84.1	-50.2	86.2	-53.5	88.9		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	-11.7	-9.8	-8.1	6.3	26.6	44.6	53.4	48.1	37.8	19.6	0.2	-8.7		
	DBStd	26.44	14.28	14.69	13.39	13.67	10.59	9.59	7.34	7.60	7.97	9.92	12.14	12.70		
	HDD50	12459	1913	1673	1802	1312	725	221	52	128	376	943	1495	1819		
	HDD65	17643	2378	2093	2267	1762	1189	613	362	525	817	1408	1945	2284		
	CDD50	294	0	0	0	0	1	58	157	70	8	0	0	0		
	CDD65	6	0	0	0	0	0	1	3	2	0	0	0	0		
	CDH74	67	0	0	0	0	0	16	38	13	0	0	0	0		
	CDH80	7	0	0	0	0	0	2	2	3	0	0	0	0		
(14) Wind	WSAvg	11.6	13.9	13.9	11.8	9.7	9.2	9.8	10.3	10.7	11.0	11.7	14.0	12.9		
(15) Precipitation	PrecAvg	10.2	0.3	0.3	0.3	0.4	0.5	0.9	1.5	2.1	1.3	1.2	0.6	0.4		
	PrecMax	16.5	1.3	0.9	1.1	1.1	2.0	3.9	3.0	3.9	3.4	3.2	1.7	1.3		
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.7	0.1	0.3	0.0	0.0		
	PrecStd	2.6	0.3	0.2	0.3	0.3	0.5	0.8	0.7	0.9	0.9	0.7	0.5	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	28.3	32.8	41.1	57.3	76.1	78.3	74.7	64.8	45.3	34.0	27.3		
		MCWB	29.1	27.2	30.7	36.3	48.0	61.9	60.9	61.8	54.2	42.9	29.1	26.1		
	2%	DB	24.0	23.3	24.6	36.5	49.3	70.2	73.9	68.0	57.9	38.3	27.8	20.8		
		MCWB	22.8	21.9	22.9	33.3	43.9	58.6	59.9	58.4	50.5	35.8	25.3	19.6		
	5%	DB	16.5	18.0	17.7	31.4	43.6	65.1	69.5	63.3	52.7	34.6	22.5	15.1		
		MCWB	15.6	16.7	16.3	29.3	40.0	55.1	59.7	55.7	47.4	33.1	21.2	14.2		
	10%	DB	8.7	12.9	11.6	25.7	39.1	59.5	65.4	59.2	48.5	31.5	17.2	9.2		
		MCWB	8.0	11.8	10.4	23.8	36.5	52.7	57.5	53.2	44.9	30.2	15.6	8.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.4	27.5	32.8	35.6	47.1	62.1	62.9	61.0	54.4	39.4	25.3	25.1		
		MCDB	29.8	28.2	34.5	38.7	53.7	72.2	71.6	70.8	64.4	42.2	27.4	26.3		
	2%	WB	23.5	23.4	27.8	32.2	43.0	58.3	61.2	57.8	50.7	36.6	21.6	20.7		
		MCDB	24.7	24.6	29.6	34.7	47.5	67.8	69.4	64.2	56.7	38.7	23.0	21.8		
	5%	WB	17.7	19.5	22.0	28.0	38.4	55.9	59.8	55.6	47.7	34.7	16.4	16.2		
		MCDB	18.4	21.0	23.6	29.7	40.9	63.9	67.7	60.4	52.2	36.5	17.5	17.1		
	10%	WB	11.4	14.5	15.5	23.1	35.2	53.1	58.0	53.1	45.6	31.0	13.4	10.1		
		MCDB	12.1	15.7	17.0	24.8	37.0	60.0	65.3	57.4	49.2	32.0	14.7	10.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	12.0	12.3	13.1	11.3	14.5	14.8	12.8	9.6	8.7	10.9	11.4		
		MCDBR	19.9	16.6	18.3	16.8	19.0	24.8	22.9	20.7	17.5	10.9	13.1	16.9		
		MCWBR	15.9	13.9	15.7	15.6	12.7	13.8	13.0	13.4	10.8	9.9	10.6	15.9		
	5% WB	MCDBR	16.9	15.0	16.3	17.6	15.6	21.9	20.2	19.1	15.4	10.5	10.0	15.9		
		MCWBR	16.4	14.7	15.2	16.1	11.9	14.3	12.6	12.8	10.5	9.8	9.9	15.7		
(40) Clear-Sky Solar Irradiance	taub		0.172	0.213	0.249	0.315	0.350	0.355	0.377	0.342	0.299	0.238	0.157	N/A		
	taud		1.893	2.101	2.207	2.077	2.121	2.316	2.365	2.481	2.510	2.187	1.929	N/A		
	Ebn at Noon		19	185	252	258	262	266	255	253	237	167	20	0		
	Edh at Noon		2	13	23	36	40	34	31	25	18	12	1	0		
(44) All-Sky Solar Radiation	RadAvg		7	145	666	1380	1866	2017	1544	1013	554	189	23	0		
	RadStd		1	10	34	72	141	163	126	90	55	22	2	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.30	+1.75	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		+1.76	+2.57	+3.26	N/A	N/A	N/A	-655	-670	N/A	N/A

Nomenclature: See separate page