

SHINGLE POINT, YT, Canada

WMO: 719680

Lat: 68.923N

Lon: 137.261W

Elev: 49

StdP: 100.73

Time Zone: -8.00 (NAP)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -38.9	(c) -37.0	(d) -40.4	(e) 0.1	(f) -36.5	(g) -39.8	(h) 0.1	(i) -36.3	(j) 23.2	(k) -16.9	(l) 21.4	(m) -16.0	(n) 2.3	(o) 270	(p) 1.010

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.2	(c) 22.5	(d) 15.6	(e) 20.0	(f) 14.7	(g) 17.7	(h) 13.4	(i) 15.8	(j) 20.5	(k) 14.7	(l) 19.0	(m) 13.6	(n) 17.2	(o) 7.0	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	9.8	17.5	12.5	9.1	16.6	11.5	8.5	15.7	44.5	20.5	41.3	19.1	38.3	17.3	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.3	(b) 15.6	(c) 12.8	(e) -41.1	(f) 26.3	(g) 2.4	(h) 2.1	(i) -42.9	(j) 27.8	(k) -44.3	(l) 29.0	(m) -45.7	(n) 30.1	(o) -47.5	(p) 31.6		
(4) 18.3	(5) 15.6	(6) 12.8	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-8.5	-24.3	-23.2	-22.3	-14.3	-3.0	7.0	11.9	9.0	3.2	-6.9	-17.7	-22.6	
	DBStd	14.69	7.94	8.16	7.44	7.59	5.88	5.33	4.08	4.22	4.43	5.51	6.74	7.05	
	HDD10.0	6922	1063	929	1001	729	403	123	29	71	209	524	831	1011	
	HDD18.3	9802	1321	1163	1259	979	661	341	201	292	454	782	1081	1269	
	CDD10.0	163	0	0	0	0	1	32	87	39	4	0	0	0	
	CDD18.3	3	0	0	0	0	0	1	2	1	0	0	0	0	
	CDH23.3	37	0	0	0	0	0	9	21	7	0	0	0	0	
	CDH26.7	4	0	0	0	0	0	1	1	2	0	0	0	0	
Wind	WSAvg	5.2	6.2	6.2	5.3	4.3	4.1	4.4	4.6	4.8	4.9	5.2	6.2	5.7	
Precipitation	PrecAvg	260	7	7	8	10	13	24	37	54	34	31	15	9	
	PrecMax	418	32	22	28	27	50	100	77	99	86	81	43	34	
	PrecMin	122	0	0	0	0	0	0	8	18	2	7	0	0	
	PrecStd	67	7	6	7	7	13	20	19	24	23	19	12	8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.7	-2.0	0.5	5.0	14.1	24.5	25.7	23.7	18.2	7.4	1.1	-2.6	
		MCWB	-1.6	-2.7	-0.7	2.4	8.9	16.6	16.1	16.5	12.4	6.0	-1.6	-3.3	
	2%	DB	-4.4	-4.8	-4.1	2.5	9.6	21.2	23.3	20.0	14.4	3.5	-2.3	-6.2	
		MCWB	-5.1	-5.6	-5.0	0.7	6.6	14.8	15.5	14.7	10.3	2.1	-3.7	-6.9	
	5%	DB	-8.6	-7.8	-8.0	-0.3	6.4	18.4	20.8	17.4	11.5	1.4	-5.3	-9.4	
		MCWB	-9.1	-8.5	-8.7	-1.5	4.5	12.8	15.4	13.2	8.6	0.6	-6.0	-9.9	
	10%	DB	-13.0	-10.6	-11.4	-3.5	3.9	15.3	18.5	15.1	9.2	-0.3	-8.2	-12.6	
		MCWB	-13.3	-11.2	-12.0	-4.5	2.5	11.5	14.1	11.8	7.2	-1.0	-9.1	-13.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.0	-2.5	0.4	2.0	8.4	16.7	17.1	16.1	12.5	4.1	-3.7	-3.9
			MCDB	-1.2	-2.1	1.4	3.7	12.0	22.3	22.0	21.6	18.0	5.7	-2.5	-3.1
2%		WB	-4.7	-4.8	-2.3	0.1	6.1	14.6	16.2	14.3	10.4	2.6	-5.8	-6.3	
		MCDB	-4.1	-4.1	-1.3	1.5	8.6	19.9	20.8	17.9	13.7	3.7	-5.0	-5.7	
5%		WB	-8.0	-7.0	-5.6	-2.2	3.5	13.3	15.4	13.1	8.7	1.5	-8.7	-8.8	
		MCDB	-7.6	-6.1	-4.7	-1.3	5.0	17.7	19.9	15.8	11.2	2.5	-8.0	-8.3	
10%		WB	-11.5	-9.7	-9.1	-5.0	1.8	11.7	14.4	11.7	7.5	-0.6	-10.3	-12.2	
		MCDB	-11.0	-9.1	-8.3	-4.0	2.8	15.5	18.5	14.1	9.6	0.0	-9.6	-11.8	
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.7	6.8	7.3	6.3	8.0	8.2	7.1	5.3	4.8	6.1	6.3	
		MCDBR	11.1	9.2	10.2	9.3	10.5	13.8	12.7	11.5	9.7	6.0	7.3	9.4	
		MCWBR	8.8	7.7	8.7	8.6	7.1	7.7	7.2	7.5	6.0	5.5	5.9	8.8	
	5% WB	MCDBR	9.4	8.4	9.1	9.8	8.6	12.2	11.2	10.6	8.5	5.9	5.6	8.8	
		MCWBR	9.1	8.2	8.5	8.9	6.6	8.0	7.0	7.1	5.8	5.4	5.5	8.7	
Clear-Sky Solar Irradiance	taub	0.172	0.213	0.249	0.315	0.350	0.355	0.377	0.342	0.299	0.238	0.157	N/A		
	taud	1.893	2.101	2.207	2.077	2.121	2.316	2.365	2.481	2.510	2.187	1.929	N/A		
	Ebn at Noon	60	584	793	814	826	839	804	799	747	528	62	0		
	Edh at Noon	5	41	73	115	125	107	99	79	58	37	4	0		
All-Sky Solar Radiation	RadAvg	0.02	0.46	2.10	4.35	5.88	6.36	4.87	3.19	1.75	0.60	0.07	0.00		
	RadStd	0.00	0.03	0.11	0.23	0.45	0.52	0.40	0.28	0.17	0.07	0.01	0.00		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) +0.72	(e) +0.97	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (11 neighbors)		+0.98	+1.43	+1.81	N/A	N/A	-364	-372	N/A	N/A

Nomenclature: See separate page