

GRISE FIORD, NU, Canada

WMO: 719710

Lat: 76.423N

Lon: 82.902W

Elev: 45

StdP: 100.79

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.6	-39.2	-45.1	0.0	-40.5	-43.5	0.1	-38.9	11.6	-19.1	8.4	-17.6	0.8	50	1.045

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.1	10.7	6.9	9.2	6.1	7.9	5.3	7.3	10.0	6.4	8.8	5.6	7.6	6.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
5.3	5.6	7.6	4.6	5.3	6.9	3.8	5.0	6.2	23.4	10.3	21.6	8.8	19.8	7.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	8.6	6.5	-42.3	13.5	2.2	1.8	-43.9	14.8	-45.2	15.8	-46.4	16.8	-48.0	18.1		
(5)			-42.3	9.3	2.2	1.5	-43.9	10.3	-45.2	11.2	-46.4	12.0	-48.0	13.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.4	-28.8	-31.0	-28.7	-20.4	-8.0	1.4	4.5	3.7	-1.6	-10.1	-18.3	-24.7	(6)
(7)		DBStd	13.80	5.83	5.84	6.81	5.42	4.92	2.59	2.47	2.33	2.99	5.07	5.97	6.51	(7)
(8)		HDD10.0	8544	1203	1148	1199	913	559	258	172	195	348	623	848	1077	(8)
(9)		HDD18.3	11585	1462	1382	1457	1163	817	508	429	453	598	881	1098	1336	(9)
(10)		CDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	1.9	1.5	1.2	1.3	1.3	1.6	1.8	1.9	2.0	3.1	3.1	2.2	1.7	(14)
(15)	Precipitation	PrecAvg	177	6	4	9	10	10	17	30	37	19	17	10	9	(15)
(16)		PrecMax	260	17	12	33	31	24	75	73	94	59	43	23	34	(16)
(17)		PrecMin	93	1	0	0	2	3	0	1	4	4	3	2	1	(17)
(18)		PrecStd	46	4	3	8	6	5	15	18	22	12	11	6	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.1	-9.3	-1.0	-5.8	2.5	12.4	13.5	11.6	5.9	1.2	-0.8	-7.9	(19)
(20)			MCWB	-8.3	-10.2	-2.7	-7.2	-0.3	6.5	8.0	7.5	2.7	-1.0	-2.7	-9.1	(20)
(21)		2%	DB	-13.9	-16.0	-12.3	-8.1	0.5	8.6	11.3	9.7	4.2	-0.7	-4.1	-10.5	(21)
(22)			MCWB	-14.5	-16.6	-13.2	-9.2	-1.4	4.8	7.2	6.3	1.6	-2.5	-5.8	-11.3	(22)
(23)		5%	DB	-17.3	-18.8	-16.0	-10.1	-0.5	6.7	9.9	8.3	3.2	-1.9	-7.5	-13.1	(23)
(24)			MCWB	-17.9	-19.3	-16.5	-11.2	-2.1	3.6	6.6	5.6	1.1	-3.3	-8.5	-13.8	(24)
(25)		10%	DB	-20.3	-22.1	-19.1	-12.2	-1.4	4.9	8.7	7.0	2.4	-3.1	-10.2	-15.0	(25)
(26)			MCWB	-20.7	-22.4	-19.6	-13.1	-2.8	2.6	6.0	5.0	0.6	-4.4	-11.0	-15.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.4	-10.0	-2.3	-6.8	0.1	6.8	8.6	8.2	3.1	-0.7	-2.6	-8.8	(27)
(28)			MCDWB	-8.2	-9.2	-0.6	-5.7	1.4	11.1	11.5	10.9	5.1	0.8	-0.9	-8.0	(28)
(29)		2%	WB	-14.6	-16.5	-12.9	-9.2	-1.1	5.0	7.6	7.0	2.2	-2.1	-5.8	-11.4	(29)
(30)			MCDWB	-13.8	-16.0	-12.4	-8.3	0.2	8.2	10.7	9.0	3.4	-1.0	-4.4	-10.5	(30)
(31)		5%	WB	-17.8	-19.3	-16.6	-11.1	-1.9	3.8	6.8	6.0	1.6	-3.2	-8.4	-13.8	(31)
(32)			MCDWB	-17.4	-18.8	-16.0	-10.2	-0.7	6.5	9.5	7.8	2.8	-2.0	-7.4	-13.1	(32)
(33)		10%	WB	-20.7	-22.4	-19.6	-13.1	-2.8	2.8	6.1	5.2	0.8	-4.5	-11.1	-15.6	(33)
(34)			MCDWB	-20.3	-22.0	-19.1	-12.3	-1.5	4.7	8.5	6.6	2.1	-3.2	-10.3	-15.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.5	6.5	6.9	7.5	6.0	4.4	5.1	3.9	3.1	4.3	5.6	6.0	(35)
(36)			MCDBR	9.9	9.2	9.5	8.3	6.0	7.5	7.5	5.9	3.7	4.8	7.6	7.2	(36)
(37)			MCWBR	9.3	8.7	8.9	7.4	4.9	4.5	4.6	3.6	2.5	4.0	6.7	6.6	(37)
(38)		5% WB	MCDBR	9.9	9.1	9.5	8.5	5.8	6.9	7.0	5.3	3.4	4.8	7.5	7.1	(38)
(39)			MCWBR	9.3	8.7	8.9	7.7	4.8	4.4	4.6	3.6	2.4	4.2	6.6	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.169	0.240	0.303	0.320	0.344	0.328	0.325	0.260	0.186	N/A	N/A	(40)	
(41)		taud	N/A	1.840	2.028	1.972	2.052	2.141	2.335	2.357	2.304	1.897	N/A	N/A	(41)	
(42)		Ebn at Noon	0	149	620	738	803	800	807	741	634	100	0	0	(42)	
(43)		Edh at Noon	0	11	59	107	118	114	90	75	47	9	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.06	1.22	4.10	6.84	7.22	5.58	3.19	1.29	0.21	0.00	0.00	(44)	
(45)		RadStd	0.00	0.01	0.06	0.12	0.28	0.50	0.48	0.28	0.10	0.02	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page