

CORNER BROOK, NL, Canada

WMO: 719730

Lat: 48.930N

Lon: 57.920W

Elev: 498

StdP: 14.43

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.4	4.3	-4.8	4.3	1.7	-0.8	5.4	5.9	23.5	21.9	21.1	19.7	6.5	130	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	79.2	65.4	76.4	64.2	73.7	62.9	68.9	75.3	66.9	72.9	65.1	71.0	9.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.3	98.8	72.9	64.5	92.4	70.9	62.6	86.5	69.1	33.3	75.5	31.8	73.0	30.4	71.0	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.3	17.7	15.6	DB	-5.7	85.5	5.9	2.2	-10.0	87.1	-13.4	88.4	-16.7	89.7	-21.0	91.3	
			WB	-6.3	72.0	5.8	2.1	-10.4	73.5	-13.8	74.7	-17.1	75.9	-21.3	77.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	20.7	19.9	25.1	34.9	45.2	54.9	63.4	62.9	54.8	44.5	35.4	26.5	(6)
	DBStd	16.86	8.24	9.35	8.77	6.95	6.64	7.03	5.53	5.20	6.66	6.62	7.48	7.71	(7)
	HDD50	4586	909	844	771	453	181	30	1	1	27	199	442	728	(8)
	HDD65	8924	1374	1264	1236	902	613	309	96	102	310	637	888	1193	(9)
	CDD50	1231	0	0	0	1	33	178	416	399	172	27	5	0	(10)
	CDD65	95	0	0	0	0	0	7	46	36	6	0	0	0	(11)
	CDH74	536	0	0	0	0	4	60	272	178	22	0	0	0	(12)
	CDH80	54	0	0	0	0	0	6	30	17	1	0	0	0	(13)
	WSAvg	6.7	7.5	7.5	7.5	7.3	6.6	6.3	6.0	5.7	6.2	6.4	6.7	7.1	(14)
	PrecAvg	45.2	4.3	3.4	3.1	2.6	2.9	3.1	3.4	4.3	4.2	4.5	4.4	4.8	(15)
(16) Precipitation	PrecMax	53.7	8.0	6.3	7.3	7.0	6.1	6.7	7.2	9.2	6.9	7.8	7.6	9.0	(16)
	PrecMin	28.4	1.9	1.4	0.9	0.5	1.0	1.2	1.7	0.9	1.5	1.5	1.6	2.1	(17)
	PrecStd	5.9	1.4	1.3	1.4	1.4	1.4	1.4	1.4	2.0	1.6	1.6	1.5	1.7	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.4	49.4	49.9	59.5	72.4	79.5	83.4	82.2	76.9	67.7	61.8	51.2	(19)
		MCWB	48.9	45.7	43.8	51.2	56.8	62.6	67.9	68.2	66.4	60.3	58.0	48.2	(20)
	2%	DB	43.5	42.1	45.1	54.0	67.1	75.1	79.9	78.6	72.5	62.8	56.5	45.2	(21)
		MCWB	41.9	39.9	40.6	46.8	54.6	61.2	65.5	66.1	64.0	56.8	53.2	42.8	(22)
	5%	DB	36.6	36.5	41.0	49.6	62.2	71.6	77.1	75.5	69.0	58.9	51.5	40.4	(23)
		MCWB	34.8	34.3	37.1	43.2	51.9	59.6	64.3	64.5	62.5	54.1	48.7	38.4	(24)
	10%	DB	32.6	32.8	37.1	45.7	58.2	68.0	74.2	72.7	66.0	55.2	46.8	36.8	(25)
		MCWB	31.1	31.0	34.0	40.3	50.3	58.5	63.4	63.2	60.3	51.1	44.3	35.1	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.8	46.2	46.2	52.9	60.3	68.0	71.5	71.1	69.0	62.2	58.6	48.7	(27)
		MCDB	51.0	49.1	48.9	57.7	68.2	74.7	80.5	78.2	74.1	65.5	61.6	50.8	(28)
	2%	WB	42.1	40.0	41.3	48.1	56.7	64.4	69.1	68.6	66.0	58.1	53.5	43.0	(29)
		MCDB	43.6	41.8	44.2	52.6	64.1	69.9	75.9	75.2	70.5	61.9	56.2	44.9	(30)
	5%	WB	35.0	34.2	37.2	44.2	53.7	61.9	67.0	66.7	63.5	54.7	49.1	38.4	(31)
		MCDB	36.5	36.0	40.6	48.6	59.9	69.3	73.4	72.8	67.9	58.3	51.4	40.0	(32)
	10%	WB	31.2	31.1	34.2	40.7	50.4	59.2	65.2	64.7	60.7	51.4	44.4	35.3	(33)
		MCDB	32.6	32.7	36.8	44.7	57.7	66.6	71.6	70.7	65.4	54.9	46.7	36.7	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	12.3	13.9	15.5	14.8	17.9	18.1	17.4	16.4	15.8	12.9	10.8	10.2	(35)
		MCDBR	18.1	18.2	20.6	21.1	26.2	24.2	22.3	20.7	19.6	18.9	17.9	16.2	(36)
		MCWBR	17.5	16.4	16.9	15.1	16.0	13.4	11.7	11.4	12.8	14.6	16.6	15.4	(37)
	5% WB	MCDBR	18.4	17.8	18.4	19.7	22.5	19.8	17.6	17.3	17.4	17.6	17.8	16.0	(38)
		MCWBR	17.8	16.5	15.8	15.5	15.6	12.7	11.1	11.1	13.1	14.7	17.0	15.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.296	0.327	0.328	0.364	0.368	0.373	0.410	0.391	0.364	0.334	0.312	0.303	(40)
	taud		2.276	2.169	2.304	2.320	2.396	2.402	2.338	2.385	2.457	2.498	2.459	2.291	(41)
	Ebn at Noon		239	255	280	280	283	281	268	269	266	256	236	218	(42)
	Edh at Noon		23	33	34	37	36	36	38	35	29	24	20	20	(43)
(44) All-Sky Solar Radiation	RadAvg		253	477	888	1264	1568	1656	1624	1395	1043	642	322	191	(44)
	RadStd		27	61	85	142	110	167	131	88	82	47	35	20	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	+2.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	+2.02	N/A	+0.61	+0.76	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page