

CORNER BROOK, NL, Canada

WMO: 719730

Lat: 48.930N

Lon: 57.920W

Elev: 152

StdP: 99.51

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.5	-15.4	-20.5	0.6	-16.8	-18.2	0.8	-14.5	10.5	-5.6	9.4	-6.8	2.9	130	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	26.2	18.6	24.7	17.9	23.2	17.2	20.5	24.1	19.4	22.7	18.4	21.7	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.1	22.7	18.0	13.2	21.6	17.0	12.4	20.6	59.7	24.1	56.0	22.8	52.8	21.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.1	7.9	7.0	DB	-21.0	29.7	3.3	1.2	-23.3	30.6	-25.2	31.3	-27.0	32.0	-29.4	32.9	(4)
(5)			WB	-21.3	22.2	3.2	1.2	-23.6	23.0	-25.5	23.7	-27.3	24.4	-29.6	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-6.3	-6.7	-3.8	1.6	7.3	12.7	17.4	17.1	12.7	6.9	1.9	-3.1	(6)	
	DBStd	9.37	4.58	5.20	4.87	3.86	3.69	3.91	3.07	2.89	3.70	3.68	4.16	4.28	(7)	
	HDD10.0	2548	505	469	428	252	101	17	1	1	15	111	246	404	(8)	
	HDD18.3	4958	763	702	687	501	341	172	53	57	172	354	493	663	(9)	
	CDD10.0	684	0	0	0	1	18	99	231	222	96	15	3	0	(10)	
	CDD18.3	53	0	0	0	0	0	4	26	20	3	0	0	0	(11)	
	CDH23.3	298	0	0	0	0	2	33	151	99	12	0	0	0	(12)	
	CDH26.7	30	0	0	0	0	0	3	17	9	1	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.3	3.3	3.3	3.3	2.9	2.8	2.7	2.6	2.8	2.9	3.0	3.2	(14)	
(15) Precipitation	PrecAvg	1149	110	87	80	67	74	78	87	109	106	115	112	123	(15)	
	PrecMax	1365	202	160	186	178	156	169	182	234	175	197	192	229	(16)	
	PrecMin	721	48	35	24	13	25	30	44	24	38	39	40	54	(17)	
	PrecStd	151	36	34	35	35	35	35	36	50	40	41	37	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	9.7	9.9	15.3	22.5	26.4	28.6	27.9	24.9	19.8	16.5	10.7	(19)	
		MCWB	9.4	7.6	6.6	10.6	13.8	17.0	19.9	20.1	19.1	15.7	14.4	9.0	(20)	
	2%	DB	6.4	5.6	7.3	12.2	19.5	23.9	26.6	25.9	22.5	17.1	13.6	7.3	(21)	
		MCWB	5.5	4.4	4.8	8.2	12.6	16.2	18.6	18.9	17.8	13.8	11.8	6.0	(22)	
	5%	DB	2.6	2.5	5.0	9.8	16.8	22.0	25.0	24.2	20.6	14.9	10.8	4.6	(23)	
		MCWB	1.6	1.3	2.9	6.2	11.1	15.3	18.0	18.1	16.9	12.3	9.3	3.6	(24)	
	10%	DB	0.4	0.4	2.9	7.6	14.6	20.0	23.4	22.6	18.9	12.9	8.2	2.7	(25)	
		MCWB	-0.5	-0.6	1.1	4.6	10.2	14.7	17.5	17.3	15.7	10.6	6.8	1.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	7.9	7.9	11.6	15.7	20.0	21.9	21.7	20.6	16.8	14.8	9.3	(27)	
		MCDB	10.6	9.5	9.4	14.3	20.1	23.7	27.0	25.7	23.4	18.6	16.4	10.4	(28)	
	2%	WB	5.6	4.5	5.2	9.0	13.7	18.0	20.6	20.4	18.9	14.5	11.9	6.1	(29)	
		MCDB	6.4	5.4	6.8	11.5	17.8	21.1	24.4	24.0	21.4	16.6	13.5	7.2	(30)	
	5%	WB	1.7	1.2	2.9	6.8	12.0	16.6	19.5	19.3	17.5	12.6	9.5	3.5	(31)	
		MCDB	2.5	2.2	4.8	9.2	15.5	20.7	23.0	22.7	20.0	14.6	10.8	4.5	(32)	
	10%	WB	-0.4	-0.5	1.2	4.8	10.2	15.1	18.5	18.2	16.0	10.8	6.9	1.8	(33)	
		MCDB	0.3	0.4	2.7	7.1	14.3	19.2	22.0	21.5	18.5	12.7	8.2	2.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.7	8.6	8.2	10.0	10.1	9.7	9.1	8.8	7.2	6.0	5.7	(35)	
		MCDBR	10.1	10.1	11.5	11.7	14.6	13.5	12.4	11.5	10.9	10.5	9.9	9.0	(36)	
	5% WB	MCWBR	9.7	9.1	9.4	8.4	8.9	7.5	6.5	6.3	7.1	8.1	9.2	8.5	(37)	
		MCWBR	10.2	9.9	10.2	10.9	12.5	11.0	9.8	9.6	9.7	9.8	9.9	8.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.296	0.327	0.328	0.364	0.368	0.373	0.410	0.391	0.364	0.334	0.312	0.303	(40)	
		taud	2.276	2.169	2.304	2.320	2.396	2.402	2.338	2.385	2.457	2.498	2.459	2.291	(41)	
	Edn at Noon	Edn at Noon	752	804	882	883	893	887	846	847	838	807	743	686	(42)	
		Edh at Noon	73	103	107	117	113	113	119	109	92	75	62	64	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.80	1.50	2.80	3.98	4.94	5.22	5.12	4.40	3.29	2.02	1.01	0.60	(44)	
	RadStd	RadStd	0.09	0.19	0.27	0.45	0.35	0.53	0.41	0.28	0.26	0.15	0.11	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	+1.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)		N/A	N/A	+1.12	N/A	+0.34	+0.42	N/A	N/A	N/A	N/A

Nomenclature: See separate page