

RABBIT KETTLE, NT, Canada

WMO: 719800

Lat: 61.960N

Lon: 127.210W

Elev: 618

StdP: 94.12

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -45.4	(c) -42.2	(d) -50.7	(e) 0.0	(f) -45.4	(g) -47.0	(h) 0.0	(i) -42.1	(j) 4.6	(k) -15.0	(l) 3.5	(m) -16.3	(n) 0.2	(o) 170	(p) 0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	27.6	14.8	25.3	13.8	23.3	13.1	15.7	24.5	14.9	22.9	14.0	21.3	2.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.8	9.9	16.5	11.9	9.3	15.9	11.0	8.8	15.6	46.0	24.4	43.5	23.0	41.2	21.5	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.4	3.8	-47.4	31.2	3.0	2.6	-49.5	33.1	-51.3	34.7	-53.0	36.2	-55.2	38.1
			-46.7	17.6	2.9	1.2	-48.8	18.4	-50.5	19.1	-52.1	19.8	-54.2	20.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.7	-25.4	-20.4	-11.7	-0.2	7.9	13.8	15.8	13.4	6.9	-2.4	-18.4	-25.2
	DBStd	16.23	8.71	7.19	8.23	5.39	4.18	3.04	2.40	3.10	3.34	5.13	7.66	8.18
	HDD10.0	5458	1098	851	673	306	92	4	1	6	101	386	851	1091
	HDD18.3	8068	1356	1084	931	556	324	140	85	156	343	643	1101	1349
	CDD10.0	441	0	0	0	0	26	118	179	111	8	0	0	0
	CDD18.3	11	0	0	0	0	0	4	6	2	0	0	0	0
	CDH23.3	449	0	0	0	0	26	128	190	103	2	0	0	0
	CDH26.7	102	0	0	0	0	2	34	45	21	0	0	0	0
(14) Wind	WSAvg	1.2	0.3	0.7	1.3	1.8	1.9	1.8	1.6	1.5	1.4	1.0	0.5	0.4
(15) Precipitation	PrecAvg	487	34	25	24	18	32	64	75	60	49	38	38	31
	PrecMax	609	52	42	45	36	59	113	147	104	95	59	58	62
	PrecMin	381	11	8	8	7	11	30	25	31	16	19	19	11
	PrecStd	58	11	9	10	8	13	22	26	18	17	11	10	12
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.9	-0.9	10.9	15.1	26.1	30.6	30.9	29.2	20.7	12.2	0.4	-1.4
		MCWB	-2.6	-3.4	4.5	6.4	11.7	15.7	15.8	15.6	11.7	6.5	-0.9	-2.0
	2%	DB	-7.2	-3.8	6.6	12.3	23.4	26.8	27.6	26.2	17.7	8.1	-3.9	-8.2
		MCWB	-7.8	-5.3	1.5	4.7	11.3	14.1	14.9	14.7	9.7	4.0	-4.8	-8.6
	5%	DB	-11.0	-6.7	3.9	10.6	20.3	24.1	25.3	23.5	15.7	6.0	-6.2	-11.0
		MCWB	-11.4	-7.9	-0.6	3.8	10.1	12.8	14.3	13.8	9.2	2.9	-6.8	-11.3
	10%	DB	-14.1	-9.2	1.0	9.0	17.5	22.0	23.3	20.9	13.7	3.9	-8.4	-14.1
		MCWB	-14.6	-10.1	-2.3	2.8	8.8	12.1	13.8	12.9	8.2	1.6	-8.9	-14.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.1	-2.9	4.4	6.7	13.1	16.7	16.9	16.6	12.7	7.3	-0.8	-2.5
		MCDB	-1.1	-1.6	10.8	13.4	23.8	27.0	26.4	25.9	19.1	11.4	0.5	-1.0
	2%	WB	-7.8	-5.4	1.6	5.2	11.7	15.2	15.8	15.2	10.7	4.4	-4.8	-8.5
		MCDB	-7.3	-3.9	6.5	11.3	21.7	24.0	24.3	23.8	15.7	7.1	-4.0	-8.1
	5%	WB	-11.4	-7.8	-0.5	4.1	10.6	13.9	15.1	14.3	9.7	3.1	-6.8	-11.3
		MCDB	-11.1	-6.7	3.2	9.7	19.5	21.4	23.1	22.0	14.5	5.8	-6.2	-10.9
	10%	WB	-14.6	-10.1	-2.2	3.2	9.3	12.8	14.3	13.4	8.7	1.8	-8.9	-14.4
		MCDB	-14.2	-9.2	1.0	8.3	16.9	19.6	21.6	20.0	13.0	3.7	-8.3	-14.0
(35) Mean Daily Temperature Range	MDBR		9.5	14.5	18.1	14.6	14.4	13.4	13.5	13.1	11.8	8.5	9.0	8.0
	5% DB	MCDBR	10.6	15.8	18.3	16.5	20.1	18.3	18.6	19.1	15.5	10.8	8.9	8.7
		MCWBR	10.1	14.3	13.1	9.5	9.2	7.2	7.4	8.3	8.3	7.0	8.2	8.6
	5% WB	MCDBR	10.3	14.8	17.6	14.7	18.6	15.5	15.6	16.3	13.7	10.2	8.7	8.7
		MCWBR	9.9	13.4	12.6	8.6	8.5	6.3	6.7	7.3	7.6	6.7	8.0	8.5
(40) Clear-Sky Solar Irradiance	taub		0.197	0.252	0.272	0.329	0.348	0.380	0.383	0.363	0.314	0.269	0.203	0.169
	taud		2.069	2.200	2.205	2.072	2.207	2.297	2.327	2.402	2.475	2.298	2.044	1.923
	Ebn at Noon		529	728	845	849	866	843	829	818	802	695	491	352
	Edh at Noon		34	63	91	129	124	116	110	94	72	57	33	21
(44) All-Sky Solar Radiation	RadAvg		0.28	1.08	2.77	4.77	5.58	5.16	4.85	3.93	2.44	1.13	0.40	0.14
	RadStd		0.02	0.09	0.17	0.25	0.29	0.35	0.34	0.26	0.23	0.09	0.04	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page