

PRIDDIS ROTHNEY OBSERVATORY, AB, Canada

WMO: 719825

Lat: 50.8691N

Lon: 114.2917W

Elev: 4170

StdP: 12.61

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.3	-11.7	-21.4	2.0	-16.0	-16.5	2.6	-11.0	28.5	37.5	23.6	36.7	6.4	200	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	81.4	58.9	78.3	58.2	75.3	56.9	62.4	74.5	60.7	74.1	59.1	71.4	8.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.9	83.6	67.8	55.6	76.9	66.2	53.7	71.8	64.4	30.2	74.7	28.9	74.1	27.7	71.6	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.8	19.6	16.5	-23.1	88.0	5.6	4.2	-27.2	91.1	-30.5	93.5	-33.7	95.9	-37.8	99.0		
(5)			-23.4	67.0	5.6	3.1	-27.4	69.3	-30.7	71.1	-33.8	72.8	-37.9	75.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.9	23.4	18.7	28.4	38.5	48.5	55.4	61.4	60.3	51.8	41.3	28.1	21.4		
	DBStd	18.56	14.93	15.79	14.23	9.23	8.57	6.01	5.58	6.27	9.47	9.36	13.20	13.79		
	HDD50	4815	823	877	672	357	134	16	1	5	91	293	659	887		
	HDD65	9221	1288	1297	1136	794	514	293	138	169	401	734	1106	1351		
	CDD50	1129	0	0	1	13	86	179	354	325	145	24	2	0		
	CDD65	62	0	0	0	0	1	6	25	25	5	0	0	0		
	CDH74	919	0	0	0	4	35	74	362	338	105	1	0	0		
	CDH80	163	0	0	0	0	1	10	70	69	13	0	0	0		
	WSAvg	8.0	8.0	7.8	8.3	8.8	8.3	8.2	7.8	7.3	7.4	8.2	8.0	7.8		
	PrecAvg	23.5	1.1	1.0	1.4	1.9	3.1	4.2	2.4	2.4	2.0	1.3	1.3	1.1		
(15) Precipitation	PrecMax	36.7	2.0	1.5	3.5	3.6	5.7	14.9	6.3	5.2	5.7	2.4	3.2	2.5		
	PrecMin	16.0	0.4	0.2	0.6	1.1	0.8	0.7	0.6	0.4	0.2	0.2	0.1	0.4		
	PrecStd	4.3	0.4	0.4	0.7	0.7	1.4	2.7	1.5	1.1	1.3	0.6	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	53.9	58.6	72.1	78.2	81.4	86.0	85.8	82.0	70.0	62.4	50.6		
		MCWB	40.3	39.5	42.0	48.4	52.8	60.5	59.3	59.2	55.3	49.4	43.9	36.9		
	2%	DB	48.5	47.7	53.8	64.3	73.7	75.6	81.4	81.0	76.9	64.6	53.6	46.6		
		MCWB	37.0	36.5	40.3	45.7	51.9	57.0	60.0	58.8	55.5	48.1	41.5	35.4		
	5%	DB	45.5	43.3	49.7	58.5	69.3	71.8	78.1	77.7	73.0	59.2	48.5	42.9		
		MCWB	35.3	33.7	37.7	42.7	50.6	55.7	59.9	58.3	54.3	45.5	38.4	33.6		
	10%	DB	42.4	39.2	45.6	53.2	64.9	68.7	74.6	74.0	68.1	55.5	44.3	39.4		
		MCWB	33.3	30.9	35.5	39.3	48.3	53.8	58.7	57.7	52.4	43.3	35.3	31.2		
	0.4%	WB	40.4	40.8	43.6	49.5	54.8	62.2	66.6	63.7	59.1	51.8	45.2	38.8		
		MCDB	52.1	51.5	56.4	69.8	72.2	76.7	77.4	75.4	74.0	66.8	59.8	48.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.5	36.8	40.9	46.2	52.8	59.2	63.3	61.6	57.0	49.0	41.9	36.1		
		MCDB	47.4	47.1	52.4	62.5	70.8	71.5	74.5	75.1	73.3	62.0	52.5	45.4		
	5%	WB	35.8	34.0	38.5	43.3	51.0	56.9	61.6	60.0	55.1	46.4	39.0	33.7		
		MCDB	45.1	43.0	48.9	57.0	67.4	69.9	73.7	73.7	70.7	57.8	47.6	42.6		
	10%	WB	33.4	31.2	35.9	40.4	49.0	54.9	59.9	58.4	52.9	43.8	35.8	31.3		
		MCDB	41.9	38.1	45.4	51.3	63.1	66.3	72.1	70.9	66.9	54.7	43.3	38.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.5	16.9	17.7	19.0	20.4	20.1	21.7	21.8	20.3	18.6	16.3	15.5		
		MCDBR	18.9	19.3	22.7	27.0	27.2	24.8	27.0	27.5	27.9	23.9	21.4	19.6		
		MCWBR	11.7	11.8	13.2	13.6	12.5	12.5	12.5	12.0	12.9	12.5	12.3	12.8		
	5% WB	MCDBR	19.1	19.5	22.0	26.5	25.5	23.1	23.2	24.4	26.2	23.3	21.8	19.8		
		MCWBR	12.4	12.5	13.1	13.9	12.1	12.4	12.5	12.2	12.5	12.7	13.0	13.2		
(40) Clear-Sky Solar Irradiance	taub		0.246	0.268	0.276	0.332	0.337	0.340	0.336	0.350	0.307	0.274	0.250	0.234		
	taud		2.449	2.434	2.479	2.327	2.384	2.410	2.431	2.397	2.496	2.571	2.519	2.442		
	Ebn at Noon		260	281	298	289	291	290	290	279	283	277	258	248		
	Edh at Noon		18	24	28	36	36	35	34	34	27	21	16	15		
(44) All-Sky Solar Radiation	RadAvg		358	663	1043	1460	1705	1813	2033	1676	1179	730	387	281		
	RadStd		25	48	74	100	138	142	140	119	129	74	28	19		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page