

REA POINT, NU, Canada

WMO: 719830

Lat: 75.367N

Lon: 105.717W

Elev: 15

StdP: 101.14

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-42.4	-40.6	-46.4	0.0	-41.8	-44.6	0.0	-40.2	19.4	-26.1	17.7	-27.7	3.3	310	1.209

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	8.9	7.4	7.4	6.2	6.1	5.2	7.7	8.7	6.4	7.3	5.3	6.1	5.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.9	6.2	8.2	5.6	5.6	6.9	4.6	5.3	5.7	24.2	8.8	21.4	7.4	19.3	6.2	12.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.5	13.5	12.1	DB	-44.3	12.3	2.6	2.2	-46.2	13.9	-47.7	15.2	-49.1	16.5	-51.0	18.1	(4)
(5)			WB	-44.0	10.0	1.8	1.8	-45.3	11.3	-46.4	12.4	-47.5	13.4	-48.8	14.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-15.6	-30.5	-31.7	-30.9	-21.0	-9.4	0.5	4.0	1.8	-4.4	-14.3	-23.1	-29.0
	DBStd	13.94	5.18	5.13	5.30	5.32	4.82	2.90	2.08	1.91	3.73	5.21	5.05	4.79
	HDD10.0	9336	1256	1167	1268	931	601	284	186	254	433	754	993	1209
	HDD18.3	12377	1514	1401	1527	1181	859	534	443	513	683	1013	1243	1467
	CDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.6	6.3	5.8	5.8	5.6	5.3	5.2	5.3	5.1	6.0	5.6	5.6	6.1
Precipitation	PrecAvg	164	6	5	6	5	8	17	27	32	21	17	11	7
	PrecMax	258	15	20	21	18	29	45	56	60	35	32	25	24
	PrecMin	50	0	1	1	0	2	3	8	5	4	7	3	0
	PrecStd	45	4	4	4	4	5	10	13	12	9	8	7	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-16.0	-14.9	-15.2	-3.6	2.2	10.2	12.7	8.5	4.1	-1.9	-8.0	-11.9
		MCWB	-16.2	-15.2	-15.5	-4.1	0.7	7.7	10.3	7.4	3.4	-2.0	-8.1	-12.0
	2%	DB	-19.1	-19.0	-18.5	-7.6	0.5	6.9	10.0	6.5	2.1	-3.0	-10.7	-16.0
		MCWB	-19.4	-19.3	-18.9	-8.0	-0.1	5.7	8.2	5.6	1.6	-3.2	-10.8	-16.3
	5%	DB	-20.7	-21.4	-21.2	-10.9	-0.8	4.9	8.3	5.4	0.9	-4.4	-13.5	-19.2
		MCWB	-21.0	-21.6	-21.5	-11.3	-1.3	4.0	6.9	4.6	0.6	-4.5	-13.8	-19.4
	10%	DB	-22.8	-23.9	-23.4	-12.9	-2.2	3.6	7.2	4.5	0.1	-6.1	-15.5	-21.8
		MCWB	-23.0	-24.1	-23.6	-13.3	-2.6	2.9	6.0	3.9	-0.2	-6.3	-15.8	-22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-16.1	-15.3	-15.3	-4.0	1.2	8.2	10.6	7.8	3.5	-2.2	-8.1	-12.0
		MCDB	-16.0	-15.1	-15.2	-3.7	1.7	10.0	12.2	8.2	4.1	-2.2	-8.1	-11.9
	2%	WB	-19.4	-19.3	-18.7	-8.0	-0.2	5.7	8.8	5.9	1.7	-3.6	-10.8	-16.2
		MCDB	-19.2	-19.0	-18.5	-7.6	0.3	6.8	10.1	6.4	2.0	-3.4	-10.7	-16.0
	5%	WB	-21.0	-21.6	-21.5	-11.2	-1.3	4.1	7.2	4.8	0.6	-5.1	-13.7	-19.4
		MCDB	-20.7	-21.5	-21.3	-11.0	-0.9	4.9	8.2	5.3	0.8	-5.0	-13.5	-19.2
	10%	WB	-23.1	-24.1	-23.6	-13.3	-2.7	3.1	6.2	4.0	-0.3	-6.6	-15.8	-22.0
		MCDB	-22.9	-23.9	-23.3	-12.9	-2.4	3.6	7.2	4.5	-0.1	-6.5	-15.6	-21.8
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.0	6.3	7.2	5.8	3.6	4.2	3.6	3.7	5.5	6.1	6.0
		MCDBR	8.8	8.4	8.4	7.1	5.7	5.3	6.2	5.3	3.9	5.6	8.6	9.5
		MCWBR	8.7	8.3	8.3	6.9	5.3	4.1	4.9	4.5	3.7	5.6	8.6	9.5
	5% WB	MCDBR	8.8	8.4	8.4	6.9	6.0	5.0	6.2	5.4	3.8	5.6	8.7	9.5
		MCWBR	8.7	8.3	8.3	6.6	5.3	4.0	5.1	4.7	3.6	5.7	8.6	9.5
Clear-Sky Solar Irradiance	taub	N/A	0.155	0.225	0.282	0.308	0.337	0.338	0.314	0.263	0.179	N/A	N/A	
	taud	N/A	1.869	2.127	2.078	2.092	2.160	2.330	2.400	2.313	1.878	N/A	N/A	
	Ebn at Noon	0	273	695	791	829	815	803	769	656	181	0	0	
	Edh at Noon	0	16	57	98	115	114	93	73	50	13	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.07	1.10	3.77	5.73	6.30	5.01	2.88	1.15	0.23	0.00	0.00	
	RadStd	0.00	0.01	0.06	0.16	0.42	0.46	0.48	0.21	0.14	0.03	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page