

NORTH CAPE, PE, Canada

WMO: 719870

Lat: 47.0581N

Lon: 63.9969W

Elev: 25

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.8	3.2	-8.0	3.6	0.3	-3.4	4.6	4.2	43.3	18.7	40.2	18.1	19.9	290	0.796

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	78.8	69.8	75.8	68.6	73.3	67.3	71.8	76.6	70.0	74.0	68.4	72.1	12.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	110.9	74.4	68.5	104.7	72.7	67.0	99.3	71.0	35.6	77.1	34.1	74.0	32.8	72.3	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.2	35.6	31.2	-5.3	86.5	4.9	2.2	-8.8	88.1	-11.7	89.4	-14.5	90.6	-18.1	92.3		
(5)			-5.7	74.8	4.9	2.1	-9.2	76.4	-12.1	77.6	-14.9	78.8	-18.4	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	20.5	19.6	26.5	36.0	46.8	57.4	66.7	66.5	59.6	49.5	38.9	29.2
	DBStd	17.70	9.30	8.72	7.22	5.90	6.74	6.57	4.76	4.50	5.31	5.70	6.74	6.89
	HDD50	4136	916	851	728	422	148	11	0	0	2	78	336	644
	HDD65	8137	1381	1271	1193	869	564	241	36	34	177	480	782	1109
	CDD50	1673	0	0	0	2	49	233	519	513	289	63	5	0
	CDD65	199	0	0	0	0	0	13	90	82	14	0	0	0
	CDH74	471	0	0	0	0	3	40	232	177	19	0	0	0
	CDH80	55	0	0	0	0	0	4	29	20	2	0	0	0
Wind	WSAvg	15.3	18.3	15.7	15.2	13.9	12.8	12.2	11.7	12.5	14.9	17.4	18.9	20.2
Precipitation	PrecAvg	50.5	4.6	3.9	4.1	3.7	3.8	3.8	3.3	3.6	4.4	5.0	5.1	5.3
	PrecMax	62.7	7.2	7.1	8.0	7.0	8.0	6.9	6.4	7.0	9.8	9.3	9.1	10.1
	PrecMin	39.4	1.8	1.2	1.5	1.6	1.7	1.5	1.7	1.3	1.3	1.4	2.7	2.5
	PrecStd	5.4	1.2	1.3	1.5	1.1	1.4	1.4	1.2	1.5	2.1	2.0	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.6	44.0	46.5	61.6	71.6	78.6	83.3	82.6	76.3	68.3	59.8	50.0
		MCWB	46.1	42.8	43.4	55.1	59.4	67.7	71.8	72.2	69.7	61.0	56.9	49.0
	2%	DB	39.4	37.6	41.4	52.5	64.8	73.8	79.6	78.3	72.0	62.3	54.5	44.1
		MCWB	38.8	36.3	39.0	47.9	57.0	65.5	70.2	70.0	66.5	58.2	52.7	43.2
	5%	DB	34.7	34.0	37.7	46.8	60.2	69.9	76.4	75.5	69.5	59.4	50.9	40.5
		MCWB	33.8	33.3	35.9	43.3	54.5	63.7	69.0	68.6	65.1	56.3	49.2	39.6
	10%	DB	32.0	31.4	35.2	43.0	56.2	66.7	73.6	72.9	67.1	57.2	47.5	37.9
		MCWB	31.2	30.6	33.8	40.2	52.1	61.8	67.7	67.4	63.3	54.5	45.5	36.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	43.4	43.9	55.6	62.4	71.3	74.1	74.3	71.1	63.4	57.8	48.9
		MCDB	46.5	44.2	45.5	59.9	67.6	75.3	80.2	79.1	74.6	66.2	59.3	49.8
	2%	WB	39.0	36.7	39.4	48.5	58.6	67.4	72.0	71.7	68.2	58.9	52.9	43.4
		MCDB	39.4	37.4	40.9	51.6	63.0	71.6	77.1	76.5	71.2	61.0	54.3	44.0
	5%	WB	33.9	33.4	36.2	43.8	55.5	64.8	70.3	69.8	65.8	56.8	49.5	39.7
		MCDB	34.6	33.9	37.4	46.2	59.2	68.8	74.6	73.9	68.4	58.8	50.8	40.3
	10%	WB	31.3	30.7	33.9	40.3	52.3	62.2	68.7	68.3	63.9	54.8	46.0	36.9
		MCDB	31.9	31.3	35.1	42.7	56.1	65.9	72.6	71.9	66.5	56.8	47.2	37.6
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.2	9.7	9.1	10.5	10.8	10.9	9.9	9.4	7.6	7.7	7.9
		MCDBR	17.0	15.3	13.7	16.8	19.2	17.7	15.5	14.1	13.3	11.6	12.9	12.5
		MCWBR	17.4	15.0	12.4	13.2	12.1	11.0	8.9	8.4	9.3	10.0	12.8	13.1
	5% WB	MCDBR	17.0	15.0	13.1	16.5	17.7	15.4	13.5	12.1	11.9	10.9	12.9	12.4
		MCWBR	17.5	14.9	12.4	14.1	12.4	11.0	8.7	8.2	9.3	10.3	13.2	13.1
Clear-Sky Solar Irradiance	taub	0.294	0.287	0.319	0.349	0.367	0.382	0.411	0.391	0.359	0.338	0.312	0.294	
	taud	2.378	2.290	2.300	2.419	2.440	2.403	2.368	2.414	2.494	2.521	2.518	2.478	
	Ebn at Noon	252	280	286	287	285	280	270	271	271	260	246	240	
	Edh at Noon	23	30	35	34	35	36	37	34	29	24	20	18	
All-Sky Solar Radiation	RadAvg	368	637	1052	1370	1649	1779	1789	1570	1213	751	391	274	
	RadStd	33	75	82	121	154	135	131	103	105	69	48	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page