

MOULD BAY, NT, Canada

WMO: 719890

Lat: 76.237N

Lon: 119.347W

Elev: 2

StdP: 101.31

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-44.9	-43.0	-49.6	0.0	-44.5	-47.4	0.0	-42.6	14.9	-25.4	13.3	-25.6	1.7	50	1.167

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	11.4	8.4	9.3	7.0	7.5	5.8	8.5	11.2	7.2	9.1	5.9	7.4	5.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
6.5	6.0	9.5	5.4	5.5	8.2	4.3	5.2	6.9	26.0	11.4	23.1	9.2	20.4	7.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.5	10.2	DB	-46.5	13.0	3.0	2.6	-48.6	14.9	-50.4	16.5	-52.1	18.0	-54.3	19.9	(4)
(5)			WB	-46.4	9.9	2.8	1.7	-48.4	11.1	-50.0	12.0	-51.6	13.0	-53.7	14.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-16.0	-31.5	-32.5	-30.7	-22.3	-9.4	0.7	4.3	1.8	-5.0	-15.5	-23.5	-29.2	
	DBStd	14.39	6.10	5.93	6.40	5.38	5.23	3.15	2.89	2.98	4.18	5.82	5.73	6.04	
	HDD10.0	9482	1287	1190	1262	970	602	281	178	256	449	791	1004	1214	
	HDD18.3	12521	1545	1423	1520	1220	861	530	434	514	699	1049	1254	1472	
	CDD10.0	2	0	0	0	0	0	0	2	0	0	0	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	4.3	4.1	3.7	3.9	3.8	4.2	4.8	5.1	4.9	4.9	4.2	3.9	3.9	
Precipitation	PrecAvg	114	3	4	3	5	9	9	16	26	17	12	6	5	
	PrecMax	160	13	20	13	20	35	30	35	66	57	34	19	17	
	PrecMin	47	0	0	0	0	1	0	0	0	3	0	0	0	
	PrecStd	27	4	4	2	5	7	8	9	16	11	7	5	4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-13.6	-14.4	-12.2	-4.8	2.1	10.7	15.0	12.2	4.1	-1.6	-6.1	-9.8	
		MCWB	-13.9	-14.9	-12.6	-5.5	0.2	7.8	9.5	8.7	3.2	-1.9	-6.5	-10.1	
	2%	DB	-17.4	-18.4	-15.4	-9.3	0.4	8.4	12.8	9.2	2.3	-3.0	-9.9	-14.4	
		MCWB	-17.7	-18.6	-15.7	-9.8	-0.7	6.1	9.0	7.3	1.7	-3.4	-10.2	-14.7	
	5%	DB	-19.7	-21.0	-18.7	-12.0	-0.9	6.1	10.8	7.3	1.2	-4.6	-13.2	-17.4	
		MCWB	-19.9	-21.3	-18.9	-12.4	-1.8	4.3	8.1	5.8	0.8	-5.0	-13.5	-17.7	
	10%	DB	-22.4	-23.4	-21.1	-14.3	-2.2	4.6	9.0	5.8	0.3	-6.8	-15.2	-19.9	
		MCWB	-22.6	-23.6	-21.3	-14.7	-2.9	3.2	6.7	4.6	-0.2	-7.2	-15.4	-20.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-13.7	-14.6	-12.5	-5.5	0.6	8.2	10.5	9.2	3.4	-1.8	-6.4	-10.0
			MCDB	-13.5	-14.4	-12.4	-4.8	1.9	10.5	13.8	11.6	3.9	-1.8	-6.1	-9.8
2%		WB	-17.6	-18.6	-15.7	-9.8	-0.6	6.0	9.2	7.3	1.8	-3.3	-10.3	-14.7	
		MCDB	-17.4	-18.4	-15.4	-9.3	0.3	8.1	12.2	9.0	2.2	-3.0	-9.9	-14.5	
5%		WB	-19.9	-21.3	-18.9	-12.4	-1.7	4.5	8.1	5.9	0.9	-5.0	-13.4	-17.7	
		MCDB	-19.6	-21.0	-18.7	-12.1	-1.0	6.0	10.8	7.2	1.2	-4.6	-13.2	-17.5	
10%		WB	-22.6	-23.6	-21.3	-14.7	-3.0	3.3	6.9	4.7	-0.1	-7.1	-15.4	-20.1	
		MCDB	-22.4	-23.4	-21.1	-14.3	-2.3	4.5	8.8	5.7	0.2	-6.8	-15.2	-19.9	
Mean Daily Temperature Range		5% DB	MDBR	7.2	7.6	7.2	8.1	6.0	3.9	4.7	3.8	3.9	6.3	6.9	6.9
			MCDBR	10.1	10.5	8.6	8.1	6.2	5.8	7.4	6.1	3.4	6.3	8.3	9.3
	MCWBR		10.0	10.4	8.5	7.8	5.6	4.2	5.0	4.6	3.0	6.3	8.3	9.2	
	5% WB	MCDBR	10.1	10.5	8.5	8.0	5.8	5.6	6.9	5.8	3.3	6.3	8.3	9.4	
		MCWBR	10.0	10.4	8.4	7.7	5.2	4.2	5.0	4.5	3.0	6.3	8.3	9.3	
Clear-Sky Solar Irradiance	taub	N/A	0.162	0.230	0.305	0.328	0.341	0.335	0.317	0.287	0.173	N/A	N/A		
	taud	N/A	1.881	2.102	2.005	2.041	2.209	2.373	2.403	2.153	1.892	N/A	N/A		
	Ebn at Noon	0	187	656	742	794	807	802	757	568	129	0	0		
	Edh at Noon	0	11	55	104	120	107	88	72	55	9	0	0		
All-Sky Solar Radiation	RadAvg	0.00	0.06	1.03	3.65	5.48	6.38	4.84	2.78	1.18	0.18	0.00	0.00		
	RadStd	0.00	0.00	0.06	0.26	0.43	0.44	0.45	0.25	0.11	0.02	0.00	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page