

LILLOOET, BC, Canada

WMO: 719990

Lat: 50.6836N

Lon: 121.9342W

Elev: 798

StdP: 14.28

Time Zone: -8.00 (NAP)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	8.6	-6.9	3.9	6.5	-3.4	4.7	9.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.5	95.3	63.3	91.5	62.4	87.9	61.4	65.2	88.0	64.0	86.1	62.8	84.0	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.3	77.6	66.5	57.5	72.6	65.8	55.9	68.5	65.8	30.4	87.0	29.5	86.6	28.7	84.3	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-1.0	100.9	7.5	3.5	-6.4	103.4	-10.8	105.4	-15.0	107.4	-20.4	109.9
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	29.4	33.5	41.8	50.3	59.8	66.5	73.2	72.1	62.1	49.3	37.4	29.4	
	DBStd	17.16	10.42	7.91	7.01	5.65	6.31	5.99	6.25	5.69	6.17	5.86	8.71	9.27	
	HDD50	2532	639	463	260	64	4	0	0	0	1	82	380	639	
	HDD65	5947	1104	883	719	442	186	49	10	11	126	486	827	1104	
	CDD50	2716	0	0	6	72	308	497	720	684	365	61	3	0	
	CDD65	655	0	0	0	0	25	96	264	230	40	0	0	0	
	CDH74	7619	0	0	0	26	417	1118	3121	2491	443	3	0	0	
	CDH80	3324	0	0	0	3	120	443	1511	1116	131	0	0	0	
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Precipitation	PrecAvg	16.6	1.9	1.0	1.1	0.8	1.2	1.5	1.1	1.1	1.1	1.5	2.3	2.1	
	PrecMax	20.8	3.2	2.2	2.4	1.6	2.7	2.6	2.7	4.3	2.1	3.4	5.6	4.0	
	PrecMin	13.2	0.6	0.2	0.3	0.3	0.2	0.7	0.1	0.2	0.3	0.6	0.6	0.8	
	PrecStd	2.0	0.6	0.5	0.6	0.3	0.7	0.5	0.7	0.9	0.5	0.6	1.2	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	53.9	64.8	77.8	88.9	95.7	101.7	98.3	89.7	71.5	58.7	50.8	
		MCWB	43.9	42.9	48.4	54.8	59.3	63.1	64.6	64.2	63.1	58.1	49.6	41.9	
	2%	DB	46.8	49.4	59.0	70.6	83.2	90.0	96.7	94.1	83.6	65.6	53.7	45.8	
		MCWB	42.0	41.6	46.3	51.9	57.5	61.6	63.4	63.4	61.0	53.9	48.0	40.0	
	5%	DB	43.3	46.5	55.8	66.3	78.6	85.0	92.6	90.3	79.1	62.1	50.7	43.0	
		MCWB	39.2	40.4	44.8	49.5	56.7	59.9	62.5	62.8	59.2	50.6	45.8	39.6	
	10%	DB	40.4	43.8	53.0	62.3	74.0	80.3	88.6	86.5	74.6	59.1	48.1	40.4	
		MCWB	37.9	39.2	43.6	47.4	55.2	58.1	61.4	61.7	58.2	49.6	43.8	37.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	46.4	51.6	55.8	61.3	65.4	66.6	66.4	64.5	58.7	53.3	43.9
			MCDB	51.1	50.5	64.4	70.8	80.4	85.9	93.6	88.4	81.2	69.8	56.6	50.6
2%		WB	41.1	43.8	48.5	53.1	59.6	63.4	65.1	65.3	62.7	55.7	48.9	41.8	
		MCDB	44.3	47.6	59.2	68.3	80.2	86.8	91.7	86.6	79.1	62.6	52.6	45.5	
5%		WB	38.7	41.8	46.7	50.7	58.2	61.7	63.7	64.2	61.0	52.7	46.9	40.2	
		MCDB	40.6	45.9	56.2	64.0	77.8	83.8	88.6	84.8	75.1	59.5	51.2	43.4	
10%		WB	37.0	40.0	44.8	48.6	56.9	60.2	62.4	62.9	59.2	50.2	45.0	38.4	
		MCDB	38.8	44.2	52.7	60.2	74.3	79.3	84.8	83.0	72.0	57.1	49.2	41.1	
Mean Daily Temperature Range	5% DB	MDBR	10.0	14.2	17.9	21.2	22.4	21.9	24.5	24.8	21.9	16.6	10.9	9.1	
		MCDBR	12.9	16.5	22.3	29.1	31.9	32.0	33.3	32.9	30.2	21.1	12.7	11.4	
		MCWBR	8.5	10.1	12.0	12.9	11.3	9.4	9.5	9.5	10.9	10.3	7.3	7.4	
	5% WB	MCDBR	10.3	15.0	23.6	25.5	29.0	28.5	30.3	29.1	25.3	18.2	10.9	10.6	
		MCWBR	7.4	10.0	12.1	11.5	10.5	8.8	8.8	8.5	9.3	9.8	6.8	7.4	
Clear-Sky Solar Irradiance	taub	0.294	0.302	0.333	0.383	0.390	0.384	0.370	0.370	0.346	0.349	0.309	0.292		
	taud	2.267	2.303	2.258	2.137	2.251	2.362	2.427	2.440	2.495	2.408	2.380	2.260		
	Ebn at Noon	230	263	274	271	274	277	279	274	269	243	225	210		
	Edh at Noon	22	27	35	44	41	37	34	32	28	25	20	19		
All-Sky Solar Radiation	RadAvg	298	593	940	1392	1721	1791	1960	1688	1175	677	326	233		
	RadStd	34	60	89	136	148	173	169	105	99	82	44	29		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page