

LILLOOET, BC, Canada

WMO: 719990

Lat: 50.6836N

Lon: 121.9342W

Elev: 243

StdP: 98.44

Time Zone: -8.00 (NAP)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.0	-13.0	-21.6	0.6	-14.2	-19.7	0.7	-12.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	35.2	17.4	33.1	16.9	31.0	16.4	18.4	31.1	17.8	30.0	17.1	28.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.2	11.1	19.2	14.1	10.4	18.8	13.3	9.8	18.8	52.9	30.5	50.8	30.4	48.8	29.0	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-18.4	38.3	4.2	1.9	-21.3	39.7	-23.8	40.8	-26.1	41.9	-29.1	43.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-1.5	0.8	5.5	10.2	15.4	19.2	22.9	22.3	16.7	9.6	3.0	-1.4	(6)
(7)		DBStd	9.53	5.79	4.40	3.90	3.14	3.51	3.33	3.47	3.16	3.43	3.26	4.84	5.15	(7)
(8)		HDD10.0	1407	355	257	144	36	2	0	0	0	1	46	211	355	(8)
(9)		HDD18.3	3304	613	491	399	246	103	27	6	6	70	270	459	613	(9)
(10)		CDD10.0	1509	0	0	3	40	171	276	400	380	203	34	2	0	(10)
(11)		CDD18.3	364	0	0	0	0	14	53	147	128	22	0	0	0	(11)
(12)		CDH23.3	4233	0	0	0	14	232	621	1734	1384	246	2	0	0	(12)
(13)		CDH26.7	1847	0	0	0	2	67	246	839	620	73	0	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	421	48	25	28	21	30	37	27	28	27	39	58	54	(15)
(16)		PrecMax	529	81	56	62	41	69	65	69	108	53	86	142	101	(16)
(17)		PrecMin	336	16	6	7	8	4	18	2	4	8	14	16	20	(17)
(18)		PrecStd	52	16	13	14	8	17	13	18	22	13	16	31	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	12.2	18.2	25.4	31.6	35.4	38.7	36.8	32.1	21.9	14.8	10.5	(19)
(20)			MCWB	6.6	6.1	9.1	12.6	15.1	17.3	18.1	17.9	17.3	14.5	9.8	5.5	(20)
(21)		2%	DB	8.2	9.6	15.0	21.5	28.5	32.2	35.9	34.5	28.7	18.7	12.1	7.7	(21)
(22)			MCWB	5.5	5.4	8.0	11.0	14.2	16.4	17.4	17.4	16.1	12.2	8.9	4.4	(22)
(23)		5%	DB	6.3	8.0	13.2	19.1	25.9	29.5	33.7	32.4	26.2	16.7	10.4	6.1	(23)
(24)			MCWB	4.0	4.7	7.1	9.7	13.7	15.5	16.9	17.1	15.1	10.4	7.7	4.2	(24)
(25)		10%	DB	4.7	6.6	11.7	16.8	23.3	26.9	31.5	30.3	23.7	15.1	9.0	4.7	(25)
(26)			MCWB	3.3	4.0	6.5	8.5	12.9	14.5	16.3	16.5	14.6	9.8	6.5	3.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.0	10.9	13.2	16.3	18.5	19.2	19.1	18.1	14.8	11.8	6.6	(27)
(28)			MCD B	10.6	10.3	18.0	21.5	26.9	29.9	34.2	31.3	27.3	21.0	13.7	10.3	(28)
(29)		2%	WB	5.0	6.6	9.2	11.7	15.3	17.5	18.4	18.5	17.1	13.2	9.4	5.4	(29)
(30)			MCD B	6.9	8.7	15.1	20.2	26.8	30.4	33.2	30.4	26.2	17.0	11.5	7.5	(30)
(31)		5%	WB	3.7	5.5	8.2	10.4	14.6	16.5	17.6	17.9	16.1	11.5	8.3	4.6	(31)
(32)			MCD B	4.8	7.7	13.5	17.8	25.5	28.8	31.5	29.4	24.0	15.3	10.7	6.3	(32)
(33)		10%	WB	2.8	4.4	7.1	9.2	13.8	15.6	16.9	17.2	15.1	10.1	7.2	3.6	(33)
(34)			MCD B	3.8	6.8	11.5	15.6	23.5	26.3	29.4	28.4	22.2	14.0	9.5	5.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.6	7.9	10.0	11.8	12.4	12.2	13.6	13.8	12.1	9.2	6.1	5.1	(35)
(36)			MCD BR	7.2	9.2	12.4	16.2	17.7	17.8	18.5	18.3	16.8	11.7	7.0	6.3	(36)
(37)			MCWBR	4.7	5.6	6.7	7.1	6.3	5.2	5.3	5.3	6.0	5.7	4.1	4.1	(37)
(38)		5% WB	MCD BR	5.7	8.3	13.1	14.2	16.1	15.9	16.8	16.1	14.1	10.1	6.1	5.9	(38)
(39)			MCWBR	4.1	5.6	6.7	6.4	5.9	4.9	4.9	4.7	5.2	5.4	3.8	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.302	0.333	0.383	0.390	0.384	0.370	0.370	0.346	0.349	0.309	0.292	(40)	
(41)		taud	2.267	2.303	2.258	2.137	2.251	2.362	2.427	2.440	2.495	2.408	2.380	2.260	(41)	
(42)		Ebn at Noon	724	829	864	853	865	873	880	863	849	765	708	661	(42)	
(43)		Edh at Noon	69	86	109	138	130	117	108	102	87	79	62	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.94	1.87	2.96	4.39	5.43	5.65	6.18	5.32	3.71	2.13	1.03	0.73	(44)	
(45)		RadStd	0.11	0.19	0.28	0.43	0.47	0.55	0.53	0.33	0.31	0.26	0.14	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page