

LACON, IL, USA

WMO: 720141

Lat: 41.019N

Lon: 89.386W

Elev: 568

StdP: 14.40

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 04868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.7	(c) 2.5	(d) -10.2	(e) 3.2	(f) -1.1	(g) -6.1	(h) 4.1	(i) 3.7	(j) 23.2	(k) 30.3	(l) 20.4	(m) 28.7	(n) 4.4	(o) 310	(p) 0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.3	(c) 91.4	(d) 75.2	(e) 89.9	(f) 74.8	(g) 87.3	(h) 73.6	(i) 79.0	(j) 87.8	(k) 77.3	(l) 85.5	(m) 75.6	(n) 83.5	(o) 7.4	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	142.1	84.4	74.8	133.1	82.1	73.0	125.1	80.6	42.9	87.5	41.0	85.4	39.4	83.0	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.0	17.8	16.0		-10.8	95.7	8.0	3.7	-16.6	98.3	-21.3	100.5	-25.8	102.5	-31.7	105.2	
			DB	-11.5	82.3	7.8	1.6	-17.0	83.5	-21.6	84.4	-25.9	85.3	-31.6	86.4	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	24.8	27.2	40.4	51.7	62.8	71.6	74.6	73.1	67.7	54.2	41.8	30.2		
	DBStd	20.06	12.59	12.22	11.30	9.46	8.68	6.00	6.00	5.44	7.39	9.71	10.07	10.94		
	HDD50	2826	783	641	341	91	7	0	0	0	1	65	281	616		
	HDD65	5831	1247	1058	765	409	149	11	3	5	54	358	695	1077		
	CDD50	3486	1	3	44	141	402	649	763	716	531	196	36	4		
	CDD65	1017	0	0	3	9	79	211	301	256	135	23	0	0		
	CDH74	9414	0	0	22	131	740	1897	2919	2258	1243	202	1	1		
	CDH80	3156	0	0	1	14	196	616	1107	765	414	43	0	0		
(14) Wind	WSAvg	6.4	7.6	7.6	7.9	8.4	6.6	5.5	4.2	4.0	4.6	6.1	7.2	7.0		
(15) Precipitation	PrecAvg	35.8	2.0	1.8	2.6	3.4	4.3	3.9	3.9	3.8	2.8	3.0	2.8	1.9		
	PrecMax	49.2	4.4	5.8	5.5	5.0	9.3	10.2	10.6	7.5	5.4	7.8	5.7	3.1		
	PrecMin	21.8	0.3	0.5	1.0	1.7	0.5	1.1	0.4	1.1	0.6	0.8	0.1	0.9		
	PrecStd	5.9	1.1	1.3	1.4	1.2	2.5	2.2	2.3	1.9	1.4	1.8	1.5	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	63.8	77.1	81.8	90.2	93.3	99.0	94.9	92.6	85.6	72.1	64.1		
		MCWB	53.3	54.1	62.8	61.4	73.2	76.0	76.9	74.5	74.4	69.7	58.2	58.0		
	2%	DB	51.7	55.6	69.8	78.2	85.0	90.0	92.0	90.3	89.4	79.4	65.9	55.4		
		MCWB	47.5	50.2	58.7	61.8	69.6	74.3	76.7	75.1	72.6	64.7	57.6	50.4		
	5%	DB	45.7	49.7	63.5	73.2	81.5	87.3	89.7	87.8	84.6	75.0	61.5	50.6		
		MCWB	42.4	44.5	55.8	58.7	66.5	72.5	76.2	74.3	71.0	63.9	54.2	47.0		
	10%	DB	40.6	43.2	58.5	69.8	78.5	83.1	86.2	84.0	81.3	70.3	57.2	45.8		
		MCWB	37.4	39.0	51.3	57.3	65.2	70.9	74.5	72.1	67.5	61.6	50.8	42.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	57.7	65.0	67.2	75.1	79.6	81.8	80.8	77.4	72.6	62.4	59.4		
		MCDB	58.4	61.3	75.0	76.3	86.4	89.0	91.6	89.3	88.2	82.0	68.2	63.0		
	2%	WB	48.3	50.0	60.4	63.9	72.3	77.0	79.7	78.1	75.3	69.3	58.6	52.3		
		MCDB	50.7	55.3	67.2	74.0	81.3	84.8	88.1	86.8	84.9	75.1	63.8	54.4		
	5%	WB	42.4	44.3	57.1	61.3	69.8	75.1	77.8	76.1	73.0	66.5	55.2	46.8		
		MCDB	45.8	48.8	62.3	70.4	77.5	83.1	85.8	83.6	81.3	71.8	60.6	49.6		
	10%	WB	37.7	39.2	51.5	58.4	67.5	73.2	76.1	74.3	71.0	63.0	51.8	42.6		
		MCDB	40.3	43.2	57.8	67.9	75.8	81.1	84.0	81.1	78.1	69.4	57.3	45.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	16.0	18.2	21.2	20.7	19.7	19.3	19.7	22.0	20.2	17.0	14.3		
		MCDBR	19.4	23.4	23.5	26.8	24.1	22.4	21.3	22.6	23.8	25.3	22.6	19.7		
	5% WB	MCWBR	15.9	17.6	15.6	14.9	12.2	10.7	9.9	10.2	10.6	13.6	15.2	16.4		
		MCWBR	18.8	21.8	21.5	23.2	21.2	18.7	19.0	18.2	20.1	19.5	19.8	18.7		
(40) Clear-Sky Solar Irradiance	taub		0.292	0.309	0.342	0.393	0.427	0.437	0.453	0.437	0.404	0.350	0.308	0.291		
	taud		2.438	2.388	2.396	2.258	2.221	2.238	2.177	2.218	2.281	2.436	2.502	2.455		
	Ebn at Noon		276	286	288	279	271	267	261	262	263	268	268	266		
	Edh at Noon		25	30	34	42	44	44	46	43	38	29	23	23		
(44) All-Sky Solar Radiation	RadAvg		561	855	1168	1496	1730	1963	1958	1724	1460	975	644	471		
	RadStd		62	93	91	125	128	148	111	107	120	114	54	60		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46) N/A
(47)	Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47) N/A

Nomenclature: See separate page