

BIG BEAR, CA, USA

WMO: 720165

Lat: 34.264N

Lon: 116.854W

Elev: 6748

StdP: 11.45

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.5	12.5	-14.6	3.2	40.0	-8.3	4.5	38.7	21.7	33.1	19.9	33.3	0.5	260	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.3	81.5	53.2	80.6	53.0	78.8	52.6	58.9	71.9	57.5	72.1	56.3	72.0	8.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.3	81.0	63.3	52.1	74.5	63.1	49.9	68.5	63.5	28.7	72.3	27.8	71.1	26.8	71.7	63.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	16.1	13.9	DB	1.6	85.3	2.9	1.9	-0.5	86.7	-2.2	87.8	-3.8	88.9	-5.9	90.3	(4)
(5)			WB	0.8	62.0	2.8	1.1	-1.2	62.8	-2.9	63.4	-4.5	64.0	-6.5	64.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.9	33.2	32.7	38.3	42.8	47.5	57.0	62.4	61.3	55.4	47.1	39.4	32.7
	DBStd	12.02	6.47	7.32	6.03	5.91	6.18	5.23	3.78	3.23	4.90	4.79	6.19	6.76
	HDD50	2697	521	484	363	220	120	9	0	0	14	110	320	536
	HDD65	6995	986	904	828	665	543	242	94	118	289	556	769	1001
	CDD50	1198	0	0	0	5	43	219	385	351	175	19	1	0
	CDD65	19	0	0	0	0	0	2	13	4	0	0	0	0
	CDH74	1835	0	0	0	0	15	418	768	545	87	2	0	0
	CDH80	155	0	0	0	0	0	45	84	25	1	0	0	0
Wind	WSAvg	4.9	4.6	5.4	5.8	6.3	5.7	5.2	4.0	3.9	3.9	4.3	4.3	4.9
Precipitation	PrecAvg	16.3	4.1	3.9	2.0	1.0	0.3	0.1	0.3	0.4	0.3	0.8	0.9	2.5
	PrecMax	33.1	17.6	10.8	7.9	2.9	2.3	1.1	1.3	2.2	2.1	5.9	2.4	11.3
	PrecMin	6.2	0.3	0.4	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.4
	PrecStd	7.6	5.1	2.5	2.0	0.7	0.5	0.3	0.4	0.6	0.5	1.3	0.7	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.0	61.0	64.1	70.2	75.5	84.2	85.6	82.0	79.2	72.4	68.3	61.3
		MCWB	39.5	40.0	42.9	45.8	48.0	52.4	53.0	53.6	51.6	46.4	44.5	39.4
	2%	DB	54.4	57.2	61.1	66.1	72.4	81.2	81.8	81.0	76.8	69.8	63.4	56.2
		MCWB	37.6	39.1	41.1	44.4	47.1	51.2	54.0	53.3	51.4	46.0	42.3	38.7
	5%	DB	51.8	54.0	57.4	63.3	69.8	79.0	80.9	79.1	73.4	67.8	60.6	52.1
		MCWB	36.5	37.3	39.4	42.5	46.1	50.6	53.9	53.3	50.8	45.5	41.1	36.6
	10%	DB	46.4	48.5	54.4	60.6	65.9	76.7	78.9	77.2	72.4	64.0	55.2	46.2
		MCWB	34.2	35.4	38.5	41.0	44.5	49.7	53.6	53.0	50.5	43.6	39.4	34.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.4	42.6	44.5	48.6	50.1	56.3	60.8	60.2	58.6	52.4	46.3	44.0
		MCDB	51.4	52.0	60.0	62.4	70.8	75.5	72.7	71.8	68.1	62.7	62.3	52.1
	2%	WB	39.8	40.1	42.6	45.8	48.4	54.0	59.2	58.7	56.6	49.1	43.9	41.0
		MCDB	49.7	54.2	57.5	63.5	69.2	76.0	72.2	72.0	69.0	61.0	59.7	50.8
	5%	WB	38.2	38.3	41.2	43.7	46.8	52.3	58.0	57.2	54.7	47.0	42.2	38.6
		MCDB	46.9	50.9	55.4	61.4	67.1	75.2	72.4	72.3	68.8	62.5	57.3	48.6
	10%	WB	36.2	36.3	39.3	41.8	45.4	50.7	56.9	55.7	52.5	45.4	40.3	36.6
		MCDB	45.0	47.3	52.6	57.9	64.0	73.5	72.3	72.5	67.7	61.8	54.6	45.9
Mean Daily Temperature Range	5% DB	MDBR	23.8	24.2	24.5	26.4	27.8	33.0	30.3	31.2	31.1	30.0	27.8	23.0
		MCDBR	30.9	32.6	32.2	33.6	35.7	37.0	33.2	33.6	33.4	36.6	34.8	32.5
		MCWBR	17.1	17.7	17.0	17.2	17.8	17.9	15.3	15.6	15.6	19.1	19.1	18.1
	5% WB	MCDBR	24.9	28.6	28.8	31.4	33.0	34.6	26.3	27.5	28.1	30.5	31.0	26.7
		MCWBR	15.0	16.7	16.3	16.9	17.0	17.0	12.8	13.4	14.1	16.7	18.0	16.0
Clear-Sky Solar Irradiance	taub	0.233	0.239	0.248	0.260	0.269	0.271	0.296	0.289	0.273	0.262	0.238	0.237	
	taud	2.648	2.654	2.610	2.574	2.578	2.588	2.559	2.569	2.604	2.603	2.672	2.655	
	Ebn at Noon	320	328	329	326	322	319	311	312	316	314	316	313	
	Edh at Noon	23	25	29	31	32	31	32	31	29	26	22	21	
All-Sky Solar Radiation	RadAvg	1045	1347	1815	2227	2487	2662	2442	2293	1994	1548	1164	946	
	RadStd	73	119	80	75	99	106	116	86	66	76	49	59	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)	+1.12	N/A	-2.97	+1.19	N/A	N/A	N/A	-180	+387	+205

Nomenclature: See separate page