

BIG SPRING, TX, USA

WMO: 720271

Lat: 32.213N

Lon: 101.521W

Elev: 784

StdP: 92.25

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03044

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.2	(c) -4.1	(d) -17.0	(e) 0.9	(f) 2.6	(g) -14.3	(h) 1.2	(i) 4.5	(j) 14.1	(k) 11.8	(l) 12.2	(m) 11.5	(n) 3.2	(o) 20	(p) 0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.2	(c) 38.1	(d) 19.5	(e) 37.5	(f) 19.5	(g) 36.4	(h) 20.1	(i) 23.0	(j) 30.9	(k) 22.5	(l) 30.3	(m) 21.9	(n) 29.7	(o) 5.0	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	17.6	24.9	20.8	17.1	24.6	20.1	16.3	24.6	72.2	30.7	70.1	30.1	68.2	29.7	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.9	(b) 10.8	(c) 9.3	(e) -9.3	(f) 41.4	(g) 2.6	(h) 3.2	(i) -11.2	(j) 43.7	(k) -12.8	(l) 45.6	(m) -14.2	(n) 47.4	(o) -16.2	(p) 49.7		
(4) 11.9	(5) 10.8	(6) 9.3	(7) -9.3	(8) 41.4	(9) 2.6	(10) 3.2	(11) -11.2	(12) 43.7	(13) -12.8	(14) 45.6	(15) -14.2	(16) 47.4	(17) -16.2	(18) 49.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	7.4	9.8	14.6	19.0	23.1	27.9	28.5	28.0	24.1	18.8	12.7	7.9
	DBStd	8.80	4.99	5.80	5.28	4.86	4.59	2.98	2.56	2.67	3.43	4.89	4.99	5.05
	HDD10.0	336	110	68	19	3	0	0	0	0	0	4	31	101
	HDD18.3	1334	338	240	136	50	13	0	0	0	2	53	177	324
	CDD10.0	3451	30	63	164	273	406	538	573	558	424	277	110	36
	CDD18.3	1407	0	2	22	69	160	288	314	299	177	68	7	1
	CDH23.3	16671	22	84	328	873	1895	3520	3873	3512	1765	666	111	23
	CDH26.7	8402	1	16	93	358	958	1944	2127	1882	776	227	18	1
(14) Wind	WSAvg	4.5	4.2	4.6	5.2	5.6	5.3	5.3	4.3	3.9	3.9	4.1	4.1	4.1
(15) Precipitation	PrecAvg	500	18	24	32	37	61	66	50	62	57	43	29	18
	PrecMax	878	50	73	97	114	181	132	145	134	151	109	178	99
	PrecMin	262	0	0	4	2	7	6	4	4	3	0	0	0
	PrecStd	151	15	22	27	31	45	40	40	37	41	33	40	23
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	28.8	32.4	36.2	38.9	41.1	39.0	40.0	37.5	34.2	28.7	26.3
		MCWB	12.1	12.2	14.0	15.5	17.0	19.0	20.0	19.7	19.3	18.4	14.8	11.8
	2%	DB	22.8	26.1	29.2	33.7	37.2	38.3	37.8	37.8	35.1	31.8	26.4	22.9
		MCWB	10.5	11.9	13.7	15.3	17.2	19.7	20.2	20.1	19.5	18.4	13.9	11.6
	5%	DB	19.2	23.2	27.1	30.9	34.7	37.3	37.1	36.7	33.4	29.1	24.0	18.9
		MCWB	9.2	11.4	13.2	14.6	17.3	19.7	20.5	20.4	19.7	17.2	13.8	10.1
	10%	DB	16.3	20.1	24.9	28.0	32.3	35.7	35.7	34.9	31.2	27.2	21.8	16.3
		MCWB	8.1	10.1	13.2	14.5	17.5	20.2	20.7	20.3	19.2	16.9	12.5	8.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.9	18.8	20.0	22.0	23.6	23.6	23.5	23.5	21.9	18.0	15.8
		MCDB	18.9	21.2	24.4	26.2	29.0	31.9	31.7	31.1	29.7	27.1	23.3	19.3
	2%	WB	12.2	14.3	17.3	19.0	21.3	22.8	22.8	22.8	22.3	20.9	16.7	13.5
		MCDB	18.2	20.4	23.6	25.0	28.0	31.2	31.2	30.7	28.0	26.3	21.7	18.1
	5%	WB	10.6	12.7	16.0	17.9	20.6	22.1	22.2	22.2	21.6	20.0	15.5	11.7
		MCDB	18.4	20.3	22.1	24.3	27.2	30.4	30.9	29.9	27.4	25.5	20.3	18.1
	10%	WB	8.9	11.1	14.7	16.9	19.9	21.6	21.7	21.7	20.9	19.1	14.1	10.0
		MCDB	16.2	19.3	21.1	24.0	26.9	29.9	30.5	29.3	27.2	24.8	19.8	15.9
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	14.6	14.8	15.1	13.8	13.1	12.2	12.1	11.9	13.3	13.8	13.2
		MCDBR	19.2	19.4	17.8	18.1	17.2	15.3	13.9	14.0	14.7	15.6	16.9	18.1
		MCWBR	9.6	9.5	7.9	7.3	6.3	4.8	4.4	4.3	5.0	6.1	8.0	9.4
	5% WB	MCDBR	16.6	16.5	14.0	14.0	13.7	12.9	11.8	11.7	10.7	11.9	12.4	15.0
		MCWBR	9.2	9.3	7.4	7.3	6.1	4.5	4.1	4.1	4.2	6.0	7.3	8.9
(40) Clear-Sky Solar Irradiance	taub		0.269	0.280	0.304	0.340	0.356	0.385	0.398	0.377	0.359	0.323	0.293	0.275
	taud		2.579	2.554	2.498	2.391	2.417	2.375	2.395	2.424	2.429	2.516	2.534	2.563
	Ebn at Noon		970	987	980	948	930	898	884	901	907	923	930	943
	Edh at Noon		79	90	103	119	118	122	119	114	109	93	82	77
(44) All-Sky Solar Radiation	RadAvg		3.39	4.17	5.41	6.65	7.00	7.49	7.13	6.61	5.46	4.45	3.55	3.00
	RadStd		0.34	0.48	0.40	0.42	0.57	0.38	0.42	0.31	0.39	0.55	0.39	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112	+78

Nomenclature: See separate page