

EDINBURG, TX, USA

WMO: 720276

Lat: 26.442N

Lon: 98.129W

Elev: 80

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12983

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.7	40.5	16.9	13.0	60.2	22.5	17.0	59.3	26.6	71.4	24.4	72.6	7.4	0	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.4	101.7	74.5	100.1	74.9	98.5	75.2	80.4	88.7	79.6	87.9	79.0	87.5	12.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.2	82.8	77.6	143.7	82.5	77.1	141.6	82.4	43.8	88.7	43.1	87.6	42.5	87.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.7	20.5	18.8	DB	31.4	105.3	3.5	1.7	28.9	106.5	26.8	107.5	24.9	108.4	22.3	109.7	(4)
			WB	28.5	81.1	3.2	1.0	26.1	81.8	24.3	82.4	22.5	83.0	20.1	83.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	61.0	66.2	71.3	77.3	82.5	86.3	87.0	88.0	83.5	77.5	68.8	62.3	(6)
		DBStd	11.62	9.44	10.02	8.19	6.14	4.70	2.83	3.08	2.86	3.92	6.58	8.73	9.43	(7)
		HDD50	45	18	8	2	0	0	0	0	0	0	3	14		(8)
		HDD65	569	191	102	39	3	0	0	0	0	5	63	166		(9)
		CDD50	9542	360	462	661	819	1006	1089	1147	1178	1005	852	567	396	(10)
		CDD65	4593	67	137	233	373	541	639	682	713	555	392	177	84	(11)
		CDH74	52291	514	1054	1922	3752	6178	8154	8877	9447	6091	4108	1560	634	(12)
(13)		CDH80	26114	117	361	680	1615	2992	4465	4970	5415	2942	1889	519	149	(13)
(14)	Wind	WSAvg	8.5	7.8	9.2	9.9	10.1	10.1	9.3	8.2	6.2	6.8	7.4	7.5		(14)
(15)	Precipitation	PrecAvg	21.2	0.8	0.8	1.1	1.5	2.1	2.3	2.0	1.6	4.4	2.2	1.2	1.1	(15)
(16)		PrecMax	30.7	3.4	3.2	5.2	4.6	6.1	8.9	11.0	5.3	10.4	6.7	3.7	4.6	(16)
(17)		PrecMin	7.6	0.1	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.2	0.8	0.9	1.2	1.5	1.5	2.0	2.7	1.5	2.7	1.9	1.0	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	87.4	93.0	93.4	99.1	99.0	102.5	102.9	103.6	101.1	97.3	92.3	87.9		(19)
(20)		0.4% MCWB	65.7	67.0	71.0	72.9	75.8	74.9	74.3	74.2	73.9	75.0	72.6	71.0		(20)
(21)		2% DB	83.2	88.1	89.7	94.1	96.6	99.6	101.0	101.9	98.1	94.3	88.7	84.3		(21)
(22)		2% MCWB	66.5	68.9	71.0	72.3	75.6	75.7	74.7	74.7	74.3	74.6	72.0	69.4		(22)
(23)		5% DB	80.2	84.4	86.9	91.2	94.7	97.8	99.4	100.3	95.8	92.0	86.0	81.0		(23)
(24)		5% MCWB	65.6	68.5	69.9	72.1	75.2	75.5	74.9	75.0	75.0	73.6	70.9	68.6		(24)
(25)		10% DB	76.2	81.0	83.9	88.8	92.6	96.1	97.2	98.4	93.1	89.9	82.5	77.4		(25)
(26)		10% MCWB	64.5	67.0	68.6	71.6	74.7	75.6	75.6	75.5	75.5	73.8	69.6	68.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	72.1	73.2	74.6	78.5	80.1	80.5	80.4	81.7	81.1	80.1	76.6	74.8		(27)
(28)		0.4% MCDB	79.4	84.4	85.5	90.0	93.2	91.4	89.2	88.7	89.1	88.0	84.2	82.8		(28)
(29)		2% WB	70.7	72.0	73.3	77.0	78.6	79.7	79.5	80.5	79.8	78.8	75.0	73.2		(29)
(30)		2% MCDB	77.6	81.1	82.6	87.6	89.7	89.4	87.9	87.7	86.8	86.4	83.3	79.6		(30)
(31)		5% WB	69.2	71.1	72.4	75.5	77.9	79.0	78.8	79.5	78.8	77.7	73.7	71.6		(31)
(32)		5% MCDB	75.8	79.1	81.0	85.0	88.1	88.3	87.4	87.0	86.1	85.4	81.5	77.9		(32)
(33)		10% WB	67.7	70.1	71.4	74.6	77.2	78.3	78.2	78.7	78.1	76.7	72.5	69.9		(33)
(34)		10% MCDB	74.2	77.6	79.2	83.6	86.7	87.6	87.0	86.8	85.7	84.6	80.0	76.1		(34)
(35)	Mean Daily Temperature Range	MDBR	21.5	21.3	20.7	21.7	19.5	20.2	20.3	21.4	18.9	22.1	21.9	20.5		(35)
(36)		5% DB MCDBR	25.0	23.8	21.6	22.7	20.7	22.1	22.9	23.5	22.4	22.7	22.9	23.2		(36)
(37)		5% DB MCWBR	12.0	8.9	7.4	7.9	5.0	4.4	4.9	5.1	5.6	7.2	9.2	11.9		(37)
(38)		5% WB MCDBR	20.0	19.4	18.3	19.0	17.5	18.8	19.6	20.1	17.8	18.9	19.8	19.6		(38)
(39)		5% WB MCWBR	11.3	9.2	7.7	6.6	5.1	4.7	4.9	5.3	5.5	7.2	9.6	11.9		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.367	0.390	0.419	0.429	0.418	0.426	0.420	0.422	0.378	0.368	0.348		(40)
(41)		taud	2.479	2.416	2.354	2.288	2.298	2.385	2.367	2.394	2.356	2.473	2.447	2.484		(41)
(42)		Ebn at Noon	286	288	287	280	275	276	274	276	273	281	276	281		(42)
(43)		Edh at Noon	30	35	39	43	43	39	39	38	38	33	31	29		(43)
(44)	All-Sky Solar Radiation	RadAvg	995	1209	1476	1745	1897	2121	2107	2017	1667	1450	1118	898		(44)
(45)		RadStd	111	189	175	162	141	80	148	95	129	147	123	128		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (21 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	+218	+205

Nomenclature: See separate page