

EDINBURG, TX, USA

WMO: 720276

Lat: 26.442N

Lon: 98.129W

Elev: 24

StdP: 101.03

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12983

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	4.7	-8.4	1.9	15.7	-5.3	2.4	15.1	11.9	21.9	10.9	22.6	3.3	0	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	38.7	23.6	37.8	23.8	36.9	24.0	26.9	31.5	26.4	31.1	26.1	30.8	5.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.5	28.2	25.3	20.5	28.1	25.1	20.2	28.0	84.1	31.5	82.4	30.9	81.0	30.8	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.6	9.2	8.4	-0.3	40.7	1.9	0.9	-1.7	41.4	-2.9	41.9	-4.0	42.5	-5.4	43.1		
			-2.0	27.3	1.8	0.6	-3.3	27.7	-4.3	28.0	-5.3	28.3	-6.6	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	16.1	19.0	21.8	25.2	28.0	30.2	30.6	31.1	28.6	25.3	20.5	16.9
	DBStd	6.45	5.24	5.57	4.55	3.41	2.61	1.57	1.71	1.59	2.18	3.66	4.85	5.24
	HDD10.0	25	10	4	1	0	0	0	0	0	0	0	2	8
	HDD18.3	316	106	57	22	2	0	0	0	0	0	3	35	92
	CDD10.0	5301	200	257	367	455	559	605	637	654	558	473	315	220
	CDD18.3	2552	37	76	129	207	301	355	379	396	308	218	98	47
	CDH23.3	29051	286	586	1068	2084	3432	4530	4932	5248	3384	2282	867	352
	CDH26.7	14508	65	201	378	897	1662	2481	2761	3008	1634	1049	288	83
Wind	WSAvg	3.8	3.5	4.1	4.4	4.5	4.5	4.1	4.1	3.7	2.8	3.1	3.3	3.4
Precipitation	PrecAvg	539	20	21	27	38	53	59	50	41	112	56	30	27
	PrecMax	779	87	82	131	118	154	226	280	134	265	171	93	117
	PrecMin	193	2	0	0	1	0	6	0	1	1	1	1	0
	PrecStd	133	20	23	31	38	39	50	68	37	68	47	25	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	33.9	34.1	37.3	37.2	39.2	39.4	39.8	38.4	36.3	33.5	31.1
		MCWB	18.7	19.4	21.7	22.7	24.3	23.8	23.5	23.5	23.3	23.9	22.6	21.7
	2%	DB	28.4	31.2	32.0	34.5	35.9	37.6	38.3	38.9	36.7	34.6	31.5	29.0
		MCWB	19.2	20.5	21.7	22.4	24.2	24.3	23.7	23.7	23.5	23.7	22.2	20.8
	5%	DB	26.8	29.1	30.5	32.9	34.8	36.5	37.4	38.0	35.4	33.3	30.0	27.2
		MCWB	18.7	20.3	21.0	22.3	24.0	24.1	23.9	23.9	23.9	23.1	21.6	20.3
	10%	DB	24.6	27.2	28.8	31.6	33.7	35.6	36.2	36.9	34.0	32.2	28.0	25.2
		MCWB	18.1	19.5	20.3	22.0	23.7	24.2	24.2	24.2	24.2	23.2	20.9	20.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	22.9	23.6	25.8	26.7	26.9	26.9	27.6	27.3	26.7	24.8	23.8
		MCDB	26.3	29.1	29.7	32.2	34.0	33.0	31.8	31.5	31.7	31.1	29.0	28.2
	2%	WB	21.5	22.2	22.9	25.0	25.9	26.5	26.4	27.0	26.5	26.0	23.9	22.9
		MCDB	25.3	27.3	28.1	30.9	32.1	31.9	31.1	30.9	30.5	30.2	28.5	26.4
	5%	WB	20.7	21.7	22.4	24.2	25.5	26.1	26.0	26.4	26.0	25.4	23.1	22.0
		MCDB	24.3	26.2	27.2	29.4	31.2	31.3	30.8	30.5	30.0	29.7	27.5	25.5
	10%	WB	19.8	21.2	21.9	23.7	25.1	25.7	25.7	25.9	25.6	24.8	22.5	21.0
		MCDB	23.5	25.3	26.2	28.7	30.4	30.9	30.6	30.4	29.8	29.2	26.7	24.5
Mean Daily Temperature Range	5% DB	MDBR	11.9	11.9	11.5	12.0	10.8	11.2	11.3	11.9	10.5	12.3	12.2	11.4
		MCDBR	13.9	13.2	12.0	12.6	11.5	12.3	12.7	13.0	12.5	12.6	12.7	12.9
		MCWBR	6.7	4.9	4.1	4.4	2.8	2.5	2.7	2.8	3.1	4.0	5.1	6.6
	5% WB	MCDBR	11.1	10.8	10.2	10.5	9.7	10.4	10.9	11.2	9.9	10.5	11.0	10.9
		MCWBR	6.3	5.1	4.3	3.7	2.8	2.6	2.7	2.9	3.0	4.0	5.3	6.6
Clear-Sky Solar Irradiance	taub	0.348	0.367	0.390	0.419	0.429	0.418	0.426	0.420	0.422	0.378	0.368	0.348	
	taud	2.479	2.416	2.354	2.288	2.298	2.385	2.367	2.394	2.356	2.473	2.447	2.484	
	Ebn at Noon	902	909	904	882	868	871	863	870	861	887	871	886	
	Edh at Noon	96	110	123	135	134	122	124	120	121	103	98	92	
All-Sky Solar Radiation	RadAvg	3.14	3.81	4.65	5.50	5.98	6.68	6.64	6.36	5.25	4.57	3.53	2.83	
	RadStd	0.35	0.60	0.55	0.51	0.45	0.25	0.47	0.30	0.41	0.46	0.39	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	+121	+114

Nomenclature: See separate page