

NORTH TEXAS REGIONAL, TX, USA

WMO: 720287

Lat: 33.714N

Lon: 96.674W

Elev: 749

StdP: 14.30

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 53967

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	25.4	8.6	8.8	27.8	12.2	10.5	33.7	28.4	58.5	26.4	57.0	7.9	340	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	100.0	73.7	97.8	73.6	95.4	73.7	78.3	90.3	77.4	89.0	76.6	88.1	9.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	137.3	82.0	74.4	132.3	81.9	73.3	127.4	81.7	42.3	90.5	41.3	89.2	40.4	87.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.9	22.3	19.7	13.9	103.3	4.1	2.9	11.0	105.4	8.6	107.1	6.3	108.7	3.3	110.8	
			DB												
			WB	12.4	79.0	3.6	1.6	9.7	80.1	7.6	81.1	5.5	82.0	2.9	83.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	44.1	47.7	56.6	63.2	71.2	80.6	84.0	83.7	77.3	67.0	56.0	46.0
	DBStd	16.29	10.31	10.85	9.41	7.97	7.10	4.75	4.86	4.97	6.05	8.52	9.06	9.71
	HDD50	696	240	159	45	8	0	0	0	0	0	3	44	197
	HDD65	2547	650	489	288	125	29	0	0	0	2	81	290	593
	CDD50	6125	57	95	248	404	657	919	1055	1044	820	530	224	72
	CDD65	2500	2	5	26	72	220	469	590	579	372	142	20	3
	CDH74	27853	7	29	156	487	1860	5356	7540	7203	3860	1219	123	13
	CDH80	13479	0	3	16	76	610	2583	4135	3908	1765	364	19	0
Wind	WSAvg	9.2	9.4	10.1	10.9	11.2	9.5	9.3	8.1	7.6	7.3	8.6	9.7	9.2
Precipitation	PrecAvg	40.1	1.8	2.7	3.2	3.7	5.7	4.3	2.0	2.2	5.2	4.2	3.0	2.2
	PrecMax	58.1	5.0	6.2	9.4	11.5	15.1	9.7	3.9	7.1	12.9	22.8	8.2	7.4
	PrecMin	18.6	0.0	0.2	0.3	0.1	0.6	0.8	0.0	0.0	0.8	0.2	0.6	0.2
	PrecStd	8.4	1.2	1.5	2.1	2.7	3.3	2.4	1.2	1.7	3.4	4.5	2.2	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.5	77.6	82.1	86.2	92.9	98.7	104.3	103.3	99.0	90.4	82.3	76.5
		MCWB	57.1	60.7	64.9	67.8	72.3	73.9	73.1	74.3	70.5	70.8	65.6	63.4
	2%	DB	70.2	72.9	78.5	81.7	89.8	96.1	100.0	100.3	95.2	87.5	77.3	71.0
		MCWB	58.0	60.5	64.0	67.0	72.1	73.8	73.4	74.2	72.2	71.1	63.2	59.6
	5%	DB	65.9	69.1	74.7	79.3	86.4	94.2	98.2	98.1	92.2	84.0	73.2	66.3
		MCWB	55.8	58.6	62.0	66.1	71.1	74.2	73.8	73.8	72.1	68.4	62.4	57.8
	10%	DB	61.5	65.2	71.7	76.8	83.4	91.4	95.4	95.1	89.9	81.2	70.2	62.6
		MCWB	51.3	57.9	61.2	64.8	69.9	73.6	74.2	73.8	71.7	66.0	61.3	54.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.5	66.4	69.0	72.9	76.8	79.2	79.9	78.9	78.5	75.0	70.9	66.7
		MCDB	69.4	73.1	76.7	80.0	86.5	90.5	93.1	92.3	88.8	84.9	76.9	71.9
	2%	WB	61.5	64.2	66.7	70.8	74.7	77.9	78.4	77.5	76.8	73.2	67.8	63.3
		MCDB	65.9	69.3	74.3	78.0	83.6	89.0	90.7	90.2	86.7	81.8	73.2	68.1
	5%	WB	57.9	61.5	65.3	69.0	73.4	76.7	77.4	76.7	75.4	71.7	65.2	60.3
		MCDB	63.9	66.7	72.1	76.3	82.8	87.8	89.2	89.4	84.9	79.9	70.5	64.3
	10%	WB	53.0	57.9	63.2	67.2	72.0	75.5	76.6	75.7	74.2	70.1	62.6	55.5
		MCDB	60.5	64.7	69.4	74.6	80.6	86.6	88.1	88.5	83.7	77.8	69.2	61.0
Mean Daily Temperature Range	5% DB	MDBR	20.0	19.7	20.1	20.2	18.8	18.9	19.6	19.9	20.1	21.3	19.9	18.7
		MCDBR	26.0	24.4	22.1	21.2	21.0	21.2	22.3	22.6	22.5	21.6	22.5	24.2
		MCWBR	16.0	15.2	11.9	11.6	8.3	5.8	5.3	5.3	6.5	8.9	12.5	15.6
	5% WB	MCDBR	21.2	21.0	19.1	18.1	18.1	18.6	18.8	19.6	18.0	17.9	19.1	19.9
		MCWBR	16.4	15.8	12.4	12.1	8.6	6.9	6.2	5.8	6.3	8.3	14.2	17.0
Clear-Sky Solar Irradiance	taub	0.310	0.320	0.354	0.386	0.423	0.435	0.440	0.441	0.396	0.353	0.331	0.313	
	taud	2.493	2.483	2.407	2.332	2.294	2.297	2.321	2.300	2.373	2.481	2.485	2.489	
	Ebn at Noon	287	296	292	286	275	271	268	266	275	280	277	279	
	Edh at Noon	27	30	36	40	42	42	41	41	36	30	27	26	
All-Sky Solar Radiation	RadAvg	881	1044	1383	1684	1820	2062	2102	1930	1613	1257	942	769	
	RadStd	90	155	102	129	179	213	129	121	155	185	120	95	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page