

NORTH TEXAS REGIONAL, TX, USA

WMO: 720287

Lat: 33.714N

Lon: 96.674W

Elev: 228

StdP: 98.61

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 53967

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.2	(c) -3.7	(d) -13.0	(e) 1.3	(f) -2.3	(g) -11.0	(h) 1.5	(i) 0.9	(j) 12.7	(k) 14.7	(l) 11.8	(m) 13.9	(n) 3.5	(o) 340	(p) 0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	37.8	23.2	36.6	23.1	35.2	23.2	25.7	32.4	25.2	31.7	24.8	31.2	4.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.6	27.8	23.6	18.9	27.7	23.0	18.2	27.6	80.6	32.5	78.2	31.8	76.1	31.0	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.2	(b) 9.9	(c) 8.8	(e) -10.0	(f) 39.6	(g) 2.3	(h) 1.6	(i) -11.7	(j) 40.8	(k) -13.0	(l) 41.7	(m) -14.3	(n) 42.6	(o) -16.0	(p) 43.8		
(a) 11.2	(b) 9.9	(c) 8.8	(e) -10.9	(f) 26.1	(g) 2.0	(h) 0.9	(i) -12.4	(j) 26.7	(k) -13.6	(l) 27.3	(m) -14.7	(n) 27.8	(o) -16.2	(p) 28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	6.7	8.7	13.6	17.3	21.8	27.0	28.9	28.7	25.2	19.4	13.3	7.8
	DBStd	9.05	5.73	6.03	5.23	4.43	3.94	2.64	2.70	2.76	3.36	4.73	5.03	5.39
	HDD10.0	387	133	88	25	4	0	0	0	0	0	2	24	109
	HDD18.3	1415	361	272	160	69	16	0	0	0	1	45	161	329
	CDD10.0	3403	32	53	138	224	365	511	586	580	456	294	124	40
	CDD18.3	1389	1	3	14	40	122	261	328	322	207	79	11	2
	CDH23.3	15474	4	16	87	271	1033	2976	4189	4002	2144	677	68	7
	CDH26.7	7488	0	2	9	42	339	1435	2297	2171	981	202	11	0
Wind	WSAvg	4.1	4.2	4.5	4.9	5.0	4.2	4.1	3.6	3.4	3.3	3.9	4.3	4.1
Precipitation	PrecAvg	1018	45	68	81	94	144	108	50	57	132	106	77	55
	PrecMax	1475	126	158	239	292	383	247	99	181	328	580	208	188
	PrecMin	473	1	5	8	3	15	20	0	0	21	5	14	5
	PrecStd	213	31	37	53	68	83	61	30	42	87	114	55	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.6	25.4	27.9	30.1	33.8	37.0	40.2	39.6	37.2	32.4	28.0	24.7
		MCWB	13.9	16.0	18.3	19.9	22.4	23.3	22.8	23.5	21.4	21.6	18.7	17.4
	2%	DB	21.2	22.7	25.8	27.6	32.1	35.6	37.8	38.0	35.1	30.8	25.1	21.6
		MCWB	14.4	15.9	17.8	19.4	22.3	23.2	23.0	23.5	22.3	21.7	17.4	15.3
	5%	DB	18.8	20.6	23.7	26.3	30.2	34.6	36.8	36.7	33.5	28.9	22.9	19.1
		MCWB	13.2	14.8	16.7	19.0	21.7	23.4	23.2	23.2	22.3	20.2	16.9	14.3
	10%	DB	16.4	18.5	22.1	24.9	28.5	33.0	35.2	35.1	32.2	27.3	21.2	17.0
		MCWB	10.7	14.4	16.2	18.2	21.1	23.1	23.5	23.2	22.0	18.9	16.3	12.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.0	19.1	20.6	22.7	24.9	26.2	26.6	26.0	25.8	23.9	21.6	19.3
		MCDB	20.8	22.8	24.8	26.7	30.3	32.5	33.9	33.5	31.5	29.4	24.9	22.2
	2%	WB	16.4	17.9	19.3	21.5	23.7	25.5	25.8	25.3	24.9	22.9	19.9	17.4
		MCDB	18.8	20.7	23.5	25.5	28.7	31.7	32.6	32.3	30.4	27.7	22.9	20.0
	5%	WB	14.4	16.4	18.5	20.6	23.0	24.8	25.2	24.8	24.1	22.1	18.4	15.7
		MCDB	17.7	19.3	22.3	24.6	28.2	31.0	31.8	31.9	29.4	26.6	21.4	18.0
	10%	WB	11.7	14.4	17.3	19.6	22.2	24.2	24.8	24.3	23.4	21.2	17.0	13.0
		MCDB	15.9	18.2	20.8	23.7	27.0	30.3	31.2	31.4	28.7	25.4	20.7	16.1
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.0	11.2	11.2	10.5	10.5	10.9	11.0	11.2	11.8	11.1	10.4
		MCDBR	14.5	13.6	12.3	11.8	11.7	11.8	12.4	12.5	12.5	12.0	12.5	13.4
		MCWBR	8.9	8.5	6.6	6.5	4.6	3.2	3.0	2.9	3.6	4.9	7.0	8.7
	5% WB	MCDBR	11.8	11.6	10.6	10.0	10.0	10.4	10.4	10.9	10.0	10.0	10.6	11.1
	MCWBR	9.1	8.8	6.9	6.7	4.8	3.8	3.5	3.2	3.5	4.6	7.9	9.4	
Clear-Sky Solar Irradiance	taub	0.310	0.320	0.354	0.386	0.423	0.435	0.440	0.441	0.396	0.353	0.331	0.313	
	taud	2.493	2.483	2.407	2.332	2.294	2.297	2.321	2.300	2.373	2.481	2.485	2.489	
	Ebn at Noon	906	933	921	901	867	853	846	840	866	883	872	880	
	Edh at Noon	85	96	112	126	133	132	128	129	115	95	86	81	
All-Sky Solar Radiation	RadAvg	2.78	3.29	4.36	5.31	5.74	6.50	6.63	6.08	5.08	3.96	2.97	2.42	
	RadStd	0.28	0.49	0.32	0.41	0.56	0.67	0.41	0.38	0.49	0.58	0.38	0.30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page