

SYLVANIA, GA, USA

WMO: 720301

Lat: 32.646N

Lon: 81.596W

Elev: 188

StdP: 14.60

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 63846

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.8	11.6	10.0	36.1	17.3	13.2	38.8	20.7	50.1	18.9	50.6	2.2	310	0.346

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	97.0	77.4	94.5	77.3	92.4	76.8	81.6	89.9	80.6	88.5	79.6	87.5	4.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	153.7	84.9	78.9	150.8	84.3	77.4	143.7	82.9	45.4	89.4	44.2	88.9	43.3	87.2	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
16.7	13.4	11.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			19.6	99.7	3.2	1.2	17.2	100.6	15.4	101.3	13.6	102.0	11.2	102.9		
			18.2	82.2	3.2	2.0	15.9	83.6	14.0	84.8	12.2	86.0	9.9	87.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	49.1	52.6	58.8	65.8	73.8	80.6	82.3	81.6	77.5	67.2	57.2	52.8	(6)
	DBStd	13.76	9.73	8.96	8.23	6.95	5.50	3.74	3.02	3.31	4.35	8.05	8.14	9.27	(7)
	HDD50	331	138	68	21	2	0	0	0	0	0	1	24	77	(8)
	HDD65	1884	499	359	224	73	7	0	0	0	0	71	259	392	(9)
	CDD50	6415	109	140	293	476	738	917	1002	979	824	535	238	164	(10)
	CDD65	2495	5	11	31	97	280	467	537	514	375	140	24	14	(11)
	CDH74	23982	27	79	307	1012	2664	4676	5603	4963	3287	1136	177	51	(12)
	CDH80	10357	1	5	50	288	1093	2172	2687	2289	1417	330	23	2	(13)
(14) Wind	WSAvg	3.9	4.6	4.8	5.0	4.7	4.0	3.3	3.1	2.9	3.5	3.3	3.6	4.1	(14)
(15) Precipitation	PrecAvg	46.7	3.8	3.6	3.9	3.0	3.2	5.4	5.3	5.4	3.8	3.5	2.6	3.3	(15)
	PrecMax	60.7	9.2	10.0	8.6	6.4	7.6	9.4	9.8	12.2	7.0	12.8	6.3	9.6	(16)
	PrecMin	32.1	0.8	0.6	0.3	0.7	0.9	2.2	1.4	2.0	0.7	0.1	0.4	0.6	(17)
	PrecStd	8.0	2.0	2.0	2.1	1.7	1.9	2.1	1.9	2.3	1.6	3.0	1.7	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.0	80.7	84.3	90.0	97.0	99.0	99.3	99.2	96.7	90.4	82.7	79.1	(19)
		MCWB	68.7	67.0	67.1	68.0	71.4	79.1	77.5	78.1	74.8	74.3	69.8	69.0	(20)
	2%	DB	72.7	76.6	81.2	86.4	91.6	95.4	96.7	96.3	92.6	87.5	79.2	74.9	(21)
		MCWB	64.9	65.4	64.4	67.9	71.7	77.6	78.4	78.0	75.9	73.8	67.4	67.4	(22)
	5%	DB	69.5	72.3	77.4	83.4	89.2	92.9	93.4	92.9	90.5	83.8	75.1	72.0	(23)
		MCWB	63.7	62.3	63.3	66.7	70.9	76.9	77.7	78.1	75.4	72.3	65.6	67.0	(24)
	10%	DB	65.6	68.2	73.3	80.7	86.2	90.6	91.3	90.6	88.3	80.9	72.1	68.4	(25)
		MCWB	61.0	60.6	61.7	65.8	70.9	76.4	77.6	77.6	74.8	70.3	64.9	64.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.2	70.3	70.7	74.6	77.5	82.1	83.7	82.5	81.0	79.5	74.3	73.3	(27)
		MCDB	74.1	76.1	77.9	81.8	84.2	91.8	93.3	91.1	88.2	83.9	77.9	76.0	(28)
	2%	WB	67.4	67.5	68.0	72.3	75.8	80.6	82.1	81.3	79.4	77.5	71.5	70.4	(29)
		MCDB	71.1	73.4	75.9	79.6	83.5	89.4	90.9	89.1	87.0	82.4	74.6	72.6	(30)
	5%	WB	64.7	65.0	66.2	70.6	74.6	79.5	80.7	80.3	78.1	75.7	69.5	67.6	(31)
		MCDB	67.6	70.2	73.3	77.8	82.5	88.4	88.7	87.9	85.9	80.7	73.6	70.5	(32)
	10%	WB	61.8	62.2	64.4	68.7	73.4	78.4	79.5	79.3	76.9	73.5	66.2	64.5	(33)
		MCDB	65.0	66.2	70.0	76.0	81.3	86.7	87.1	86.8	84.4	78.1	70.7	67.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.0	22.2	23.1	23.9	22.1	19.1	19.0	18.2	19.9	22.1	23.3	20.7	(35)
		MCDBR	23.0	25.1	26.2	27.1	25.7	21.8	21.3	21.1	23.2	22.7	25.8	20.9	(36)
	5% WB	MCWBR	15.4	14.6	12.4	10.7	8.5	7.2	7.0	7.2	9.0	10.7	15.0	14.1	(37)
		MCWBR	19.6	21.2	20.8	20.8	19.4	18.5	18.5	18.2	19.4	17.6	18.6	16.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.326	0.334	0.364	0.401	0.453	0.498	0.531	0.519	0.429	0.394	0.353	0.329	(40)
		taud	2.498	2.471	2.417	2.307	2.197	2.123	2.048	2.078	2.322	2.383	2.455	2.523	(41)
	Ebn at Noon		284	292	290	282	267	254	245	246	266	267	271	276	(42)
		Edh at Noon	28	31	36	41	47	50	54	51	39	34	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		926	1124	1464	1844	1982	1994	1939	1765	1515	1303	1018	809	(44)
	RadStd		46	108	118	124	128	148	134	98	126	146	74	72	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	+1.03	N/A	N/A	N/A	N/A	N/A	N/A	-167	+351	+243

Nomenclature: See separate page