

SYLVANIA, GA, USA

WMO: 720301

Lat: 32.646N

Lon: 81.596W

Elev: 57

StdP: 100.64

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 63846

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	-1.2	-11.4	1.4	2.3	-8.2	1.9	3.8	9.3	10.1	8.4	10.4	1.0	310	0.346

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	36.1	25.2	34.7	25.1	33.6	24.9	27.6	32.1	27.0	31.4	26.5	30.8	2.2	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	22.0	29.4	26.0	21.5	29.1	25.2	20.5	28.3	87.6	31.9	84.9	31.6	82.7	30.7	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.0	5.1	-6.9	37.6	1.8	0.7	-8.2	38.1	-9.2	38.5	-10.2	38.9	-11.5	39.4		
			-7.7	27.9	1.8	1.1	-9.0	28.7	-10.0	29.4	-11.0	30.0	-12.3	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	9.5	11.4	14.9	18.8	23.2	27.0	28.0	27.5	25.3	19.6	14.0	11.6
	DBStd	7.65	5.40	4.98	4.57	3.86	3.05	2.08	1.68	1.84	2.42	4.47	4.52	5.15
	HDD10.0	184	77	38	12	1	0	0	0	0	0	1	13	43
	HDD18.3	1047	277	199	124	41	4	0	0	0	0	39	144	218
	CDD10.0	3564	61	78	163	264	410	509	557	544	458	297	132	91
	CDD18.3	1386	3	6	17	54	156	259	298	286	208	78	13	8
	CDH23.3	13323	15	44	171	562	1480	2598	3113	2757	1826	631	98	28
	CDH26.7	5754	1	3	28	160	607	1207	1493	1272	787	183	13	1
Wind	WSAvg	1.7	2.1	2.1	2.2	2.1	1.8	1.5	1.4	1.3	1.6	1.5	1.6	1.8
Precipitation	PrecAvg	1186	96	91	99	75	82	138	134	136	96	90	66	84
	PrecMax	1543	233	253	218	163	192	238	249	311	178	326	161	244
	PrecMin	816	21	14	7	18	24	55	36	51	17	3	11	15
	PrecStd	202	51	51	54	43	48	54	49	59	41	77	43	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.6	27.1	29.1	32.2	36.1	37.2	37.4	37.4	35.9	32.4	28.2	26.2
		MCWB	20.4	19.5	19.5	20.0	21.9	26.2	25.3	25.6	23.8	23.5	21.0	20.5
	2%	DB	22.6	24.8	27.3	30.2	33.1	35.2	35.9	35.7	33.7	30.8	26.2	23.8
		MCWB	18.3	18.5	18.0	20.0	22.1	25.4	25.8	25.6	24.4	23.2	19.7	19.7
	5%	DB	20.8	22.4	25.2	28.5	31.8	33.8	34.1	33.8	32.5	28.8	23.9	22.2
		MCWB	17.6	16.8	17.4	19.3	21.6	24.9	25.4	25.6	24.1	22.4	18.7	19.4
	10%	DB	18.7	20.1	23.0	27.0	30.1	32.5	32.9	32.6	31.3	27.2	22.3	20.2
		MCWB	16.1	15.9	16.5	18.8	21.6	24.6	25.3	25.3	23.8	21.3	18.3	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.3	21.5	23.7	25.3	27.8	28.7	28.1	27.2	26.4	23.5	22.9
		MCDB	23.4	24.5	25.5	27.7	29.0	33.2	34.1	32.8	31.2	28.8	25.5	24.4
	2%	WB	19.6	19.7	20.0	22.4	24.3	27.0	27.8	27.4	26.3	25.3	21.9	21.3
		MCDB	21.7	23.0	24.4	26.4	28.6	31.9	32.7	31.7	30.5	28.0	23.7	22.5
	5%	WB	18.2	18.3	19.0	21.5	23.7	26.4	27.1	26.8	25.6	24.3	20.8	19.8
		MCDB	19.8	21.2	22.9	25.5	28.0	31.3	31.5	31.1	29.9	27.0	23.1	21.4
	10%	WB	16.6	16.8	18.0	20.4	23.0	25.8	26.4	26.3	24.9	23.0	19.0	18.1
		MCDB	18.3	19.0	21.1	24.5	27.4	30.4	30.6	30.5	29.1	25.6	21.5	19.8
Mean Daily Temperature Range	5% DB	MDBR	11.7	12.3	12.8	13.3	12.3	10.6	10.6	10.1	11.1	12.3	13.0	11.5
		MCDBR	12.8	13.9	14.6	15.0	14.3	12.1	11.8	11.7	12.9	12.6	14.3	11.6
		MCWBR	8.5	8.1	6.9	6.0	4.7	4.0	3.9	4.0	5.0	5.9	8.3	7.9
	5% WB	MCDBR	10.9	11.8	11.6	11.5	10.8	10.3	10.3	10.1	10.8	9.8	10.3	9.2
		MCWBR	8.5	8.0	6.6	5.8	4.4	4.1	4.2	4.2	4.6	5.0	7.2	7.3
Clear-Sky Solar Irradiance	taub	0.326	0.334	0.364	0.401	0.453	0.498	0.531	0.519	0.429	0.394	0.353	0.329	
	taud	2.498	2.471	2.417	2.307	2.197	2.123	2.048	2.078	2.322	2.383	2.455	2.523	
	Ebn at Noon	894	921	914	889	842	800	772	775	838	842	853	870	
	Edh at Noon	87	98	112	130	147	157	169	162	122	106	90	81	
All-Sky Solar Radiation	RadAvg	2.92	3.54	4.61	5.81	6.25	6.29	6.11	5.56	4.78	4.11	3.21	2.55	
	RadStd	0.14	0.34	0.37	0.39	0.40	0.47	0.42	0.31	0.40	0.46	0.23	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	+0.57	N/A	N/A	N/A	N/A	N/A	N/A	-93	+195	+135

Nomenclature: See separate page