

MT PLEASANT, TX, USA

WMO: 720311

Lat: 33.096N

Lon: 94.961W

Elev: 363

StdP: 14.50

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53962

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	27.5	10.2	9.4	33.9	14.5	11.6	35.3	24.1	51.3	20.8	51.9	4.5	320	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.5	99.5	74.4	97.3	74.4	95.0	74.4	78.3	90.0	77.6	89.4	77.1	88.5	6.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.8	136.9	80.5	75.0	133.2	80.4	74.1	129.1	80.4	42.0	91.0	41.3	89.2	40.6	88.7	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.8	17.4	15.4	DB	16.7	102.4	4.3	2.7	13.6	104.3	11.1	105.9	8.7	107.4	5.6	109.4	
			WB	15.4	79.8	3.7	1.3	12.7	80.7	10.5	81.4	8.4	82.1	5.7	83.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	45.7	49.2	57.3	63.8	72.0	80.1	82.0	83.4	77.1	66.0	55.4	47.8	(6)
	DBStd	15.34	9.89	10.24	9.25	7.41	6.37	3.89	3.73	4.35	5.62	8.33	9.05	9.41	(7)
	HDD50	582	201	129	39	5	0	0	0	0	0	2	48	158	(8)
	HDD65	2380	602	448	267	107	19	0	0	0	1	92	308	536	(9)
	CDD50	6083	68	107	266	418	682	903	993	1037	812	497	209	91	(10)
	CDD65	2406	4	6	29	70	236	453	528	572	363	122	19	4	(11)
	CDH74	25715	13	35	194	586	2097	4860	6004	6954	3705	1128	118	21	(12)
	CDH80	12282	0	2	21	95	715	2343	3091	3860	1778	362	15	0	(13)
(14) Wind	WSAvg	5.9	6.9	7.4	7.6	7.4	6.0	5.1	4.2	4.1	4.3	5.2	5.9	6.4	(14)
(15) Precipitation	PrecAvg	46.3	4.0	3.7	4.8	4.1	5.0	4.1	3.9	2.6	3.7	4.5	4.1	4.1	(15)
	PrecMax	72.3	9.3	9.4	10.0	9.6	9.9	10.4	10.2	7.6	8.4	17.2	12.1	7.1	(16)
	PrecMin	24.9	0.3	0.4	1.4	1.5	1.0	0.1	0.0	0.3	0.6	0.2	1.1	0.6	(17)
	PrecStd	12.6	2.1	2.3	2.2	2.1	2.8	2.9	3.1	1.9	2.1	3.7	2.5	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.1	78.2	82.3	87.6	92.5	99.2	100.1	104.4	99.2	90.8	82.0	77.2	(19)
		MCWB	59.7	62.8	64.1	69.3	72.6	73.4	75.6	72.0	72.4	71.3	68.2	65.6	(20)
	2%	DB	72.1	73.9	79.2	82.1	89.7	96.4	97.9	100.3	95.3	87.8	77.3	72.5	(21)
		MCWB	60.8	61.0	63.9	66.9	72.2	73.8	75.5	73.8	72.3	71.5	65.1	62.8	(22)
	5%	DB	68.0	70.5	75.6	80.4	86.8	93.3	95.4	98.8	92.5	84.3	73.3	68.8	(23)
		MCWB	59.3	61.0	62.3	66.0	71.7	74.5	75.7	74.5	72.3	68.8	63.8	61.0	(24)
	10%	DB	63.3	66.9	72.4	77.4	84.2	90.9	93.0	95.8	90.0	80.9	70.4	64.3	(25)
		MCWB	54.7	58.8	61.1	64.8	70.6	74.4	75.2	74.5	72.0	67.5	62.9	57.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	67.4	68.4	72.6	76.6	79.2	79.2	79.4	77.6	75.5	71.6	68.8	(27)
		MCDB	71.6	73.8	76.7	80.1	85.9	89.4	91.7	91.3	88.2	84.6	77.8	73.0	(28)
	2%	WB	64.0	65.4	66.6	70.5	75.0	78.0	78.2	78.3	76.6	74.1	68.9	66.1	(29)
		MCDB	68.6	70.4	74.6	78.1	84.5	88.2	90.5	90.6	86.8	82.5	73.7	70.6	(30)
	5%	WB	61.1	63.2	65.1	68.9	73.7	77.2	77.5	77.6	75.5	72.6	66.4	62.9	(31)
		MCDB	66.3	67.9	72.5	76.5	83.0	87.3	89.6	90.2	85.4	80.4	71.7	66.9	(32)
	10%	WB	56.1	60.2	63.4	67.4	72.4	76.3	76.9	76.9	74.6	70.8	64.0	59.3	(33)
		MCDB	61.7	66.3	70.0	75.0	81.3	85.9	88.5	88.9	84.1	77.4	68.7	63.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.2	19.7	21.0	21.9	20.2	20.1	20.4	22.5	22.1	23.1	21.9	19.9	(35)
		MCDBR	26.2	24.2	23.6	24.1	22.3	23.3	23.9	26.2	25.4	25.2	24.2	25.1	(36)
		MCWBR	15.9	14.7	11.8	11.4	8.4	6.4	6.0	5.7	7.3	10.4	13.9	16.9	(37)
	5% WB	MCDBR	20.4	20.1	19.3	18.9	19.5	19.6	20.5	21.6	20.6	19.8	18.8	21.4	(38)
		MCWBR	15.4	14.8	12.0	11.2	8.7	6.8	6.5	6.3	7.0	9.7	13.9	16.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.321	0.335	0.359	0.396	0.428	0.446	0.461	0.458	0.407	0.360	0.342	0.325	(40)
	taud		2.488	2.464	2.416	2.313	2.283	2.272	2.266	2.264	2.367	2.472	2.472	2.489	(41)
	Ebn at Noon		284	292	292	283	274	267	263	262	272	279	273	276	(42)
	Edh at Noon		28	31	35	41	43	43	43	43	37	31	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		857	971	1353	1674	1828	2010	2028	1893	1595	1267	920	750	(44)
	RadStd		79	153	116	110	155	188	139	147	145	176	114	97	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page