

PERRYTON OCHILTREE COUNTY AP, TX, USA

WMO: 720315

Lat: 36.414N

Lon: 100.750W

Elev: 889

StdP: 91.09

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03045

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-9.8	-17.7	0.9	-8.4	-15.5	1.1	-4.8	15.1	8.8	13.9	8.6	4.7	0	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	38.7	19.6	37.3	19.7	36.0	19.7	22.8	31.1	22.1	30.7	21.6	30.1	7.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	17.2	25.3	20.1	16.4	24.8	19.3	15.6	24.4	72.0	31.1	69.4	30.9	67.2	29.9	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.1	12.2	11.0	-16.7	41.2	2.8	1.8	-18.8	42.5	-20.4	43.6	-22.0	44.6	-24.1	45.9		
			-17.3	23.7	2.6	0.9	-19.2	24.4	-20.8	24.9	-22.2	25.4	-24.1	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	2.6	3.8	9.4	13.7	18.9	25.2	27.1	26.0	22.3	15.0	8.5	2.7
	DBStd	10.10	5.46	6.31	5.54	5.19	4.89	3.44	3.08	3.05	3.99	5.19	5.33	5.43
	HDD10.0	857	233	188	77	22	2	0	0	0	0	14	89	231
	HDD18.3	2301	486	408	279	156	53	1	0	0	12	126	296	485
	CDD10.0	2559	5	14	59	132	279	456	529	497	369	171	44	4
	CDD18.3	964	0	1	3	16	72	207	271	239	131	24	1	0
	CDH23.3	11974	2	24	97	323	979	2554	3437	2679	1469	359	48	1
	CDH26.7	6362	0	6	26	121	449	1401	2023	1484	711	132	9	0
Wind	WSAvg	5.3	5.0	5.3	5.6	6.2	5.4	5.7	4.9	4.5	5.0	5.2	5.2	5.0
Precipitation	PrecAvg	550	15	14	37	46	70	81	79	73	42	46	24	24
	PrecMax	681	52	41	100	156	134	152	198	145	156	144	104	94
	PrecMin	395	0	0	0	0	6	5	24	2	0	1	0	0
	PrecStd	75	14	13	28	42	28	44	47	35	36	40	25	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.4	26.7	29.7	33.4	37.0	41.1	40.7	40.0	37.5	33.6	27.8	21.0
		MCWB	9.9	10.8	12.9	14.1	16.2	18.2	19.8	20.1	18.7	16.8	12.7	9.8
	2%	DB	18.8	22.2	26.2	30.1	33.8	37.8	38.7	37.7	35.3	30.2	24.1	17.4
		MCWB	7.9	10.0	12.3	14.1	16.7	19.2	20.1	20.0	18.7	16.7	12.1	8.3
	5%	DB	15.2	18.3	22.8	27.3	31.8	36.0	37.4	36.2	33.0	27.4	21.1	14.6
		MCWB	6.4	8.1	11.3	13.8	16.8	19.6	20.1	20.3	18.8	15.5	10.8	7.0
	10%	DB	12.2	14.3	19.9	24.0	29.0	33.9	36.0	34.1	31.1	24.5	17.7	11.8
		MCWB	5.2	6.5	10.7	13.3	16.8	19.7	20.2	20.3	18.6	14.9	9.5	5.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	12.7	16.9	18.2	21.7	23.3	23.7	23.3	22.6	20.6	15.1	11.8
		MCDB	20.7	21.6	23.1	24.5	28.3	32.1	31.9	31.3	29.9	26.6	20.1	15.9
	2%	WB	8.8	10.4	14.9	16.8	20.5	22.4	22.8	22.5	21.3	19.0	13.2	9.3
		MCDB	17.2	20.7	20.6	23.2	26.9	31.4	31.2	30.7	28.8	24.9	20.6	15.8
	5%	WB	7.0	8.8	13.2	15.5	19.4	21.6	22.0	21.9	20.6	17.7	11.8	7.5
		MCDB	14.6	18.1	19.6	22.5	26.0	30.6	31.0	30.2	28.1	23.5	19.2	13.7
	10%	WB	5.4	7.0	11.5	14.2	18.2	21.0	21.4	21.3	20.0	16.3	10.4	5.8
		MCDB	11.6	14.1	19.3	22.0	25.5	29.5	30.5	29.5	27.2	22.2	17.6	11.5
Mean Daily Temperature Range	5% DB	MDBR	14.3	14.7	15.7	15.6	14.9	14.9	14.6	14.1	14.6	14.8	15.0	13.2
		MCDBR	19.6	21.7	19.9	20.8	19.0	17.7	17.0	16.9	17.3	18.9	19.2	17.9
		MCWBR	11.0	11.2	9.7	8.9	7.1	5.0	4.2	4.2	5.3	7.9	9.3	10.3
	5% WB	MCDBR	18.5	20.6	16.4	15.2	14.6	14.7	14.4	13.6	13.7	14.2	16.9	16.5
		MCWBR	10.6	11.0	8.8	7.7	6.9	5.1	4.3	4.2	4.8	7.1	8.9	10.0
Clear-Sky Solar Irradiance	taub	0.257	0.265	0.297	0.325	0.343	0.373	0.381	0.366	0.337	0.301	0.273	0.257	
	taud	2.586	2.578	2.487	2.426	2.443	2.402	2.411	2.417	2.479	2.560	2.571	2.591	
	Ebn at Noon	961	990	976	957	938	906	896	904	919	931	931	939	
	Edh at Noon	73	83	101	113	113	118	116	113	101	84	74	69	
All-Sky Solar Radiation	RadAvg	2.89	3.68	4.91	6.09	6.89	7.42	7.23	6.42	5.46	4.07	3.12	2.53	
	RadStd	0.26	0.39	0.39	0.37	0.47	0.44	0.34	0.32	0.26	0.48	0.30	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page