

NUECES COUNTY AP, TX, USA

WMO: 720316

Lat: 27.779N

Lon: 97.691W

Elev: 79

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12984

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.6	36.9	16.3	12.6	49.0	20.9	15.7	51.5	29.9	68.2	27.3	66.2	9.6	340	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	99.2	76.9	97.4	77.3	95.7	77.4	81.9	89.0	81.1	88.3	80.3	87.7	12.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.5	83.7	79.4	153.0	83.3	78.8	149.8	83.1	45.5	89.6	44.6	87.9	43.8	87.8	95.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.1	23.7	20.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.5	57.5	62.1	68.4	74.1	79.1	83.7	85.6	86.5	82.7	75.4	66.9	59.6
	DBStd	12.13	9.29	10.09	8.08	6.24	4.55	2.67	2.67	2.81	3.85	7.34	8.67	9.87
	HDD50	88	35	20	3	0	0	0	0	0	0	4	26	26
	HDD65	820	266	159	62	9	0	0	0	0	14	83	227	227
	CDD50	8676	268	359	572	724	902	1012	1104	1131	982	788	510	324
	CDD65	3933	34	78	166	283	437	562	639	666	532	337	139	60
	CDH74	42203	228	462	1014	2231	4288	6645	8090	8589	5860	3344	1078	374
	CDH80	19113	31	106	247	714	1608	3202	4192	4630	2706	1332	279	66
Wind	WSAvg	9.8	10.0	10.8	11.8	12.2	10.8	9.0	9.1	8.9	7.4	8.6	9.1	9.4
Precipitation	PrecAvg	31.7	1.6	1.7	2.4	2.0	3.5	3.0	2.7	2.8	5.0	3.4	2.0	1.7
	PrecMax	46.7	5.1	4.6	6.0	8.2	12.0	10.2	17.1	7.2	14.4	14.6	7.1	8.2
	PrecMin	14.6	0.0	0.0	0.2	0.1	0.0	0.2	0.0	0.4	1.1	0.0	0.1	0.2
	PrecStd	8.2	1.3	1.4	1.6	1.9	2.7	2.1	3.6	2.2	3.0	3.2	1.7	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.0	88.3	90.7	95.1	94.5	99.0	100.4	101.6	100.4	94.6	89.3	85.7
		MCWB	64.9	68.6	69.2	70.1	76.8	76.2	77.5	75.2	74.7	76.7	73.2	69.7
	2%	DB	79.5	83.0	85.3	90.1	91.5	96.0	98.5	99.4	96.7	91.7	86.2	81.6
		MCWB	65.8	67.9	70.7	72.2	75.6	77.2	77.9	77.0	76.0	76.1	72.4	69.3
	5%	DB	76.5	79.8	82.4	86.8	90.0	93.9	96.6	97.8	93.8	90.0	83.3	78.5
		MCWB	64.9	68.0	70.0	71.4	75.6	77.3	77.8	77.5	76.6	75.1	71.5	68.2
	10%	DB	72.4	76.4	79.9	84.1	88.0	92.0	94.8	96.0	91.6	87.7	80.6	74.7
		MCWB	65.0	66.9	68.8	71.3	75.2	77.3	77.9	77.7	76.5	73.8	70.0	68.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	74.4	77.7	79.4	81.0	82.3	82.9	83.2	82.4	81.1	77.5	74.7
		MCDB	74.9	79.1	80.7	84.7	86.4	89.4	90.5	90.6	90.0	88.0	82.5	79.1
	2%	WB	70.6	72.4	74.0	77.3	79.7	81.1	81.2	81.7	81.3	79.4	76.0	73.2
		MCDB	74.9	78.2	79.8	84.1	85.0	88.2	89.6	88.8	87.8	86.4	81.5	77.3
	5%	WB	69.0	70.8	72.7	75.7	78.6	80.3	80.3	80.7	80.3	78.1	74.6	71.5
		MCDB	73.7	76.6	78.6	82.0	84.5	87.4	88.6	88.2	86.9	84.9	80.1	76.2
	10%	WB	66.8	69.4	71.4	74.5	77.7	79.4	79.7	80.0	79.3	77.0	72.7	69.6
		MCDB	71.3	74.2	76.9	80.5	84.2	86.7	87.9	87.9	86.0	83.7	78.0	73.9
Mean Daily Temperature Range	5% DB	MDBR	21.0	20.1	19.4	18.7	16.9	17.6	18.2	19.5	17.8	20.6	20.7	20.2
		MCDBR	25.4	22.4	19.8	20.3	19.1	20.3	21.2	21.2	20.5	20.3	20.7	22.9
		MCWBR	14.9	11.6	9.6	9.1	6.6	5.9	5.4	5.1	6.2	7.9	9.5	13.5
	5% WB	MCDBR	18.5	18.0	17.0	16.1	14.4	16.2	18.0	18.4	16.8	17.3	17.2	19.1
		MCWBR	12.7	10.8	10.3	8.0	6.2	5.7	5.3	5.2	5.9	8.8	9.5	13.2
Clear-Sky Solar Irradiance	taub	0.355	0.362	0.383	0.430	0.471	0.447	0.455	0.448	0.439	0.390	0.375	0.348	0.348
	taud	2.464	2.447	2.388	2.268	2.186	2.313	2.307	2.325	2.317	2.443	2.433	2.499	2.499
	Ebn at Noon	281	289	288	276	264	268	266	267	267	275	272	279	279
	Edh at Noon	30	33	37	43	47	42	42	41	40	33	31	28	28
All-Sky Solar Radiation	RadAvg	960	1136	1436	1706	1892	2106	2085	1997	1649	1432	1077	862	862
	RadStd	104	193	160	164	148	104	172	110	145	156	113	119	119

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	+218	+189

Nomenclature: See separate page