

NUECES COUNTY AP, TX, USA

WMO: 720316

Lat: 27.779N

Lon: 97.691W

Elev: 24

StdP: 101.04

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12984

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.7	-8.7	1.8	9.5	-6.2	2.2	10.8	13.4	20.1	12.2	19.0	4.3	340	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	37.4	24.9	36.3	25.2	35.4	25.2	27.7	31.7	27.3	31.3	26.8	30.9	5.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.9	28.7	26.3	21.9	28.5	26.0	21.4	28.4	87.9	32.0	85.9	31.0	84.1	31.0	35.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.7	10.6	9.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	14.2	16.7	20.2	23.4	26.2	28.7	29.8	30.3	28.2	24.1	19.4	15.3	
	DBStd	6.74	5.16	5.61	4.49	3.47	2.53	1.48	1.48	1.56	2.14	4.08	4.82	5.48	
	HDD10.0	49	19	11	2	0	0	0	0	0	0	0	2	14	
	HDD18.3	456	148	88	34	5	0	0	0	0	0	8	46	126	
	CDD10.0	4820	149	199	318	402	501	562	613	628	546	438	283	180	
	CDD18.3	2185	19	43	92	157	243	312	355	370	296	187	77	33	
	CDH23.3	23446	127	257	563	1239	2382	3692	4494	4772	3256	1858	599	208	
CDH26.7	10618	17	59	137	397	893	1779	2329	2572	1503	740	155	37		
Wind	WSAvg	4.4	4.5	4.8	5.3	5.5	4.8	4.0	4.1	4.0	3.3	3.9	4.1	4.2	
Precipitation	PrecAvg	804	40	42	62	51	89	76	68	70	126	87	52	42	
	PrecMax	1186	130	116	152	208	304	258	435	184	367	372	180	209	
	PrecMin	372	0	1	4	3	1	5	0	11	29	0	2	6	
	PrecStd	209	34	36	41	49	68	54	92	56	77	81	44	45	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.4	31.3	32.6	35.0	34.7	37.2	38.0	38.7	38.0	34.8	31.8	29.8	
		MCWB	18.3	20.3	20.6	21.2	24.9	24.5	25.3	24.0	23.7	24.8	22.9	20.9	
	2%	DB	26.4	28.3	29.6	32.3	33.0	35.6	36.9	37.4	35.9	33.2	30.1	27.6	
		MCWB	18.8	19.9	21.5	22.3	24.2	25.1	25.5	25.0	24.4	24.5	22.5	20.7	
	5%	DB	24.7	26.6	28.0	30.4	32.2	34.4	35.9	36.5	34.4	32.2	28.5	25.8	
		MCWB	18.3	20.0	21.1	21.9	24.2	25.2	25.4	25.3	24.8	23.9	21.9	20.1	
	10%	DB	22.5	24.7	26.6	28.9	31.1	33.4	34.9	35.6	33.1	31.0	27.0	23.7	
		MCWB	18.4	19.4	20.4	21.8	24.0	25.2	25.5	25.4	24.7	23.2	21.1	20.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	23.6	25.4	26.3	27.2	27.9	28.3	28.5	28.0	27.3	25.3	23.7
			MCDB	23.8	26.2	27.1	29.3	30.2	31.9	32.5	32.5	32.2	31.1	28.0	26.1
2%		WB	21.5	22.4	23.3	25.1	26.5	27.3	27.3	27.6	27.4	26.3	24.4	22.9	
		MCDB	23.8	25.7	26.5	28.9	29.4	31.2	32.0	31.6	31.0	30.2	27.5	25.2	
5%		WB	20.6	21.6	22.6	24.3	25.9	26.8	26.8	27.1	26.8	25.6	23.7	22.0	
		MCDB	23.1	24.8	25.9	27.8	29.2	30.8	31.5	31.2	30.5	29.4	26.7	24.5	
10%		WB	19.4	20.8	21.9	23.6	25.4	26.3	26.5	26.6	26.3	25.0	22.6	20.9	
		MCDB	21.8	23.4	24.9	26.9	29.0	30.4	31.1	31.1	30.0	28.7	25.6	23.3	
Mean Daily Temperature Range		5% DB	MDBR	11.6	11.1	10.8	10.4	9.4	9.8	10.1	10.8	9.9	11.5	11.5	11.2
			MCDBR	14.1	12.5	11.0	11.3	10.6	11.3	11.8	11.8	11.4	11.3	11.5	12.7
	MCWBR		8.3	6.5	5.3	5.0	3.7	3.3	3.0	2.9	3.5	4.4	5.3	7.5	
	5% WB	MCDBR	10.3	10.0	9.5	9.0	8.0	9.0	10.0	10.2	9.3	9.6	9.6	10.6	
		MCWBR	7.1	6.0	5.7	4.4	3.4	3.2	3.0	2.9	3.3	4.9	5.3	7.3	
Clear-Sky Solar Irradiance	taub	0.355	0.362	0.383	0.430	0.471	0.447	0.455	0.448	0.439	0.390	0.375	0.348	0.348	
	taud	2.464	2.447	2.388	2.268	2.186	2.313	2.307	2.325	2.317	2.443	2.433	2.499	2.499	
	Ebn at Noon	887	910	908	870	831	846	837	843	842	868	856	879	879	
	Edh at Noon	96	105	118	137	149	131	131	128	125	105	98	89	89	
All-Sky Solar Radiation	RadAvg	3.03	3.58	4.53	5.38	5.96	6.64	6.57	6.29	5.20	4.51	3.40	2.72	2.72	
	RadStd	0.33	0.61	0.51	0.52	0.47	0.33	0.54	0.35	0.46	0.49	0.36	0.38	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Regional (31 neighbors)	N/A	N/A	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	+121	+105

Nomenclature: See separate page