

CLEBURNE, TX, USA

WMO: 720320

Lat: 32.354N

Lon: 97.434W

Elev: 854

StdP: 14.25

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53981

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	27.7	9.6	9.3	31.6	13.9	11.5	36.9	27.7	45.2	24.7	46.7	7.6	340	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.8	100.5	73.6	99.3	74.0	97.2	73.9	79.0	88.0	78.2	87.6	77.5	87.2	9.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	145.5	81.8	75.4	137.5	80.6	75.1	135.8	80.4	43.2	87.5	42.1	88.3	41.4	87.2	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	20.3	18.4	16.1	104.7	4.0	3.0	13.2	106.8	10.9	108.6	8.6	110.3	5.7	112.5
			15.4	80.6	3.7	1.4	12.7	81.5	10.5	82.3	8.4	83.1	5.7	84.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	46.9	50.9	58.8	65.5	73.3	82.3	85.0	85.3	79.5	68.1	57.0	48.2	(6)
	DBStd	15.84	9.93	10.87	9.33	7.66	6.43	4.03	3.86	4.50	5.21	8.60	9.41	9.51	(7)
	HDD50	520	176	113	33	4	0	0	0	0	0	4	40	150	(8)
	HDD65	2161	564	405	233	85	14	0	0	0	0	69	267	524	(9)
	CDD50	6657	80	138	304	468	723	968	1084	1095	886	565	250	96	(10)
	CDD65	2822	3	10	39	99	272	518	619	630	436	165	27	4	(11)
	CDH74	32446	37	80	264	745	2400	6173	7970	8356	4727	1471	188	35	(12)
	CDH80	16346	4	12	42	186	877	3172	4458	4771	2279	504	37	4	(13)
(14) Wind	WSAvg	9.1	9.2	9.9	10.8	11.0	9.9	9.1	8.0	7.8	7.6	8.5	8.9	8.8	(14)
(15) Precipitation	PrecAvg	37.8	2.5	2.7	3.7	3.2	4.1	3.7	2.1	2.6	3.3	3.9	3.1	2.8	(15)
	PrecMax	55.0	4.7	7.3	7.6	7.0	9.5	13.0	4.8	6.5	11.4	10.3	8.7	10.1	(16)
	PrecMin	19.4	0.4	0.0	1.1	0.5	1.4	0.9	0.0	0.0	0.3	0.2	0.4	0.3	(17)
	PrecStd	8.9	1.2	1.9	1.7	1.9	2.2	3.1	1.3	1.7	2.9	2.7	2.2	2.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	81.5	84.0	90.2	93.5	100.2	104.2	105.5	99.5	92.8	84.1	78.9	(19)
		MCWB	58.1	61.2	63.2	68.2	73.9	73.7	73.1	73.4	71.7	70.2	67.5	62.7	(20)
	2%	DB	72.8	75.4	80.9	84.1	90.8	98.7	100.3	101.7	96.8	89.6	79.3	72.6	(21)
		MCWB	57.9	61.5	64.6	67.9	73.8	73.7	73.5	73.2	72.4	71.6	65.1	60.8	(22)
	5%	DB	68.0	72.2	76.9	81.5	88.3	95.4	99.1	99.5	93.2	85.6	74.8	68.1	(23)
		MCWB	58.2	60.4	63.5	68.1	73.1	74.5	74.0	74.5	72.7	70.5	63.3	60.2	(24)
	10%	DB	63.5	68.0	72.8	78.8	84.4	92.9	96.8	97.3	90.8	81.9	71.9	63.8	(25)
		MCWB	54.2	59.8	62.4	66.9	72.0	74.3	74.4	74.4	72.8	67.5	63.3	56.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	69.2	71.4	75.0	79.1	80.3	80.2	79.6	78.9	76.5	72.6	69.0	(27)
		MCDB	69.8	74.1	77.8	81.5	85.9	89.4	89.3	88.8	86.7	83.8	77.5	72.4	(28)
	2%	WB	64.1	66.8	69.0	73.1	77.4	78.7	78.7	78.3	77.7	75.0	69.8	65.9	(29)
		MCDB	67.6	71.2	74.2	79.7	84.8	87.8	88.3	88.5	86.2	82.2	73.1	69.7	(30)
	5%	WB	60.5	64.2	67.4	71.6	75.9	77.7	77.9	77.6	76.6	73.7	67.5	62.7	(31)
		MCDB	65.1	67.5	73.3	77.4	83.2	87.1	87.8	88.4	85.0	80.2	72.4	64.8	(32)
	10%	WB	55.2	61.2	65.6	70.0	74.5	76.8	77.1	76.9	75.7	72.2	65.2	58.7	(33)
		MCDB	62.1	66.2	70.4	75.3	81.5	86.3	87.2	87.9	83.8	78.5	69.5	63.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.8	20.2	20.6	20.7	18.9	19.9	20.7	20.8	20.6	21.8	20.6	20.1	(35)
		MCDBR	27.6	25.5	23.5	22.7	21.8	23.0	23.7	23.4	23.0	22.9	24.0	26.0	(36)
		MCWBR	16.1	15.2	12.2	12.0	8.2	5.7	5.4	5.3	7.0	9.3	12.8	16.2	(37)
	5% WB	MCDBR	22.3	21.6	18.5	17.9	17.5	18.0	19.4	19.8	18.4	18.3	18.7	20.4	(38)
		MCWBR	17.0	15.9	12.1	11.8	9.2	6.3	6.1	5.6	6.5	9.1	13.9	17.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.310	0.324	0.351	0.390	0.419	0.428	0.433	0.430	0.397	0.358	0.335	0.316	(40)
	taud		2.509	2.477	2.419	2.334	2.313	2.324	2.347	2.337	2.377	2.471	2.474	2.495	(41)
	Ebn at Noon		290	296	294	285	277	273	271	271	276	280	278	281	(42)
	Edh at Noon		27	31	35	40	42	41	40	40	36	31	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		940	1102	1443	1740	1869	2106	2148	1965	1651	1303	989	827	(44)
	RadStd		94	177	113	147	180	192	148	126	134	194	125	109	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page