

SANDPOINT, ID, USA

WMO: 720322

Lat: 48.299N

Lon: 116.560W

Elev: 648

StdP: 93.78

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 04129

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-14.0	-11.3	-20.3	0.7	-12.8	-17.0	0.9	-9.8	11.6	-9.2	9.9	-8.0	2.7	30	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	32.1	17.0	30.1	16.7	27.8	15.8	18.5	28.0	17.6	26.8	16.7	26.0	2.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	12.2	20.7	14.0	10.8	19.9	12.7	9.9	19.2	54.7	28.2	51.7	26.7	49.2	26.5	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.3	5.8	DB	-19.3	34.5	3.0	1.8	-21.5	35.8	-23.2	36.9	-24.9	37.9	-27.1	39.2	(4)
(5)			WB	-19.7	21.3	2.9	2.2	-21.7	22.9	-23.4	24.2	-25.1	25.4	-27.2	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-1.6	-0.6	3.0	6.8	12.0	14.7	18.9	18.4	13.4	7.1	2.2	-2.0	(6)	
	DBStd	8.13	4.22	3.95	3.20	3.23	3.54	3.46	2.90	2.72	3.26	3.33	4.00	4.20	(7)	
	HDD10.0	1720	358	298	216	108	21	3	0	0	6	102	237	372	(8)	
	HDD18.3	3957	617	531	474	347	197	117	28	33	149	348	486	630	(9)	
	CDD10.0	895	0	0	0	11	83	145	275	259	109	11	1	0	(10)	
	CDD18.3	92	0	0	0	0	1	9	45	34	3	0	0	0	(11)	
	CDH23.3	2135	0	0	0	3	68	204	929	784	145	1	1	0	(12)	
	CDH26.7	702	0	0	0	0	6	54	337	272	33	0	0	0	(13)	
(14) Wind	WSAvg	2.0	2.1	2.3	1.9	2.2	2.3	2.0	1.8	1.7	1.7	1.7	2.0	2.1	(14)	
(15) Precipitation	PrecAvg	854	110	83	73	55	67	60	33	34	42	65	123	122	(15)	
	PrecMax	1124	259	198	170	125	173	157	168	113	94	139	274	230	(16)	
	PrecMin	582	8	4	3	8	18	10	0	0	1	0	28	17	(17)	
	PrecStd	121	54	49	36	25	31	31	32	31	27	40	57	53	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	9.8	15.9	22.9	27.5	31.3	33.9	33.7	30.2	21.3	15.9	8.6	(19)	
		MCWB	5.1	5.8	8.2	11.7	14.0	17.5	17.9	17.0	16.3	13.5	13.5	6.6	(20)	
	2%	DB	5.3	7.4	12.5	19.9	25.3	27.7	32.3	32.0	27.3	17.7	11.3	5.9	(21)	
		MCWB	3.5	4.2	6.9	10.7	13.9	16.1	17.2	16.6	15.2	11.1	9.0	4.3	(22)	
	5%	DB	3.9	6.1	10.2	17.0	22.7	26.0	30.3	30.0	24.8	15.2	9.7	3.8	(23)	
		MCWB	2.4	3.6	6.0	9.0	12.9	14.9	16.7	16.6	14.3	9.8	7.6	2.5	(24)	
	10%	DB	2.6	4.7	8.0	13.7	20.9	22.9	28.0	27.6	22.3	12.8	7.6	2.6	(25)	
		MCWB	1.5	2.7	4.7	7.3	12.1	13.9	16.0	15.7	13.3	8.7	6.0	1.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	6.8	9.6	12.9	15.7	19.0	20.6	19.1	17.8	14.4	13.8	7.1	(27)	
		MCDB	6.6	7.8	13.1	21.0	23.9	29.2	30.1	28.4	25.0	19.5	16.4	8.0	(28)	
	2%	WB	4.0	5.2	7.8	11.0	14.5	17.3	18.9	18.1	16.2	12.4	9.5	4.2	(29)	
		MCDB	5.5	6.5	10.8	18.5	23.3	26.3	28.2	27.6	24.4	15.7	10.9	5.6	(30)	
	5%	WB	2.8	3.9	6.5	9.6	13.4	16.0	17.8	17.3	15.1	11.1	7.7	2.9	(31)	
		MCDB	3.8	5.7	9.3	15.7	21.6	23.7	27.3	26.6	23.1	13.8	8.6	3.6	(32)	
	10%	WB	2.0	2.8	5.3	8.1	12.4	14.9	16.9	16.5	13.9	9.8	6.6	2.0	(33)	
		MCDB	2.7	4.2	7.9	12.9	19.2	21.8	26.3	26.3	21.3	13.1	7.8	2.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	7.0	8.7	10.8	13.3	13.0	17.3	17.3	15.3	10.8	6.6	4.9	(35)	
		MCDBR	5.5	8.8	12.9	16.8	18.3	18.3	20.4	21.1	20.3	14.5	10.2	5.7	(36)	
	5% WB	MCWBR	4.3	5.9	7.8	8.6	8.3	8.2	8.5	8.8	9.5	8.8	7.9	4.8	(37)	
		MCWBR	5.3	7.3	11.0	15.6	16.9	16.0	18.1	18.7	18.3	12.4	9.4	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.269	0.273	0.293	0.347	0.361	0.356	0.355	0.367	0.340	0.305	0.286	0.266	(40)	
		taud	2.399	2.401	2.441	2.364	2.392	2.440	2.450	2.421	2.478	2.574	2.539	2.447	(41)	
	Edn at Noon	Edn at Noon	815	897	932	903	900	905	901	874	868	854	797	776	(42)	
		Edh at Noon	65	82	93	112	114	109	107	105	90	70	58	56	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.95	1.89	2.88	4.37	5.64	5.96	7.18	5.97	4.23	2.45	1.13	0.76	(44)	
	RadStd	RadStd	0.14	0.26	0.37	0.42	0.45	0.56	0.48	0.42	0.43	0.30	0.14	0.11	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page