

CORONA, CA, USA

WMO: 720333

Lat: 33.898N

Lon: 117.602W

Elev: 533

StdP: 14.42

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 53175

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	30.1	33.8	1.3	6.0	63.4	7.0	8.0	65.4	27.7	59.6	24.2	62.6	0.3	60	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	31.0	99.1	69.5	95.8	68.7	92.8	68.0	73.7	93.0	72.4	90.8	71.1	88.7	11.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	101.6	83.4	65.4	95.8	80.9	64.2	91.7	78.9	37.4	93.3	36.2	90.6	35.0	88.9	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.0	16.9	15.6	DB	24.4	106.0	3.2	2.7	22.1	108.0	20.2	109.5	18.4	111.0	16.1	113.0
			WB	23.1	76.4	3.3	1.3	20.7	77.3	18.8	78.1	16.9	78.9	14.5	79.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.5	55.1	54.4	58.1	60.9	63.7	69.3	74.6	75.1	72.6	65.2	59.1	52.8
	DBStd	9.37	6.89	6.39	5.08	5.13	4.72	4.48	4.19	4.57	5.75	5.67	5.78	5.78
	HDD50	90	21	25	2	1	0	0	0	0	0	0	3	38
	HDD65	1720	320	303	221	142	81	9	0	0	5	64	193	382
	CDD50	5000	180	148	253	328	424	578	763	779	677	471	276	123
	CDD65	1156	13	6	6	19	41	138	298	315	232	70	16	2
	CDH74	17704	210	254	485	805	933	1909	3488	3995	3251	1613	629	132
	CDH80	8299	35	56	139	316	384	811	1720	2116	1722	755	226	19
(14) Wind	WSAvg	5.2	5.1	4.4	5.0	5.8	6.2	6.1	6.2	6.2	5.1	4.6	4.1	4.2
(15) Precipitation	PrecAvg	11.5	2.3	2.5	1.4	1.0	0.2	0.0	0.1	0.0	0.2	0.5	1.2	1.9
	PrecMax	24.4	8.4	8.4	3.4	2.9	0.9	0.1	0.9	0.2	0.5	5.5	2.2	8.5
	PrecMin	4.4	0.4	0.2	0.3	0.3	0.0	0.0	0.0	0.0	0.1	0.0	0.4	0.2
	PrecStd	5.4	2.2	2.1	0.8	0.6	0.2	0.0	0.2	0.0	0.1	1.2	0.5	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.7	85.7	89.9	94.4	96.9	100.1	100.0	101.9	104.0	99.0	91.7	82.4
		MCWB	54.2	57.2	59.1	59.4	63.0	69.2	72.7	70.7	70.8	63.4	59.9	54.5
	2%	DB	80.5	81.4	83.8	88.4	89.7	92.7	95.3	97.5	98.7	93.2	86.8	78.1
		MCWB	54.1	55.8	58.8	59.7	62.0	69.8	71.0	70.5	70.3	60.9	58.9	54.1
	5%	DB	75.3	76.7	79.8	82.6	83.5	88.3	92.1	94.3	94.1	88.7	81.4	73.1
		MCWB	53.2	56.1	57.3	58.7	63.1	67.7	70.3	70.4	69.4	61.4	56.8	52.1
	10%	DB	72.1	71.8	74.9	78.3	78.9	84.1	89.6	90.9	90.4	83.0	76.3	67.9
		MCWB	52.2	53.8	56.4	58.5	62.1	66.8	70.1	70.2	68.4	60.2	54.2	51.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.5	62.1	64.0	66.0	68.3	72.9	75.3	75.6	75.3	69.1	63.1	61.4
		MCDB	72.3	73.9	81.4	82.8	87.6	92.9	94.7	95.2	97.5	88.3	80.0	67.0
	2%	WB	58.2	59.3	61.7	63.5	66.1	70.3	73.3	73.4	73.1	66.4	61.4	58.9
		MCDB	66.7	72.0	77.8	79.9	83.1	89.6	91.7	92.1	93.8	82.3	77.5	67.2
	5%	WB	56.3	57.6	59.9	61.2	64.3	68.8	72.0	72.1	71.3	64.8	59.9	57.1
		MCDB	66.8	71.3	74.3	77.6	79.7	86.5	89.1	90.2	90.3	79.7	74.6	64.4
	10%	WB	54.6	55.9	58.1	59.5	62.4	67.3	70.6	70.8	69.5	63.3	58.5	54.9
		MCDB	66.2	68.0	70.5	74.7	76.3	83.3	86.9	88.3	86.6	76.7	71.3	62.9
(35) Mean Daily Temperature Range	5% DB	MDBR	27.5	28.1	29.6	30.2	26.8	28.4	28.6	31.0	32.5	32.6	32.1	28.2
		MCDBR	34.3	39.8	40.2	42.4	38.5	36.4	32.8	35.7	38.9	43.8	42.1	40.4
		MCWBR	16.1	19.1	18.2	18.4	16.4	15.8	13.3	14.4	15.7	18.1	19.2	19.7
	5% WB	MCDBR	28.8	33.3	33.6	33.4	31.3	32.6	29.3	30.5	33.7	33.9	34.4	26.1
		MCWBR	15.9	17.6	17.2	16.5	14.7	14.5	12.2	12.8	14.3	16.6	17.7	15.4
(40) Clear-Sky Solar Irradiance	taub		0.311	0.319	0.342	0.355	0.356	0.367	0.381	0.365	0.350	0.344	0.306	0.305
	taud		2.544	2.534	2.445	2.416	2.445	2.422	2.449	2.480	2.510	2.499	2.597	2.595
	Ebn at Noon		288	297	296	296	294	290	285	289	290	283	288	284
	Edh at Noon		26	29	34	37	36	37	36	34	32	30	24	23
(44) All-Sky Solar Radiation	RadAvg		1022	1304	1751	2127	2313	2478	2413	2287	1942	1476	1136	926
	RadStd		70	129	88	100	132	134	115	57	62	94	59	66

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	+1.13	N/A	-3.06	+1.30	N/A	N/A	N/A	-202	+401	+202

Nomenclature: See separate page