

CORONA, CA, USA

WMO: 720333

Lat: 33.898N

Lon: 117.602W

Elev: 163

StdP: 99.39

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 53175

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.1	1.0	-17.1	0.9	17.5	-13.9	1.1	18.5	12.4	15.3	10.8	17.0	0.2	60	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.2	37.3	20.8	35.4	20.4	33.8	20.0	23.1	33.9	22.4	32.7	21.7	31.5	5.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.5	28.6	18.6	13.7	27.2	17.9	13.1	26.0	69.2	34.1	66.3	32.6	63.6	31.6	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.5	7.0	-4.2	41.1	1.8	1.5	-5.5	42.2	-6.6	43.1	-7.6	43.9	-8.9	45.0		
			-4.9	24.7	1.9	0.7	-6.3	25.2	-7.3	25.6	-8.4	26.0	-9.7	26.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	12.8	12.4	14.5	16.1	17.6	20.7	23.7	24.0	22.5	18.4	15.1	11.5	(6)
(7)		DBStd	5.21	3.83	3.55	2.82	2.85	2.62	2.49	2.33	2.54	3.19	3.15	3.21	3.21	(7)
(8)		HDD10.0	50	12	14	1	1	0	0	0	0	0	0	2	21	(8)
(9)		HDD18.3	956	178	168	123	79	45	5	0	0	3	36	107	212	(9)
(10)		CDD10.0	2778	100	82	141	182	236	321	424	433	376	262	153	68	(10)
(11)		CDD18.3	642	7	3	3	11	23	77	166	175	129	39	9	1	(11)
(12)		CDH23.3	9836	117	141	269	447	518	1061	1938	2219	1806	896	349	73	(12)
(13)		CDH26.7	4611	19	31	77	176	213	451	956	1176	957	419	126	11	(13)
(14)	Wind	WSAvg	2.3	2.3	2.0	2.2	2.6	2.8	2.7	2.8	2.3	2.1	1.8	1.9	(14)	
(15)	Precipitation	PrecAvg	292	58	64	35	26	6	1	3	5	13	30	48	(15)	
(16)		PrecMax	621	214	214	86	74	22	2	22	5	13	140	56	216	(16)
(17)		PrecMin	112	10	5	8	7	1	0	0	0	2	0	10	4	(17)
(18)		PrecStd	137	57	54	21	15	5	0	5	1	3	31	13	49	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	29.8	32.1	34.7	36.1	37.9	37.8	38.8	40.0	37.2	33.2	28.0	(19)
(20)		0.4%	MCWB	12.4	14.0	15.0	15.2	17.2	20.7	22.6	21.5	21.5	17.4	15.5	12.5	(20)
(21)		2%	DB	27.0	27.4	28.8	31.3	32.0	33.7	35.1	36.4	37.0	34.0	30.5	25.6	(21)
(22)		2%	MCWB	12.3	13.2	14.9	15.4	16.7	21.0	21.7	21.4	21.3	16.1	15.0	12.3	(22)
(23)		5%	DB	24.1	24.9	26.5	28.1	28.6	31.3	33.4	34.6	34.5	31.5	27.4	22.8	(23)
(24)		5%	MCWB	11.8	13.4	14.1	14.8	17.3	19.8	21.3	21.3	20.8	16.3	13.8	11.2	(24)
(25)		10%	DB	22.3	22.1	23.8	25.7	26.0	28.9	32.0	32.7	32.4	28.3	24.6	20.0	(25)
(26)		10%	MCWB	11.2	12.1	13.6	14.7	16.7	19.4	21.2	21.2	20.2	15.6	12.4	10.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.9	16.7	17.8	18.9	20.2	22.7	24.1	24.2	24.1	20.6	17.3	16.3	(27)
(28)		0.4%	MCDWB	22.4	23.3	27.5	28.2	30.9	33.8	34.8	35.1	36.4	31.3	26.7	19.5	(28)
(29)		2%	WB	14.6	15.2	16.5	17.5	18.9	21.3	23.0	23.0	22.8	19.1	16.3	15.0	(29)
(30)		2%	MCDWB	19.3	22.2	25.4	26.6	28.4	32.0	33.1	33.4	34.3	28.0	25.3	19.5	(30)
(31)		5%	WB	13.5	14.2	15.5	16.2	17.9	20.4	22.2	22.3	21.8	18.2	15.5	13.9	(31)
(32)		5%	MCDWB	19.3	21.9	23.5	25.4	26.5	30.3	31.7	32.3	32.4	26.5	23.7	18.0	(32)
(33)		10%	WB	12.6	13.3	14.5	15.3	16.9	19.6	21.5	21.6	20.8	17.4	14.7	12.7	(33)
(34)		10%	MCDWB	19.0	20.0	21.4	23.7	24.6	28.5	30.5	31.3	30.4	24.8	21.8	17.2	(34)
(35)	Mean Daily Temperature Range	MDBR	15.3	15.6	16.4	16.8	14.9	15.8	15.9	17.2	18.0	18.1	17.9	15.7	(35)	
(36)		5% DB	MCDBR	19.1	22.1	22.3	23.5	21.4	20.2	18.2	19.8	21.6	24.4	23.4	22.4	(36)
(37)		5% DB	MCWBR	9.0	10.6	10.1	10.2	9.1	8.8	7.4	8.0	8.7	10.1	10.7	11.0	(37)
(38)		5% WB	MCDBR	16.0	18.5	18.7	18.6	17.4	18.1	16.3	17.0	18.7	18.8	19.1	14.5	(38)
(39)		5% WB	MCWBR	8.9	9.8	9.6	9.1	8.2	8.0	6.8	7.1	8.0	9.2	9.9	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.319	0.342	0.355	0.356	0.367	0.381	0.365	0.350	0.344	0.306	0.305	(40)	
(41)		taud	2.544	2.534	2.445	2.416	2.445	2.422	2.449	2.480	2.510	2.499	2.597	2.595	(41)	
(42)		Ebn at Noon	907	935	933	932	928	913	898	910	914	893	907	895	(42)	
(43)		Edh at Noon	81	91	108	116	114	116	113	108	100	93	76	73	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.22	4.11	5.52	6.70	7.29	7.81	7.61	7.21	6.12	4.65	3.58	2.92	(44)	
(45)		RadStd	0.22	0.41	0.28	0.32	0.42	0.42	0.36	0.18	0.20	0.30	0.18	0.21	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.63	N/A	-1.70	+0.72	N/A	N/A	-112	+223	+112

Nomenclature: See separate page