

ALLEN PARISH, LA, USA

WMO: 720346

Lat: 30.750N

Lon: 92.688W

Elev: 107

StdP: 14.64

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53991

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.6	29.5	17.2	13.1	37.2	22.4	16.9	39.2	16.7	53.1	15.5	52.3	1.8	0	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	96.7	77.3	94.5	77.5	92.5	77.6	81.8	87.4	81.0	87.3	80.2	87.2	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.1	162.3	83.4	79.3	152.7	83.2	78.6	149.2	83.1	45.6	88.1	44.5	85.9	43.6	88.7	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.3	12.5	10.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			19.9	83.0	5.0	1.2	16.4	83.8	13.5	84.5	10.7	85.2	7.1	86.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	49.1	54.2	60.3	66.6	73.0	79.7	81.2	81.8	77.3	67.4	57.4	53.1
	DBStd	13.50	9.86	9.96	8.96	7.05	5.83	2.99	2.71	3.12	4.36	7.90	9.22	9.80
	HDD50	330	137	62	19	2	0	0	0	0	0	1	32	77
	HDD65	1823	500	326	198	64	11	0	0	0	0	68	263	393
	CDD50	6469	110	179	339	499	714	891	966	986	819	541	252	173
	CDD65	2491	8	24	53	112	261	441	501	521	369	143	34	24
	CDH74	24197	20	83	356	1016	2570	4524	5061	5311	3419	1517	222	98
	CDH80	10650	0	2	38	203	953	2198	2443	2696	1563	529	22	3
Wind	WSAvg	3.2	4.0	4.6	4.4	4.2	3.1	2.3	1.8	1.9	2.2	2.6	3.2	3.6
Precipitation	PrecAvg	63.0	6.4	4.8	4.6	4.9	4.9	5.0	4.9	3.9	4.7	5.1	5.6	5.9
	PrecMax	81.8	13.6	11.7	9.1	14.1	14.6	12.4	10.2	6.3	12.3	15.4	11.6	9.5
	PrecMin	45.4	1.2	0.4	1.5	1.2	0.0	1.0	1.7	0.6	1.9	0.0	0.9	3.5
	PrecStd	10.2	3.4	2.6	2.2	3.0	3.5	3.1	2.0	1.5	2.6	4.3	3.0	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.5	79.7	83.4	87.9	92.7	98.8	97.4	99.9	95.4	90.8	82.4	80.5
		MCWB	66.6	69.5	68.1	72.8	73.8	73.4	77.1	77.8	75.2	72.6	72.2	71.8
	2%	DB	73.1	76.7	81.0	84.3	90.3	94.9	95.0	97.2	92.9	88.3	79.5	76.9
		MCWB	66.6	67.0	68.5	71.8	74.0	77.0	78.1	78.6	76.0	74.0	70.1	70.3
	5%	DB	70.5	73.5	78.6	82.1	88.1	92.5	93.0	94.7	90.7	86.0	76.8	73.6
		MCWB	65.6	66.9	67.7	70.1	73.9	77.7	78.3	78.2	76.3	72.6	68.6	69.2
	10%	DB	67.8	71.5	75.2	80.5	85.8	90.5	91.0	91.6	88.8	82.5	73.3	71.0
		MCWB	63.1	67.1	66.3	69.1	73.8	77.3	78.5	78.4	75.9	70.7	68.3	67.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.1	72.2	73.5	76.6	79.3	83.1	83.6	83.1	82.1	78.8	75.2	74.7
		MCDB	73.0	75.6	77.1	81.6	84.1	87.4	86.7	88.4	86.1	84.1	78.8	76.6
	2%	WB	69.7	70.5	72.0	74.8	77.5	80.9	81.6	81.7	80.3	77.4	73.2	72.0
		MCDB	71.4	74.0	76.5	80.0	84.1	87.1	86.7	88.4	85.5	83.8	76.2	75.9
	5%	WB	67.3	69.3	70.3	73.4	76.3	79.8	80.8	81.0	78.8	75.9	71.6	70.2
		MCDB	69.9	72.8	75.1	78.6	83.3	87.2	86.9	88.2	85.3	82.9	75.5	73.5
	10%	WB	63.5	67.0	68.8	72.2	75.2	78.9	79.9	80.1	77.7	73.6	69.0	68.1
		MCDB	66.3	70.4	73.5	77.5	82.4	86.5	87.1	87.9	84.8	79.2	72.9	70.7
Mean Daily Temperature Range	5% DB	MDBR	22.9	22.3	23.9	23.5	23.1	21.3	19.8	20.9	22.2	27.0	24.6	21.0
		MCDBR	24.1	22.5	22.9	23.7	24.3	24.8	22.4	24.7	24.0	26.7	25.1	21.8
		MCWBR	17.7	14.5	13.2	12.6	11.5	10.7	9.2	9.3	10.6	13.3	16.3	15.7
	5% WB	MCDBR	19.6	17.4	19.0	19.5	21.1	21.1	20.1	21.1	20.7	21.2	19.9	19.1
		MCWBR	17.0	13.6	12.6	12.0	10.8	10.5	9.8	9.5	10.4	12.2	14.5	15.0
Clear-Sky Solar Irradiance	taub	0.332	0.353	0.376	0.419	0.448	0.484	0.501	0.494	0.451	0.374	0.356	0.348	
	taud	2.520	2.463	2.394	2.278	2.233	2.171	2.160	2.178	2.268	2.458	2.458	2.471	
	Ebn at Noon	285	288	288	278	269	258	253	254	261	277	273	272	
	Edh at Noon	28	32	37	43	45	48	48	47	41	32	29	28	
All-Sky Solar Radiation	RadAvg	892	1018	1410	1725	1907	1887	1861	1761	1582	1369	1030	790	
	RadStd	85	169	120	131	127	161	147	167	144	178	101	88	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+218	+148

Nomenclature: See separate page