

GREENVILLE, AL, USA

WMO: 720362

Lat: 31.846N

Lon: 86.611W

Elev: 138

StdP: 99.68

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 63874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	-1.9	-13.5	1.2	1.0	-11.0	1.5	2.6	8.5	8.1	7.9	9.3	2.3	350	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	35.3	23.9	34.4	23.9	33.5	23.8	25.8	31.9	25.5	31.4	25.1	30.7	2.6	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	19.5	28.0	23.9	19.0	27.7	23.5	18.6	27.5	80.4	32.2	78.5	31.3	76.8	30.7	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.3	5.4	DB	-7.0	36.4	2.2	1.1	-8.6	37.2	-9.9	37.8	-11.1	38.5	-12.7	39.3	(4)
(5)			WB	-7.7	26.8	2.4	0.4	-9.4	27.1	-10.8	27.3	-12.2	27.6	-13.9	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	9.1	11.7	15.2	18.6	22.8	26.6	27.5	27.3	25.2	19.6	13.1	11.1	(6)	
	DBStd	7.67	5.97	5.63	4.75	3.50	2.98	1.83	1.60	1.72	2.67	4.43	4.36	5.05	(7)	
	HDD10.0	218	91	45	12	1	0	0	0	0	1	18	51		(8)	
	HDD18.3	1078	290	195	117	39	5	0	0	0	1	39	164	228	(9)	
	CDD10.0	3512	62	92	174	258	397	498	542	536	457	299	111	85	(10)	
	CDD18.3	1331	4	9	22	46	144	248	283	277	207	80	7	4	(11)	
	CDH23.3	12475	23	39	168	448	1354	2477	2780	2598	1832	682	62	12	(12)	
(13)	CDH26.7	5390	6	3	22	88	518	1189	1316	1211	809	218	10	0	(13)	
(14)	Wind	WSAvg	2.2	2.6	2.7	2.8	2.4	2.0	1.8	1.7	1.6	1.7	2.1	2.2	2.5	(14)
(15) Precipitation	PrecAvg	1380	136	111	149	107	82	123	140	108	109	92	124	106	(15)	
	PrecMax	1813	239	199	389	241	206	268	389	205	460	298	317	191	(16)	
	PrecMin	1005	42	36	11	31	0	39	35	39	14	6	33	48	(17)	
	PrecStd	193	52	52	86	53	51	67	83	46	99	75	72	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	27.1	28.8	30.2	34.2	36.3	36.3	36.4	35.4	32.9	28.1	24.9	(19)	
		MCWB	18.7	19.4	18.1	19.0	21.8	23.5	24.8	23.4	23.1	22.3	18.0	18.6	(20)	
	2%	DB	22.9	24.4	27.1	28.8	32.4	34.9	34.9	34.9	34.0	31.0	24.9	22.8	(21)	
		MCWB	17.1	17.5	18.0	19.0	21.6	23.6	24.4	24.3	23.2	21.0	17.4	18.0	(22)	
	5%	DB	20.6	22.3	25.3	27.7	31.0	33.9	33.9	33.8	32.8	29.1	23.2	21.3	(23)	
		MCWB	16.7	17.2	17.5	18.4	21.0	23.5	24.5	24.3	23.1	20.6	17.0	17.7	(24)	
	10%	DB	18.6	20.5	23.4	26.2	29.7	32.7	32.7	32.6	31.3	27.3	21.4	19.6	(25)	
		MCWB	15.2	16.0	16.2	18.0	20.7	23.4	24.4	24.3	23.0	20.0	15.6	16.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	20.2	20.7	22.4	23.9	25.8	26.4	26.6	25.5	24.5	21.5	21.1	(27)	
		MCDB	24.2	24.1	24.3	26.7	29.3	32.1	32.8	32.6	30.6	28.2	23.4	23.0	(28)	
	2%	WB	19.1	19.4	19.7	21.4	23.2	25.3	25.8	25.9	24.9	23.5	19.9	19.6	(29)	
		MCDB	21.5	23.0	23.4	25.3	28.9	31.8	32.0	31.9	30.1	27.2	23.4	21.5	(30)	
	5%	WB	17.7	18.4	18.8	20.5	22.7	24.8	25.5	25.5	24.5	22.7	18.5	18.6	(31)	
		MCDB	19.8	21.7	23.1	24.2	28.3	30.9	31.5	31.2	29.6	26.7	21.3	20.4	(32)	
	10%	WB	16.0	17.0	17.9	19.5	22.0	24.2	25.0	25.0	24.0	21.6	17.1	17.2	(33)	
		MCDB	18.4	19.8	22.1	23.2	27.3	30.0	30.7	30.3	28.9	25.7	20.2	19.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	11.7	12.7	12.8	12.3	11.3	10.5	10.5	11.3	12.7	13.5	11.1	(35)	
		MCDBR	12.7	11.8	13.5	14.4	14.2	13.1	11.9	12.1	12.8	13.9	14.6	11.7	(36)	
	5% WB	MCWBR	8.2	6.6	6.1	6.3	5.5	4.1	3.8	4.2	4.6	5.9	8.6	8.4	(37)	
		MCWBR	9.9	10.5	10.7	10.2	11.1	11.2	10.5	10.3	10.3	10.5	11.6	10.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.321	0.331	0.356	0.382	0.430	0.466	0.528	0.510	0.431	0.369	0.343	0.323	(40)	
		taud	2.535	2.512	2.440	2.364	2.268	2.222	2.055	2.106	2.306	2.456	2.475	2.540	(41)	
	Ebn at Noon		906	929	925	909	863	827	775	784	838	874	870	884	(42)	
		Edh at Noon	85	95	110	123	137	143	168	158	124	99	89	80	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.86	3.43	4.62	5.71	6.26	6.13	5.94	5.53	4.96	4.26	3.24	2.47	(44)	
	RadStd		0.20	0.43	0.41	0.46	0.42	0.49	0.38	0.33	0.39	0.51	0.30	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+159	+105

Nomenclature: See separate page