

SLAYTON, MN, USA

WMO: 720368

Lat: 43.987N

Lon: 95.783W

Elev: 495

StdP: 95.52

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 54924

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.6	-21.8	-27.5	0.3	-23.0	-25.8	0.4	-21.5	14.6	-7.7	13.4	-9.7	4.4	330	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	31.6	21.7	30.1	21.2	28.5	20.2	24.3	28.8	23.2	27.5	22.1	26.3	6.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	18.8	27.0	21.9	17.6	25.9	20.8	16.4	25.0	76.2	29.0	71.7	27.6	67.3	26.3	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.6	10.5	DB	-26.8	34.0	2.4	1.4	-28.6	35.0	-30.0	35.8	-31.4	36.6	-33.2	37.7	(4)
(5)			WB	-27.1	25.7	2.4	1.2	-28.8	26.5	-30.2	27.2	-31.5	27.9	-33.3	28.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-9.0	-7.9	-0.1	6.7	14.0	19.7	21.9	20.3	16.1	8.9	1.2	-6.8	(6)	
	DBStd	12.29	7.19	6.70	7.08	5.81	5.10	3.52	3.15	3.01	4.55	5.35	6.25	6.59	(7)	
	HDD10.0	2438	589	501	319	128	19	0	0	0	5	86	269	522	(8)	
	HDD18.3	4388	848	734	571	349	153	26	7	14	95	297	514	781	(9)	
	CDD10.0	1402	0	0	7	29	143	291	369	319	189	51	5	0	(10)	
	CDD18.3	309	0	0	0	1	19	66	117	74	29	4	0	0	(11)	
	CDH23.3	2795	0	0	2	18	229	601	1052	576	276	42	0	0	(12)	
	CDH26.7	794	0	0	0	2	74	176	325	141	69	7	0	0	(13)	
(14) Wind	WSAvg	4.6	5.5	5.3	5.1	5.5	5.1	4.1	3.2	3.0	3.7	4.6	5.2	4.8	(14)	
(15) Precipitation	PrecAvg	743	16	23	39	81	84	120	90	78	91	60	36	25	(15)	
	PrecMax	1169	46	48	94	193	178	302	240	174	271	141	108	54	(16)	
	PrecMin	545	1	5	0	36	19	54	23	7	23	10	0	4	(17)	
	PrecStd	153	13	12	27	37	43	54	49	55	67	41	35	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	12.3	21.8	26.2	32.4	33.3	33.5	32.0	31.3	27.6	20.3	9.8	(19)	
		MCWB	3.4	9.8	12.1	14.9	17.6	21.5	24.0	23.1	20.0	17.2	12.2	6.9	(20)	
	2%	DB	3.8	5.3	16.8	22.2	28.6	30.5	31.8	30.0	28.9	23.9	15.7	5.8	(21)	
		MCWB	1.5	2.9	11.3	12.7	17.1	20.1	23.3	22.4	20.0	15.1	9.9	3.1	(22)	
	5%	DB	2.1	2.9	12.8	19.1	26.0	28.7	30.1	28.0	26.8	20.9	12.8	2.9	(23)	
		MCWB	0.8	1.1	9.5	10.7	16.0	19.0	22.3	21.2	18.6	13.4	7.7	1.4	(24)	
	10%	DB	0.6	1.0	9.7	16.1	22.8	27.0	28.4	26.7	24.5	17.6	9.9	1.3	(25)	
		MCWB	-0.1	-0.1	7.3	9.5	14.8	18.0	21.2	20.3	17.6	11.7	6.3	0.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	9.4	15.6	15.9	20.7	24.3	26.4	25.2	23.8	19.9	14.1	7.6	(27)	
		MCDB	6.5	12.3	19.2	21.8	27.7	29.0	30.8	29.7	27.7	24.8	17.1	9.1	(28)	
	2%	WB	1.8	3.6	12.1	14.0	19.2	22.4	24.7	23.8	21.8	16.6	10.4	3.3	(29)	
		MCDB	3.2	5.4	14.9	19.9	24.8	27.3	29.1	27.9	25.7	21.7	14.6	5.1	(30)	
	5%	WB	0.8	1.3	9.5	12.4	17.6	20.8	23.7	22.7	20.2	14.0	8.4	1.6	(31)	
		MCDB	1.9	2.6	12.7	17.1	23.3	26.0	28.3	26.5	24.6	19.4	12.4	2.9	(32)	
	10%	WB	-0.1	0.0	6.9	10.7	16.2	19.7	22.6	21.5	18.9	12.1	6.3	0.3	(33)	
		MCDB	0.7	0.8	9.8	15.0	21.0	24.9	27.1	25.1	23.0	16.4	9.9	1.1	(34)	
(35) Mean Daily Temperature Range	MDBR		8.8	8.9	8.8	10.7	11.2	10.7	11.1	10.8	12.1	11.0	9.7	8.0	(35)	
	5% DB	MCDBR	8.8	10.4	14.2	16.3	15.3	13.6	12.1	12.2	14.1	15.5	13.6	9.3	(36)	
		MCWBR	7.2	8.1	9.0	8.5	6.8	6.0	5.8	6.0	6.4	8.1	8.1	7.4	(37)	
	5% WB	MCDBR	8.7	9.6	13.0	13.7	12.2	11.4	11.1	10.8	12.0	13.1	12.2	8.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.259	0.274	0.306	0.361	0.379	0.394	0.404	0.405	0.360	0.319	0.284	0.265	(40)	
	taud		2.455	2.431	2.442	2.323	2.342	2.359	2.319	2.287	2.390	2.492	2.515	2.457	(41)	
	Ebn at Noon		887	930	937	902	892	876	863	848	864	863	848	841	(42)	
	Edh at Noon		70	86	98	121	122	121	124	124	103	81	67	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.88	2.94	3.84	4.77	5.51	6.15	6.61	5.45	4.32	2.88	1.94	1.45	(44)	
	RadStd		0.19	0.29	0.35	0.45	0.40	0.42	0.24	0.42	0.31	0.36	0.15	0.14	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page