

DRIGGS-REED, ID, USA

WMO: 720369

Lat: 43.743N

Lon: 111.098W

Elev: 6229

StdP: 11.68

Time Zone: -7.00 (NAM)

Period: 06-19

WBAN: 04135

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -5.7	(d) -16.3	(e) 2.9	(f) -9.8	(g) -10.8	(h) 3.9	(i) -5.2	(j) 26.5	(k) 31.8	(l) 22.0	(m) 29.5	(n) 2.9	(o) 110	(p) 0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	87.1	57.3	84.7	56.8	82.1	56.3	60.6	78.6	59.3	77.6	58.0	76.5	10.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.3	82.3	63.8	52.9	75.3	64.2	50.7	69.2	63.8	29.6	77.8	28.6	77.5	27.6	76.2	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	18.7	16.6	-23.0	90.9	6.3	1.8	-27.5	92.1	-31.2	93.2	-34.7	94.2	-39.3	95.5
			-23.7	63.9	6.0	2.1	-28.0	65.4	-31.6	66.6	-34.9	67.8	-39.3	69.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.5	17.4	21.6	29.6	37.9	47.7	56.5	65.0	63.4	55.0	41.2	30.1	19.0
	DBStd	18.50	10.74	9.61	9.37	8.36	7.22	7.05	4.73	5.21	7.38	8.42	10.42	10.79
	HDD50	4852	1012	794	633	372	131	23	0	1	37	290	598	961
	HDD65	9067	1477	1214	1097	814	536	263	58	89	307	738	1048	1426
	CDD50	1373	0	0	1	8	60	219	466	416	187	16	0	0
	CDD65	113	0	0	0	0	0	10	59	38	6	0	0	0
	CDH74	3520	0	0	0	1	23	460	1550	1205	269	12	0	0
	CDH80	977	0	0	0	0	0	115	472	347	42	1	0	0
	WSAvg	6.9	5.8	7.3	7.5	8.0	7.4	7.6	7.0	6.6	6.6	6.6	6.7	6.2
(15) Precipitation	PrecAvg	16.3	1.5	1.0	1.1	1.3	2.0	1.9	1.3	1.2	1.5	1.2	1.2	1.3
	PrecMax	24.0	4.4	2.6	3.1	3.4	3.9	5.8	3.1	4.2	4.8	3.2	2.8	4.0
	PrecMin	10.1	0.2	0.2	0.0	0.2	0.7	0.1	0.0	0.0	0.0	0.0	0.2	0.2
	PrecStd	3.8	0.8	0.6	0.7	0.9	0.9	1.5	0.9	0.9	1.2	0.9	0.6	0.8
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.4	44.3	60.0	70.5	77.1	88.0	89.3	89.3	85.0	73.6	60.4	45.9
		MCWB	34.0	35.3	42.9	48.2	51.7	56.9	58.9	56.5	55.5	50.3	44.4	37.2
	2%	DB	37.2	40.0	54.2	64.5	73.3	83.1	87.3	86.6	80.4	66.4	54.0	40.3
		MCWB	32.4	34.0	40.4	45.9	51.1	56.5	58.1	56.4	53.8	47.2	41.5	34.4
	5%	DB	34.8	37.5	47.3	58.7	69.1	79.5	85.2	84.2	77.0	61.9	49.2	37.4
		MCWB	31.5	33.3	37.8	43.4	49.3	55.1	57.8	55.8	52.1	45.7	39.1	32.9
	10%	DB	32.5	35.6	42.9	53.3	64.6	75.5	82.7	81.4	73.6	56.8	44.6	34.4
		MCWB	29.8	32.0	35.9	40.9	48.1	54.3	57.2	55.5	51.4	43.5	36.9	31.2
	0.4%	WB	35.6	36.6	44.2	50.1	54.6	60.9	63.1	61.8	60.3	52.1	46.0	38.0
		MCDB	38.6	40.8	58.2	69.3	70.1	81.5	81.1	78.3	72.5	70.2	56.5	43.3
	2%	WB	33.6	35.1	41.4	46.8	52.2	58.4	61.3	59.7	57.2	49.1	42.8	35.6
		MCDB	36.3	38.9	52.4	61.5	69.7	78.3	79.6	76.7	72.0	63.5	51.6	39.3
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	32.0	33.8	38.7	44.1	50.4	56.5	59.9	58.4	54.9	46.5	40.1	33.3
		MCDB	34.5	36.9	46.2	56.7	67.0	75.4	78.8	76.1	71.2	58.4	48.0	35.9
	10%	WB	30.0	32.5	36.2	41.6	48.6	54.9	58.8	57.0	52.8	44.5	37.5	31.4
		MCDB	32.2	35.6	42.3	51.8	63.1	72.8	77.8	75.5	68.6	55.3	43.3	34.5
		MDBR	20.9	18.9	19.8	21.0	24.4	28.3	32.6	32.2	29.1	23.5	20.1	19.3
		MCDBR	17.0	16.0	23.5	30.4	33.2	37.2	36.3	37.2	36.1	32.1	25.1	16.9
(36) Mean Daily Temperature Range	5% DB	MCWBR	13.5	12.3	13.4	15.5	15.7	16.6	15.1	14.7	15.7	16.7	14.3	11.9
		MCDBR	14.9	13.9	21.6	28.0	29.9	33.4	33.0	31.8	28.8	27.4	22.2	14.7
	5% WB	MCWBR	12.5	11.0	12.3	14.7	14.7	15.7	14.8	13.8	12.8	14.7	13.0	11.3
(40) Clear-Sky Solar Irradiance	taub		0.231	0.242	0.258	0.292	0.301	0.306	0.319	0.325	0.296	0.276	0.250	0.231
	taud		2.359	2.326	2.366	2.408	2.516	2.540	2.524	2.481	2.566	2.586	2.519	2.402
	Ebn at Noon		293	308	315	309	308	305	300	295	298	293	285	283
	Edh at Noon		24	30	33	35	33	32	32	32	27	23	21	21
(44) All-Sky Solar Radiation	RadAvg		542	825	1226	1627	1884	2233	2337	1978	1533	972	586	421
	RadStd		61	100	108	133	196	196	116	113	129	83	63	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page