

WHITING FIELD NAS SOUTH, FL, USA

WMO: 720383

Lat: 30.704N

Lon: 87.023W

Elev: 178

StdP: 14.60

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 53847

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.5	31.8	10.9	9.6	36.9	15.5	12.1	40.6	23.2	52.1	20.6	50.7	6.5	340	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	96.4	77.0	94.5	76.9	92.9	76.6	81.4	89.8	80.3	88.6	79.4	87.7	6.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.4	85.2	78.2	147.3	84.4	77.2	142.7	83.6	45.0	89.9	43.9	88.5	42.9	87.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	17.0	15.3	22.7	99.3	3.4	2.9	20.3	101.4	18.3	103.1	16.4	104.7	13.9	106.8		
(5)			20.2	82.4	3.2	1.5	17.8	83.5	16.0	84.4	14.1	85.3	11.8	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.1	52.3	56.8	62.0	68.0	75.1	81.7	82.8	82.9	79.8	70.5	60.1	56.5		
	DBStd	12.88	10.00	9.28	8.34	6.09	5.00	3.21	2.93	3.19	3.99	7.40	8.33	9.61		
	HDD50	198	92	39	10	0	0	0	0	0	0	0	15	42		
	HDD65	1388	409	255	159	41	5	0	0	0	0	34	189	296		
	CDD50	7170	163	228	382	539	779	951	1016	1019	894	636	319	244		
	CDD65	2886	15	25	66	129	319	501	551	554	444	206	43	33		
	CDH74	28074	37	98	353	1029	2985	5307	5906	5880	4180	1890	303	106		
	CDH80	11704	0	6	48	195	1148	2488	2711	2664	1775	631	36	2		
(14) Wind	WSAvg	6.2	7.4	7.4	7.7	7.1	6.0	4.7	4.1	4.5	5.4	6.4	6.7	7.2		
(15) Precipitation	PrecAvg	64.4	5.4	5.2	5.9	4.1	4.7	7.4	7.8	6.3	5.3	3.3	3.9	4.7		
	PrecMax	86.5	15.7	9.8	13.0	12.6	11.7	27.3	17.8	10.0	19.5	8.8	8.7	9.4		
	PrecMin	36.5	0.8	1.4	0.9	0.4	0.0	1.6	2.0	2.8	0.6	0.0	0.4	1.1		
	PrecStd	12.5	3.1	2.3	2.7	3.1	2.7	4.8	3.8	2.0	3.5	2.4	2.3	2.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.7	80.8	84.2	87.2	94.5	100.2	98.1	98.5	95.9	92.2	83.8	79.5		
		MCWB	67.9	64.7	66.5	67.2	72.4	75.4	78.3	77.9	75.2	73.3	69.8	70.5		
	2%	DB	74.5	77.2	81.1	84.4	91.0	95.9	95.4	96.1	93.5	88.8	80.1	77.0		
		MCWB	67.3	65.8	66.2	67.6	72.2	76.2	77.9	77.8	75.4	72.0	67.2	70.2		
	5%	DB	71.5	73.9	78.2	82.3	88.4	93.5	93.6	93.9	91.4	86.4	77.5	74.4		
		MCWB	65.7	65.4	65.8	67.8	71.9	75.9	78.0	77.9	75.4	71.2	66.7	68.6		
	10%	DB	68.5	71.3	74.9	80.0	86.2	91.2	91.5	91.6	89.2	83.8	74.9	71.9		
		MCWB	62.9	64.4	64.5	67.1	71.3	75.7	77.9	77.5	75.4	69.9	66.0	66.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	71.9	72.6	76.1	78.0	81.3	82.5	82.7	80.4	78.8	75.4	74.8		
		MCDB	74.4	74.8	77.3	81.0	85.3	89.3	91.6	91.3	88.1	84.2	77.8	77.2		
	2%	WB	69.2	70.2	70.5	74.3	76.3	79.9	81.4	81.5	79.0	76.6	73.1	71.7		
		MCDB	72.5	73.4	75.5	78.8	83.6	87.8	90.5	89.5	87.0	83.2	76.3	74.5		
	5%	WB	67.0	68.5	69.2	72.1	75.1	78.7	80.2	80.4	78.0	75.3	69.9	69.7		
		MCDB	70.5	71.7	73.9	77.6	82.7	87.0	89.1	88.5	86.1	82.5	75.1	73.0		
	10%	WB	64.4	66.3	67.6	70.4	73.9	77.8	79.3	79.5	77.1	73.6	67.2	67.6		
		MCDB	68.4	70.0	72.7	76.3	82.0	86.7	87.8	87.6	85.0	80.7	73.0	71.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	21.7	22.1	22.0	21.6	19.0	17.8	17.5	18.9	23.1	24.1	19.6		
		MCDBR	19.3	20.9	21.8	23.1	24.0	22.7	20.3	20.5	20.9	23.4	23.6	18.0		
	5% WB	MCWBR	13.3	12.6	10.9	10.4	9.4	7.9	7.3	7.4	7.7	10.4	13.8	12.8		
		MCWBR	17.0	16.3	16.0	16.1	19.3	18.4	18.1	17.5	17.5	18.3	19.6	15.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.328	0.345	0.368	0.398	0.436	0.466	0.513	0.499	0.440	0.380	0.353	0.337		
		taud	2.545	2.501	2.429	2.350	2.279	2.249	2.135	2.167	2.306	2.452	2.470	2.529		
	Ebn at Noon	Ebn at Noon	287	292	291	284	272	263	250	252	264	275	275	278		
		Edh at Noon	27	31	36	40	43	44	49	47	40	32	29	26		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	968	1154	1564	1891	2092	1983	1878	1749	1630	1433	1100	849		
	RadStd	RadStd	71	152	125	151	117	159	123	127	101	145	96	82		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	+184

Nomenclature: See separate page