

WHITING FIELD NAS SOUTH, FL, USA

WMO: 720383

Lat: 30.704N

Lon: 87.023W

Elev: 54

StdP: 100.67

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 53847

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.9	(c) -0.1	(d) -11.7	(e) 1.4	(f) 2.7	(g) -9.2	(h) 1.7	(i) 4.8	(j) 10.4	(k) 11.1	(l) 9.2	(m) 10.4	(n) 2.9	(o) 340	(p) 0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	35.8	25.0	34.7	24.9	33.8	24.8	27.4	32.1	26.8	31.5	26.4	30.9	2.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	29.6	25.7	21.0	29.1	25.1	20.4	28.6	86.9	32.2	84.3	31.4	82.0	30.8	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.6	6.9	-5.1	37.4	1.9	1.6	-6.5	38.6	-7.6	39.5	-8.7	40.4	-10.0	41.5
			-6.6	28.0	1.8	0.8	-7.9	28.6	-8.9	29.1	-9.9	29.6	-11.2	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	11.3	13.8	16.7	20.0	24.0	27.6	28.2	28.3	26.6	21.4	15.6	13.6
	DBStd	7.16	5.56	5.15	4.63	3.39	2.78	1.78	1.63	1.77	2.22	4.11	4.63	5.34
	HDD10.0	110	51	22	6	0	0	0	0	0	0	0	8	23
	HDD18.3	771	227	142	88	23	3	0	0	0	0	19	105	164
	CDD10.0	3983	91	127	212	299	433	528	564	566	497	353	177	136
	CDD18.3	1603	8	14	37	72	177	278	306	308	247	114	24	18
	CDH23.3	15597	21	54	196	572	1658	2948	3281	3267	2322	1050	168	59
	CDH26.7	6502	0	3	27	108	638	1382	1506	1480	986	351	20	1
Wind	WSAvg	2.8	3.3	3.3	3.4	3.2	2.7	2.1	1.8	2.0	2.4	2.9	3.0	3.2
Precipitation	PrecAvg	1637	137	131	151	104	120	189	198	161	134	85	100	119
	PrecMax	2197	399	249	330	321	296	693	453	253	496	224	221	238
	PrecMin	926	21	36	23	9	1	41	50	70	14	0	10	27
	PrecStd	317	80	59	69	78	69	122	96	52	90	62	59	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.4	27.1	29.0	30.7	34.7	37.9	36.7	37.0	35.5	33.4	28.8	26.4
		MCWB	19.9	18.2	19.2	19.6	22.4	24.1	25.7	25.5	24.0	22.9	21.0	21.4
	2%	DB	23.6	25.1	27.3	29.1	32.8	35.5	35.2	35.6	34.2	31.6	26.7	25.0
		MCWB	19.6	18.8	19.0	19.8	22.3	24.5	25.5	25.5	24.1	22.2	19.6	21.2
	5%	DB	21.9	23.3	25.6	28.0	31.4	34.1	34.2	34.4	33.0	30.2	25.3	23.6
		MCWB	18.7	18.6	18.8	19.9	22.2	24.4	25.5	25.5	24.1	21.8	19.3	20.3
	10%	DB	20.3	21.8	23.9	26.7	30.1	32.9	33.1	33.1	31.8	28.8	23.8	22.1
		MCWB	17.1	18.0	18.1	19.5	21.8	24.3	25.5	25.3	24.1	21.1	18.9	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	22.2	22.5	24.5	25.6	27.4	28.0	28.2	26.9	26.0	24.1	23.8
		MCDB	23.6	23.8	25.2	27.2	29.6	31.8	33.1	33.0	31.2	29.0	25.5	25.1
	2%	WB	20.6	21.2	21.4	23.5	24.6	26.6	27.4	27.5	26.1	24.8	22.9	22.0
		MCDB	22.5	23.0	24.2	26.0	28.7	31.0	32.5	32.0	30.5	28.4	24.6	23.6
	5%	WB	19.5	20.3	20.7	22.3	23.9	25.9	26.8	26.9	25.6	24.0	21.1	21.0
		MCDB	21.4	22.1	23.3	25.3	28.2	30.6	31.7	31.4	30.1	28.1	24.0	22.8
	10%	WB	18.0	19.1	19.8	21.3	23.3	25.5	26.3	26.4	25.1	23.1	19.6	19.8
		MCDB	20.2	21.1	22.6	24.6	27.8	30.4	31.0	30.9	29.5	27.1	22.8	21.9
Mean Daily Temperature Range	5% DB	MDBR	12.1	12.1	12.3	12.2	12.0	10.5	9.9	9.7	10.5	12.8	13.4	10.9
		MCDBR	10.7	11.6	12.1	12.8	13.4	12.6	11.3	11.4	11.6	13.0	13.1	10.0
		MCWBR	7.4	7.0	6.1	5.8	5.2	4.4	4.0	4.1	4.3	5.8	7.7	7.1
	5% WB	MCDBR	9.4	9.0	8.9	9.0	10.7	10.2	10.1	9.7	9.7	10.2	10.9	8.5
		MCWBR	7.6	7.0	5.7	5.5	4.9	4.3	4.0	4.1	4.0	5.5	8.0	7.3
Clear-Sky Solar Irradiance	taub	0.328	0.345	0.368	0.398	0.436	0.466	0.513	0.499	0.440	0.380	0.353	0.337	
	taud	2.545	2.501	2.429	2.350	2.279	2.249	2.135	2.167	2.306	2.452	2.470	2.529	
	Ebn at Noon	905	919	916	896	859	828	788	795	833	867	866	875	
	Edh at Noon	85	97	112	125	136	139	155	149	125	101	91	83	
All-Sky Solar Radiation	RadAvg	3.05	3.64	4.93	5.96	6.59	6.25	5.92	5.51	5.14	4.52	3.47	2.68	
	RadStd	0.23	0.48	0.40	0.48	0.37	0.50	0.39	0.40	0.32	0.46	0.30	0.26	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+159	+102

Nomenclature: See separate page