

BEEVILLE MUNICIPAL, TX, USAWMO: **720391**Lat: **28.363N**Lon: **97.792W**Elev: **270**StdP: **14.55**Time Zone: **-6.00 (NAC)**Period: **07-19**WBAN: **00127****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.4	36.4	12.4	10.4	47.2	18.0	13.7	48.6	26.1	62.6	23.9	65.9	8.3	0	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.3	99.5	74.7	97.8	75.1	96.0	75.6	81.2	87.5	80.4	86.9	79.6	86.4	10.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	157.9	81.8	79.1	152.5	81.5	78.2	148.0	81.4	44.9	88.5	44.1	87.6	43.3	86.7	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.2	18.4	27.9	103.5	4.0	3.1	25.0	105.7	22.6	107.5	20.3	109.2	17.4	111.5		
(5)			24.0	82.2	3.7	2.6	21.3	84.0	19.1	85.5	17.0	86.9	14.3	88.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.0	55.8	60.6	65.7	72.3	78.5	83.9	84.1	85.1	81.0	73.6	64.6	57.9		
	DBStd	12.37	9.08	9.93	8.30	6.11	5.15	3.28	2.95	2.89	3.96	6.55	8.62	9.35		
	HDD50	119	48	26	7	0	0	0	0	0	0	0	8	30		
	HDD65	981	306	181	95	12	1	0	0	0	0	15	111	260		
	CDD50	8145	226	322	494	670	885	1018	1058	1087	930	733	446	276		
	CDD65	3533	20	57	117	232	421	568	593	622	480	283	99	41		
	CDH74	36801	164	388	780	1821	4118	6641	6835	7499	4897	2671	739	248		
	CDH80	17202	20	88	179	572	1727	3433	3526	4043	2348	1065	170	31		
(14) Wind	WSAvg	8.3	8.3	9.0	9.6	9.9	10.0	8.8	8.1	7.2	6.1	7.0	7.8	8.2		
(15) Precipitation	PrecAvg	31.7	1.8	1.6	2.4	2.2	2.9	3.0	4.0	2.5	4.5	3.0	2.1	1.6		
	PrecMax	43.2	6.3	5.2	5.9	9.2	7.8	8.2	15.7	7.7	12.3	12.3	6.4	7.4		
	PrecMin	17.0	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.5	0.0	0.0	0.0	0.0		
	PrecStd	7.8	1.5	1.5	1.7	2.3	2.2	2.0	4.1	2.2	3.0	3.1	2.0	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	88.1	89.3	93.1	96.4	101.6	100.3	101.8	99.6	93.5	88.1	83.5		
		MCWB	65.3	68.0	67.9	67.4	74.7	74.4	74.8	73.9	72.8	74.8	72.6	67.8		
	2%	DB	78.8	82.1	84.2	88.4	93.1	98.6	98.9	99.7	96.4	90.8	84.6	80.6		
		MCWB	63.0	67.5	68.8	71.2	75.2	75.0	75.3	74.7	74.8	73.6	69.8	67.4		
	5%	DB	74.7	79.1	81.5	86.1	90.9	96.3	96.7	98.1	93.7	88.5	81.5	77.0		
		MCWB	62.6	67.0	68.5	70.3	74.6	75.7	75.6	75.1	75.1	72.2	68.3	66.7		
	10%	DB	71.2	75.1	78.8	83.0	89.0	94.4	94.5	95.6	91.0	86.4	78.7	73.1		
		MCWB	62.7	65.7	67.4	69.5	74.4	76.0	76.6	76.2	75.0	71.6	68.5	66.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.6	73.5	74.9	78.4	81.3	81.6	83.1	81.5	81.4	80.1	77.4	74.4		
		MCDB	74.6	78.3	79.7	83.4	87.7	86.8	86.0	89.8	87.7	85.2	81.9	77.2		
	2%	WB	69.8	71.8	73.2	76.2	79.4	80.5	81.3	80.5	80.3	78.6	75.1	72.8		
		MCDB	73.0	77.4	78.4	81.3	84.1	86.3	86.9	88.6	87.2	83.9	79.1	75.8		
	5%	WB	67.2	70.3	72.0	74.6	78.3	79.4	80.2	79.7	79.4	77.5	73.0	70.8		
		MCDB	72.6	75.3	77.4	80.0	83.9	85.8	86.4	87.7	86.8	82.6	77.6	74.9		
	10%	WB	64.4	68.9	70.6	73.5	77.3	78.6	79.3	78.9	78.4	76.0	70.9	68.2		
		MCDB	68.3	73.2	75.8	78.7	83.5	85.4	86.0	86.6	85.2	81.6	75.8	72.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	21.5	21.1	20.7	19.3	20.7	20.2	22.3	20.5	22.7	21.2	19.9		
		MCDBR	26.7	24.2	22.4	22.1	21.1	23.5	24.2	24.9	23.8	24.0	23.2	23.1		
		MCWBR	15.1	12.6	11.4	9.3	6.2	5.4	5.8	5.8	7.4	9.6	11.5	14.6		
		MCDBR	20.7	20.2	19.5	16.4	16.3	18.8	19.6	22.0	19.9	19.9	19.7	20.4		
	5% WB	MCWBR	15.0	13.0	12.1	8.6	6.9	6.8	7.2	7.8	8.2	10.2	12.8	15.0		
(40) Clear-Sky Solar Irradiance	taub		0.347	0.355	0.379	0.425	0.467	0.441	0.450	0.436	0.430	0.384	0.365	0.334		
	taud		2.464	2.448	2.382	2.269	2.189	2.321	2.320	2.351	2.328	2.443	2.442	2.517		
	Ebn at Noon		283	291	289	277	265	270	267	271	269	277	274	283		
	Edh at Noon		30	33	38	43	47	41	41	40	39	33	31	28		
(44) All-Sky Solar Radiation	RadAvg		945	1108	1412	1669	1865	2095	2068	1986	1643	1414	1062	852		
	RadStd		107	193	150	162	159	114	188	111	153	163	114	116		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	+175

Nomenclature: See separate page