

BEEVILLE MUNICIPAL, TX, USA

WMO: 720391

Lat: 28.363N

Lon: 97.792W

Elev: 82

StdP: 100.34

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 00127

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.2	2.4	-10.9	1.5	8.4	-7.8	2.0	9.2	11.7	17.0	10.7	18.8	3.7	0	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	37.5	23.7	36.5	23.9	35.6	24.2	27.3	30.8	26.9	30.5	26.5	30.2	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.6	27.7	26.2	21.8	27.5	25.7	21.1	27.4	86.5	31.4	84.7	30.9	82.8	30.4	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.3	9.0	8.2	-2.3	39.7	2.2	1.7	-3.9	40.9	-5.2	41.9	-6.5	42.9	-8.1	44.2		
			-4.5	27.9	2.1	1.4	-6.0	28.9	-7.2	29.7	-8.3	30.5	-9.8	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	13.2	15.9	18.7	22.4	25.9	28.8	29.0	29.5	27.2	23.1	18.1	14.4
	DBStd	6.87	5.05	5.52	4.61	3.40	2.86	1.82	1.64	1.61	2.20	3.64	4.79	5.19
	HDD10.0	66	27	14	4	0	0	0	0	0	0	0	4	17
	HDD18.3	545	170	101	53	7	1	0	0	0	0	8	62	144
	CDD10.0	4525	126	179	274	372	492	566	588	604	517	407	248	153
	CDD18.3	1963	11	32	65	129	234	316	329	346	267	157	55	23
	CDH23.3	20445	91	216	433	1012	2288	3689	3797	4166	2721	1484	411	138
	CDH26.7	9557	11	49	99	318	959	1907	1959	2246	1304	592	94	17
Wind	WSAvg	3.7	3.7	4.0	4.3	4.4	4.5	3.9	3.6	3.2	2.7	3.1	3.5	3.7
Precipitation	PrecAvg	804	45	40	60	57	74	76	101	64	115	77	53	40
	PrecMax	1097	159	133	150	234	199	209	399	195	313	312	162	188
	PrecMin	433	0	0	1	0	1	3	8	12	13	0	0	1
	PrecStd	198	38	39	43	59	55	52	105	55	77	79	50	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	31.2	31.8	34.0	35.8	38.7	37.9	38.8	37.5	34.2	31.2	28.6
		MCWB	18.5	20.0	19.9	19.7	23.7	23.6	23.8	23.3	22.7	23.8	22.6	19.9
	2%	DB	26.0	27.9	29.0	31.4	33.9	37.0	37.1	37.6	35.8	32.7	29.2	27.0
		MCWB	17.2	19.7	20.4	21.8	24.0	23.9	24.1	23.7	23.8	23.1	21.0	19.7
	5%	DB	23.7	26.2	27.5	30.1	32.7	35.7	36.0	36.7	34.3	31.4	27.5	25.0
		MCWB	17.0	19.4	20.3	21.3	23.7	24.3	24.2	23.9	24.0	22.3	20.2	19.3
	10%	DB	21.8	23.9	26.0	28.3	31.7	34.7	34.7	35.4	32.8	30.2	26.0	22.9
		MCWB	17.0	18.7	19.6	20.8	23.5	24.4	24.8	24.6	23.9	22.0	20.3	19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	23.0	23.8	25.8	27.4	27.6	28.4	27.5	27.4	26.7	25.2	23.5
		MCDB	23.6	25.7	26.5	28.6	30.9	30.5	30.0	32.1	30.9	29.5	27.7	25.1
	2%	WB	21.0	22.1	22.9	24.6	26.3	27.0	27.4	26.9	26.8	25.9	23.9	22.7
		MCDB	22.8	25.2	25.8	27.4	29.0	30.2	30.5	31.5	30.7	28.8	26.2	24.4
	5%	WB	19.6	21.3	22.2	23.7	25.7	26.3	26.8	26.5	26.3	25.3	22.8	21.6
		MCDB	22.6	24.0	25.2	26.6	28.8	29.9	30.2	30.9	30.4	28.1	25.3	23.8
	10%	WB	18.0	20.5	21.4	23.0	25.2	25.9	26.3	26.1	25.8	24.4	21.6	20.1
		MCDB	20.2	22.9	24.3	26.0	28.6	29.7	30.0	30.4	29.6	27.6	24.3	22.3
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.9	11.7	11.5	10.7	11.5	11.2	12.4	11.4	12.6	11.8	11.1
		MCDBR	14.8	13.4	12.4	12.3	11.7	13.1	13.5	13.9	13.2	13.3	12.9	12.9
		MCWBR	8.4	7.0	6.3	5.2	3.4	3.0	3.2	3.2	4.1	5.4	6.4	8.1
	5% WB	MCDBR	11.5	11.2	10.9	9.1	9.1	10.5	10.9	12.2	11.1	11.0	11.0	11.3
		MCWBR	8.3	7.2	6.7	4.8	3.8	3.8	4.0	4.3	4.6	5.7	7.1	8.3
Clear-Sky Solar Irradiance	taub	0.347	0.355	0.379	0.425	0.467	0.441	0.450	0.436	0.430	0.384	0.365	0.334	
	taud	2.464	2.448	2.382	2.269	2.189	2.321	2.320	2.351	2.328	2.443	2.442	2.517	
	Ebn at Noon	893	916	911	874	834	851	842	853	849	873	864	892	
	Edh at Noon	95	105	119	137	149	130	129	125	124	104	97	87	
All-Sky Solar Radiation	RadAvg	2.98	3.49	4.45	5.26	5.88	6.60	6.52	6.26	5.18	4.46	3.35	2.69	
	RadStd	0.34	0.61	0.47	0.51	0.50	0.36	0.59	0.35	0.48	0.51	0.36	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page