

HOMERVILLE, GA, USA

WMO: 720392

Lat: 31.056N

Lon: 82.767W

Elev: 57

StdP: 100.64

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00128

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.4	(c) -0.9	(d) -8.9	(e) 1.8	(f) 2.7	(g) -6.3	(h) 2.2	(i) 3.0	(j) 9.0	(k) 10.3	(l) 8.3	(m) 11.3	(n) 1.1	(o) 320	(p) 0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	35.3	25.1	34.8	25.0	33.0	24.5	27.4	31.5	26.8	31.2	26.2	30.7	2.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.9	28.7	25.9	21.4	28.4	25.1	20.3	27.9	86.3	31.3	84.0	31.5	81.6	30.6	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.5	(b) 5.9	(c) 5.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 7.5	(b) 5.9	(c) 5.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	10.3	12.8	15.9	19.7	23.6	26.9	27.7	27.6	25.5	20.5	14.7	13.1		
	DBStd	7.18	5.31	5.01	4.68	3.33	2.85	2.06	1.59	1.51	2.17	3.83	4.55	5.24		
	HDD10.0	136	63	26	9	0	0	0	0	0	0	1	9	28		
	HDD18.3	872	253	164	103	23	2	0	0	0	0	24	127	176		
	CDD10.0	3749	72	104	191	292	423	506	549	547	466	326	151	124		
	CDD18.3	1444	3	9	27	65	167	256	291	288	216	92	18	13		
	CDH23.3	13653	27	76	251	670	1603	2576	2908	2754	1873	713	140	63		
	CDH26.7	5839	1	6	48	184	664	1267	1397	1253	794	201	19	6		
(14) Wind	WSAvg	1.7	2.0	2.1	2.2	2.0	1.8	1.7	1.5	1.4	1.3	1.5	1.5	1.7		
(15) Precipitation	PrecAvg	1268	123	96	123	65	67	151	151	138	116	86	62	74		
	PrecMax	1680	429	197	259	137	152	268	208	233	403	257	180	122		
	PrecMin	871	18	23	1	7	15	37	63	68	18	7	7	24		
	PrecStd	235	92	43	75	36	36	61	34	42	93	73	45	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	27.5	30.0	32.2	35.0	37.1	36.3	36.2	35.0	32.3	28.8	27.5		
		MCWB	20.1	19.4	19.1	21.6	21.7	24.8	25.5	25.5	23.7	22.9	23.3	21.9		
	2%	DB	23.0	26.0	27.8	30.3	32.8	35.3	35.2	35.0	32.9	30.3	27.0	25.1		
		MCWB	18.3	18.6	19.2	20.4	21.6	24.9	25.6	25.7	23.9	22.5	20.7	20.1		
	5%	DB	21.2	23.7	26.3	28.8	32.1	34.0	34.1	33.7	32.4	28.8	25.0	22.9		
		MCWB	17.6	17.7	18.4	19.8	21.5	24.4	25.3	25.7	23.9	21.6	19.4	19.9		
	10%	DB	18.9	22.0	24.1	27.4	30.9	32.7	32.8	32.5	31.2	27.5	22.8	22.0		
		MCWB	16.4	17.1	17.6	19.1	21.9	24.2	25.1	25.4	23.9	21.2	18.6	19.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.3	22.1	23.8	24.7	27.6	28.6	29.4	26.9	25.1	25.0	23.3		
		MCDB	23.8	24.2	26.4	28.6	29.7	31.7	32.2	30.4	30.0	28.3	27.7	25.6		
	2%	WB	20.1	20.2	21.1	22.6	24.0	26.7	27.3	27.4	26.1	24.2	23.0	22.3		
		MCDB	22.4	23.7	24.6	27.1	29.0	31.5	31.8	31.4	29.8	27.9	24.4	23.9		
	5%	WB	18.5	19.1	20.2	21.6	23.5	25.9	26.6	26.8	25.5	23.5	21.3	21.1		
		MCDB	21.1	22.8	23.9	25.8	28.4	31.0	31.5	31.0	29.4	26.8	23.5	22.4		
	10%	WB	17.1	17.7	19.1	20.7	22.8	25.4	25.9	26.2	25.0	22.6	19.5	19.5		
		MCDB	18.4	19.6	23.0	24.5	27.7	30.5	30.8	30.5	29.0	25.7	22.6	21.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.8	13.2	13.3	12.6	11.5	10.9	10.2	10.8	12.4	13.8	12.0		
		MCDBR	13.7	13.9	14.8	14.9	14.1	13.1	12.1	11.5	12.3	13.3	14.1	12.3		
	5% WB	MCWBR	9.0	7.7	6.9	5.7	4.4	4.1	3.9	4.0	4.2	5.8	7.8	8.0		
		MCWBR	11.8	11.7	11.4	11.4	11.1	11.5	10.9	10.1	9.7	10.0	10.4	10.2		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.334	0.370	0.388	0.428	0.473	0.509	0.499	0.428	0.379	0.348	0.332		
	taud		2.521	2.504	2.419	2.361	2.283	2.226	2.123	2.154	2.344	2.453	2.487	2.534		
	Ebn at Noon		903	929	912	904	865	823	791	795	843	866	869	878		
	Edh at Noon		87	97	113	124	135	142	157	151	120	101	89	82		
(44) All-Sky Solar Radiation	RadAvg		3.07	3.67	4.81	5.86	6.41	6.03	6.01	5.47	4.84	4.25	3.40	2.69		
	RadStd		0.19	0.43	0.42	0.44	0.38	0.40	0.37	0.36	0.39	0.39	0.23	0.24		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	+0.49	+0.74	N/A	N/A	N/A	N/A	N/A	-22	-78	+168	+114

Nomenclature: See separate page