

KNOX COUNTY AP, OH, USA

WMO: 720414

Lat: 40.333N

Lon: 82.517W

Elev: 363

StdP: 97.04

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 00139

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-13.8	-20.2	0.6	-15.3	-17.8	0.8	-13.0	11.2	-2.2	10.3	-2.8	2.6	270	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	32.1	23.5	30.9	22.9	29.1	22.0	25.1	29.6	24.1	28.6	23.4	27.4	3.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.8	19.5	27.5	22.8	18.3	26.2	22.3	17.8	25.7	78.8	29.2	74.9	28.5	71.6	27.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.1	7.2	DB	-20.6	33.8	3.7	1.8	-23.3	35.0	-25.4	36.0	-27.5	37.0	-30.1	38.3	(4)
(5)			WB	-20.8	26.3	3.3	1.0	-23.2	27.0	-25.2	27.6	-27.1	28.2	-29.5	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-3.1	-0.8	4.2	11.1	17.3	21.1	23.0	22.0	19.0	12.1	5.6	0.7	(6)	
	DBStd	10.35	6.48	6.62	6.01	5.15	4.55	3.23	2.77	2.57	4.06	5.04	5.40	5.60	(7)	
	HDD10.0	1443	408	307	199	47	3	0	0	0	1	34	151	293	(8)	
	HDD18.3	3126	665	536	439	222	75	13	2	3	41	201	381	547	(9)	
	CDD10.0	1836	1	5	18	80	230	333	402	373	269	100	20	4	(10)	
	CDD18.3	478	0	0	1	5	44	96	145	118	60	9	1	0	(11)	
	CDH23.3	3819	0	0	3	52	369	736	1201	896	488	72	2	0	(12)	
	CDH26.7	1142	0	0	1	5	79	214	422	251	156	14	0	0	(13)	
(14) Wind	WSAvg	3.0	3.7	3.6	3.7	3.7	3.0	2.6	2.1	2.0	2.3	2.9	3.3	3.4	(14)	
(15) Precipitation	PrecAvg	1050	79	55	82	98	112	107	109	98	87	69	72	83	(15)	
	PrecMax	1416	225	127	157	165	211	236	259	186	191	141	138	207	(16)	
	PrecMin	715	20	29	33	47	46	19	43	35	32	19	22	36	(17)	
	PrecStd	157	45	25	32	29	51	49	57	42	35	35	26	39	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	19.1	22.9	27.4	30.3	32.5	34.0	32.4	32.5	28.7	22.2	17.2	(19)	
		MCWB	13.9	14.4	15.9	16.5	21.5	23.3	25.4	22.8	23.8	21.9	15.1	14.9	(20)	
	2%	DB	12.7	14.9	19.1	24.9	28.8	31.0	32.2	31.0	30.9	25.1	18.8	14.0	(21)	
		MCWB	10.8	12.2	13.7	15.7	20.2	22.4	24.3	22.8	22.5	17.9	13.3	12.2	(22)	
	5%	DB	9.1	12.3	16.3	22.4	27.4	29.0	30.9	29.1	28.0	22.8	16.4	12.1	(23)	
		MCWB	7.8	10.2	11.8	14.8	19.6	21.7	23.6	22.0	21.6	16.8	11.5	11.0	(24)	
	10%	DB	6.2	8.8	13.8	20.0	25.8	27.6	29.0	27.8	26.2	20.3	13.9	8.9	(25)	
		MCWB	4.4	6.7	10.1	13.5	18.6	20.7	22.6	21.3	20.2	16.5	10.0	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	15.6	17.1	18.9	23.6	25.1	26.8	25.6	24.8	22.4	17.1	15.3	(27)	
		MCDB	15.4	18.2	22.6	23.9	28.1	30.3	31.4	29.7	30.1	25.9	20.2	16.6	(28)	
	2%	WB	11.3	12.8	15.0	17.2	22.1	23.7	25.6	24.5	23.8	20.3	14.8	12.7	(29)	
		MCDB	12.4	13.9	18.4	21.5	26.6	28.3	30.0	28.3	28.7	23.1	17.3	13.9	(30)	
	5%	WB	8.1	10.1	13.0	15.8	20.8	22.9	24.6	23.5	22.8	18.6	12.4	10.8	(31)	
		MCDB	8.6	12.3	15.4	20.4	24.9	27.4	29.0	27.0	26.9	21.4	15.7	11.8	(32)	
	10%	WB	4.4	6.8	11.0	14.7	19.7	22.1	23.6	22.7	21.7	16.7	10.6	7.6	(33)	
		MCDB	6.0	8.7	13.3	18.9	23.8	26.3	27.6	26.0	25.0	19.9	13.4	8.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	8.6	9.7	11.3	11.3	10.7	10.7	11.1	11.0	10.5	8.9	7.0	(35)	
		MCDBR	10.8	12.0	13.2	14.0	12.8	12.5	12.1	12.3	13.1	13.5	12.3	10.3	(36)	
	5% WB	MCWBR	9.8	9.5	8.7	8.0	6.2	5.6	5.5	5.4	5.9	7.1	8.1	9.2	(37)	
		MCWBR	10.2	11.2	10.7	11.9	10.9	10.5	10.6	10.0	11.4	11.1	10.9	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.303	0.326	0.351	0.387	0.422	0.443	0.453	0.437	0.384	0.358	0.322	0.303	(40)	
		taud	2.430	2.349	2.355	2.278	2.210	2.190	2.179	2.210	2.336	2.402	2.469	2.461	(41)	
	Ebn at Noon		860	886	900	886	858	838	825	828	853	838	831	831	(42)	
		Edh at Noon	80	100	112	129	142	145	145	137	113	95	77	72	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.56	2.42	3.42	4.65	5.46	5.96	5.87	5.39	4.37	2.96	1.97	1.33	(44)	
	RadStd		0.15	0.32	0.33	0.43	0.46	0.44	0.35	0.27	0.39	0.26	0.28	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)			+0.41	N/A	N/A	N/A	N/A	N/A	N/A	+123	+68

Nomenclature: See separate page