

STEVENS FIELD, CO, USA

WMO: 720539

Lat: 37.283N

Lon: 107.050W

Elev: 2335

StdP: 76.24

Time Zone: -7.00 (NAM)

Period: 09-19

WBAN: 00165

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.3	-14.5	-23.1	0.6	-1.3	-21.0	0.8	0.3	8.3	-0.4	7.0	-0.5	0.1	300	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	30.0	11.4	28.6	11.4	27.5	11.1	14.7	19.9	14.1	20.2	13.7	20.4	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.7	13.1	15.5	12.7	12.2	15.1	11.8	11.5	15.0	49.9	19.6	48.0	19.9	46.3	20.1	17.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.4	5.9	DB	-22.2	32.1	2.9	0.9	-24.2	32.8	-25.9	33.3	-27.5	33.8	-29.6	34.4	(4)
(5)			WB	-22.5	16.2	2.7	0.6	-24.4	16.6	-26.0	17.0	-27.4	17.3	-29.4	17.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-3.5	-1.7	2.9	6.3	10.0	16.8	19.4	17.9	14.6	8.0	2.1	-2.4	(6)	
	DBStd	8.59	4.12	4.37	3.68	3.29	3.42	2.51	1.72	1.62	2.85	3.49	3.82	4.14	(7)	
	HDD10.0	1829	419	329	220	114	43	0	0	0	3	78	237	385	(8)	
	HDD18.3	3998	678	562	478	360	259	59	10	26	115	321	486	643	(9)	
	CDD10.0	944	0	0	0	4	43	204	290	246	142	16	0	0	(10)	
	CDD18.3	72	0	0	0	0	0	13	42	13	3	0	0	0	(11)	
	CDH23.3	1907	0	0	0	1	20	624	677	434	151	2	0	0	(12)	
	CDH26.7	417	0	0	0	0	0	159	169	74	15	0	0	0	(13)	
(14) Wind	WSAvg	1.5	0.8	1.2	1.7	2.3	2.3	2.1	1.6	1.4	1.4	1.3	1.0	0.8	(14)	
(15) Precipitation	PrecAvg	534	42	39	43	37	34	22	55	72	59	50	39	40	(15)	
	PrecMax	687	114	104	100	100	86	58	108	142	112	123	80	132	(16)	
	PrecMin	361	9	10	6	15	4	3	5	25	17	2	1	9	(17)	
	PrecStd	74	28	20	22	23	22	14	24	25	29	31	20	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	12.7	18.5	22.2	25.5	31.7	31.2	30.1	28.3	22.7	16.7	11.3	(19)	
		MCWB	2.0	3.4	5.3	6.9	8.1	11.1	12.0	11.4	11.8	8.3	5.2	2.1	(20)	
	2%	DB	7.4	10.8	16.2	19.2	23.5	30.2	29.9	28.5	27.0	20.2	14.8	8.7	(21)	
		MCWB	0.4	2.4	4.4	5.7	7.4	10.6	11.9	11.4	10.9	7.5	4.5	1.0	(22)	
	5%	DB	5.4	8.6	13.7	17.5	21.9	28.5	28.7	27.4	25.2	18.7	12.7	6.7	(23)	
		MCWB	-0.7	1.7	3.3	5.1	6.8	10.2	12.0	11.5	10.2	6.8	3.5	0.4	(24)	
	10%	DB	3.4	6.1	11.5	15.6	20.2	27.1	27.4	26.1	23.4	17.1	10.2	4.2	(25)	
		MCWB	-1.0	0.3	2.4	4.3	6.4	9.4	12.1	11.6	9.6	6.3	2.4	-0.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	4.2	5.8	8.0	9.9	13.9	15.7	15.5	13.9	12.0	6.8	3.6	(27)	
		MCDB	7.0	10.9	14.9	17.1	19.7	20.3	20.0	19.2	19.3	15.1	10.7	7.4	(28)	
	2%	WB	1.7	3.0	5.0	6.9	8.7	12.7	14.9	14.8	13.1	10.0	5.5	2.3	(29)	
		MCDB	3.9	8.2	14.2	16.2	18.8	22.3	20.0	19.6	19.1	14.6	11.9	5.6	(30)	
	5%	WB	0.9	1.9	3.9	5.9	7.8	11.8	14.3	14.1	12.5	8.7	4.2	1.4	(31)	
		MCDB	2.8	7.2	12.3	14.7	18.3	23.9	20.4	19.6	18.8	14.3	11.4	4.1	(32)	
	10%	WB	0.2	1.0	2.9	5.1	7.1	11.0	13.9	13.6	11.7	7.5	3.0	0.4	(33)	
		MCDB	2.6	5.0	9.7	13.7	17.7	23.4	20.8	19.7	18.5	14.6	9.5	3.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	13.3	14.4	15.0	15.9	19.3	16.2	16.0	16.2	15.4	13.6	12.1	(35)	
		MCDBR	16.4	15.9	17.6	18.6	19.6	21.1	18.3	18.8	18.9	18.4	17.4	15.0	(36)	
	5% WB	MCWBR	10.3	8.4	8.0	8.1	7.7	7.1	5.2	5.8	6.4	7.9	8.5	8.6	(37)	
		MCWBR	11.0	14.1	16.1	16.5	17.0	17.8	14.4	13.3	13.2	14.1	15.2	10.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.224	0.229	0.254	0.281	0.298	0.294	0.347	0.324	0.282	0.259	0.245	0.230	(40)	
		taud	2.547	2.556	2.530	2.512	2.523	2.536	2.444	2.477	2.638	2.668	2.596	2.554	(41)	
	Ebn at Noon		1001	1031	1023	1001	981	980	926	944	979	982	965	970	(42)	
		Edh at Noon	73	83	95	103	104	103	112	106	85	74	70	68	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.99	3.89	5.24	6.29	7.04	7.75	6.53	5.96	5.40	4.26	3.21	2.56	(44)	
	RadStd		0.21	0.28	0.37	0.36	0.57	0.46	0.41	0.29	0.30	0.34	0.23	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page