

UNIVERSITY-OXFORD, MS, USA

WMO: 720541

Lat: 34.383N

Lon: 89.550W

Elev: 452

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 53806

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.1	22.7	3.3	6.6	25.0	9.3	9.0	29.2	19.0	43.5	17.5	43.3	3.0	0	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	93.1	74.5	91.1	75.0	90.2	74.8	78.3	88.4	77.5	87.4	76.7	86.1	5.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.3	134.8	82.0	74.7	132.0	81.5	73.3	125.8	80.3	42.1	88.0	41.2	86.6	40.2	86.6	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	13.7	11.9	10.4	96.6	5.7	2.4	6.3	98.3	3.0	99.8	-0.2	101.1	-4.4	102.9		
			9.2	80.6	5.2	1.6	5.4	81.7	2.4	82.6	-0.6	83.5	-4.3	84.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	40.8	44.9	52.0	61.5	68.9	76.9	78.8	78.3	73.6	60.8	49.8	44.0	(6)
	DBStd	15.92	10.69	11.25	10.11	7.80	7.23	4.20	4.00	4.04	6.21	8.45	9.20	9.70	(7)
	HDD50	1017	324	216	100	9	1	0	0	0	0	11	114	242	(8)
	HDD65	3243	752	565	413	154	51	0	0	0	9	187	459	653	(9)
	CDD50	5003	38	72	162	353	586	806	894	876	707	344	109	56	(10)
	CDD65	1758	1	2	11	49	171	357	429	411	266	55	4	2	(11)
	CDH74	15685	0	7	73	385	1340	3323	4075	3705	2305	454	15	3	(12)
	CDH80	6261	0	0	6	48	378	1378	1780	1588	959	124	0	0	(13)
(14) Wind	WSAvg	4.3	5.3	5.9	5.6	5.3	4.4	3.7	3.2	2.9	3.2	3.6	4.3	4.8	(14)
(15) Precipitation	PrecAvg	56.3	4.9	5.0	5.6	5.4	5.6	4.1	4.1	3.5	3.8	3.6	5.3	5.9	(15)
	PrecMax	83.8	12.6	13.7	16.1	18.5	13.1	13.3	11.1	11.4	10.0	13.0	11.9	19.9	(16)
	PrecMin	36.4	0.4	0.9	1.3	1.1	0.7	0.2	1.0	0.5	0.4	0.0	1.2	0.5	(17)
	PrecStd	11.8	2.9	2.9	2.9	3.2	3.1	2.9	2.3	2.1	2.2	2.6	3.0	3.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	74.7	81.0	83.8	89.9	94.8	95.1	95.2	94.8	89.7	76.8	73.1	(19)
		MCWB	60.5	63.5	63.5	67.8	71.1	72.8	76.1	75.9	71.9	69.4	63.7	65.2	(20)
	2%	DB	65.5	70.5	75.3	81.4	86.2	91.2	92.7	92.8	91.3	82.4	72.3	67.9	(21)
		MCWB	59.3	61.3	61.7	65.2	70.6	75.1	76.2	75.2	72.3	68.5	60.8	63.6	(22)
	5%	DB	62.6	66.2	72.3	78.9	84.0	90.2	90.6	90.6	90.1	79.2	68.3	63.9	(23)
		MCWB	56.8	59.3	59.6	64.1	70.1	75.0	76.4	75.1	72.3	65.8	60.9	60.4	(24)
	10%	DB	57.2	63.3	68.0	75.2	81.7	87.8	89.7	88.4	86.1	74.9	64.4	60.6	(25)
		MCWB	51.9	56.1	58.1	62.6	68.7	74.4	76.1	74.6	72.2	65.3	57.7	55.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	66.1	65.9	70.5	74.5	78.5	79.5	79.4	77.3	74.2	68.4	67.2	(27)
		MCDB	67.1	70.1	74.8	79.4	82.3	88.6	89.5	90.8	87.0	83.1	71.2	70.6	(28)
	2%	WB	60.8	63.6	64.1	68.5	72.9	77.5	78.3	78.1	75.7	72.2	65.3	64.1	(29)
		MCDB	64.3	67.3	71.6	76.4	81.8	87.9	88.2	88.5	85.5	80.3	69.0	66.8	(30)
	5%	WB	57.4	60.4	62.5	67.0	71.8	76.7	77.7	77.2	74.5	69.9	62.6	61.6	(31)
		MCDB	60.6	65.9	69.3	74.4	81.1	86.4	87.5	86.8	83.8	75.1	66.2	64.2	(32)
	10%	WB	54.1	57.5	60.4	65.5	70.7	75.5	76.9	76.1	73.4	67.1	59.3	57.3	(33)
		MCDB	56.4	61.5	66.7	73.1	79.0	84.2	86.1	84.9	82.2	72.7	64.6	59.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	19.6	21.3	22.0	19.7	19.5	18.4	19.3	20.6	21.9	21.6	17.3	(35)
		MCDBR	22.4	22.2	23.7	23.5	21.3	22.1	20.1	21.5	24.5	24.8	23.6	19.2	(36)
	5% WB	MCWBR	16.6	14.8	13.0	10.8	8.7	8.3	7.1	7.6	8.2	11.7	14.1	14.7	(37)
		MCWBR	18.9	19.4	20.0	17.8	17.9	18.9	18.4	18.2	18.8	19.5	17.3	17.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.315	0.322	0.359	0.392	0.429	0.457	0.500	0.498	0.428	0.368	0.335	0.315	(40)
		taud	2.516	2.494	2.414	2.312	2.261	2.195	2.113	2.105	2.296	2.438	2.479	2.529	(41)
	Ebn at Noon		285	294	290	284	273	264	252	250	264	274	273	277	(42)
		Edh at Noon	26	30	35	41	43	46	50	49	39	31	27	25	(43)
(44) All-Sky Solar Radiation	RadAvg		791	948	1321	1672	1881	2038	1943	1797	1562	1243	899	679	(44)
	RadStd		67	131	120	107	103	119	106	118	123	157	92	68	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page