

LAGO VISTA, TX, USA

WMO: 720542

Lat: 30.500N

Lon: 97.967W

Elev: 1231

StdP: 14.05

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00166

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.6	31.6	9.9	9.6	38.7	14.2	11.8	42.9	19.9	50.1	18.2	52.5	7.0	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.4	99.5	70.8	97.6	71.5	95.8	72.1	76.7	85.3	76.0	84.9	75.4	84.4	7.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.1	137.7	78.4	74.1	133.1	78.2	73.3	129.6	78.1	40.9	85.6	40.3	85.0	39.7	84.2	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	15.9	13.6	21.1	103.8	4.1	2.5	18.1	105.5	15.7	107.0	13.4	108.4	10.4	110.2
			18.3	78.1	3.7	1.5	15.6	79.2	13.4	80.0	11.3	80.9	8.6	81.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.2	51.0	55.1	62.4	69.2	75.4	82.3	84.8	85.8	79.9	70.3	60.2	52.5
	DBStd	14.34	9.66	11.08	8.98	6.75	5.85	3.53	3.17	3.47	5.27	8.14	9.32	9.58
	HDD50	306	107	68	18	0	0	0	0	0	0	2	25	86
	HDD65	1582	441	302	152	38	7	0	0	0	1	47	194	400
	CDD50	7296	136	212	403	575	788	970	1080	1111	897	631	330	163
	CDD65	3099	6	26	72	163	330	520	615	646	448	210	50	13
	CDH74	31882	36	123	419	1124	2734	5689	7498	8133	4349	1534	206	37
	CDH80	15048	1	22	66	305	1029	2726	3974	4477	1966	455	26	1
(14) Wind	WSAvg	7.2	7.4	7.9	8.0	8.4	7.8	7.1	6.7	6.5	5.8	6.8	6.9	7.1
(15) Precipitation	PrecAvg	34.1	2.4	2.0	2.7	3.0	3.9	3.4	2.2	2.0	3.2	3.9	3.0	2.4
	PrecMax	55.2	7.6	6.7	6.8	7.3	13.6	9.8	7.9	7.6	10.6	15.6	11.2	12.9
	PrecMin	15.9	0.0	0.1	0.0	0.5	0.1	0.2	0.0	0.0	0.2	0.0	0.0	0.2
	PrecStd	9.9	1.9	1.7	1.6	1.8	2.8	2.5	2.0	2.0	2.2	3.7	2.7	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	82.6	85.6	90.7	95.2	100.1	101.3	102.4	99.1	91.4	83.5	78.2
		MCWB	59.5	59.1	63.3	66.0	71.8	70.2	71.2	71.3	68.5	68.0	69.6	63.3
	2%	DB	73.2	77.7	81.5	86.8	90.9	96.8	99.2	99.7	95.4	87.9	79.3	73.4
		MCWB	57.7	59.9	62.6	66.5	70.9	71.5	71.1	71.3	70.7	70.8	64.8	63.3
	5%	DB	69.7	73.4	79.0	83.4	88.5	94.5	97.0	98.6	92.5	85.4	76.4	70.4
		MCWB	57.5	60.9	62.5	66.7	70.5	72.4	71.6	71.6	71.0	68.9	64.5	62.3
	10%	DB	65.6	70.2	75.3	80.8	86.1	91.3	95.0	96.6	90.2	81.9	72.9	67.7
		MCWB	55.5	61.2	61.8	64.9	70.2	72.6	72.4	72.2	70.6	66.7	64.4	60.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.2	69.0	69.8	73.8	76.4	77.9	77.2	77.3	77.3	76.2	73.2	69.7
		MCDB	70.0	72.7	75.6	81.3	84.7	86.1	88.3	86.4	82.5	81.4	78.2	72.6
	2%	WB	64.0	67.3	68.4	72.0	75.1	76.5	76.3	76.2	76.1	74.8	71.0	67.1
		MCDB	68.7	71.1	74.1	79.2	83.1	85.0	86.6	85.9	82.6	80.1	74.9	70.9
	5%	WB	61.1	65.4	67.0	70.5	73.9	75.6	75.5	75.4	75.2	73.4	68.7	64.6
		MCDB	65.8	69.0	73.0	77.6	82.0	84.7	85.3	85.6	82.5	79.0	72.6	68.8
	10%	WB	58.4	62.9	65.7	69.2	72.9	75.0	75.0	74.9	74.4	72.0	66.5	61.9
		MCDB	64.0	67.9	71.9	76.3	80.9	84.2	84.8	85.3	81.8	78.5	71.3	66.0
(35) Mean Daily Temperature Range	5% DB	MDBR	19.1	18.6	19.7	19.3	18.2	18.5	19.7	20.4	18.4	18.6	17.6	17.2
		MCDBR	23.4	20.5	21.7	22.1	20.7	21.2	22.0	22.3	21.1	19.4	18.4	19.6
		MCWBR	13.1	12.0	10.1	9.7	6.9	4.6	4.5	4.8	5.5	7.2	9.3	12.8
	5% WB	MCDBR	18.5	16.2	17.6	17.0	16.3	17.1	18.8	19.6	16.9	16.2	15.6	17.7
		MCWBR	14.4	13.5	11.3	9.3	6.6	4.8	4.6	4.4	4.9	8.8	11.7	14.8
(40) Clear-Sky Solar Irradiance	taub		0.314	0.324	0.348	0.387	0.425	0.414	0.426	0.416	0.393	0.364	0.344	0.312
	taud		2.525	2.505	2.447	2.357	2.301	2.376	2.382	2.390	2.403	2.472	2.464	2.540
	Ebn at Noon		292	299	297	287	276	277	273	275	279	281	278	287
	Edh at Noon		28	31	35	40	42	39	38	38	36	31	29	26
(44) All-Sky Solar Radiation	RadAvg		970	1131	1453	1741	1840	2114	2125	2007	1650	1351	1021	858
	RadStd		103	190	134	157	175	150	172	107	152	195	123	113

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144

Nomenclature: See separate page