

CARSON, NV, USA

WMO: 720549

Lat: 39.192N

Lon: 119.734W

Elev: 4699

StdP: 12.37

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 00171

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.2	15.6	-2.0	5.9	38.1	0.9	6.8	37.9	23.8	45.1	20.1	43.8	0.9	330	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.0	94.5	58.3	91.4	57.5	90.2	57.1	61.4	86.3	60.1	84.3	58.9	82.9	9.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.3	74.9	66.0	50.4	64.6	66.5	48.0	59.0	66.5	29.6	85.3	28.6	83.6	27.7	83.7	65.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	17.6	16.0	DB	3.0	98.6	4.5	3.0	-0.2	100.8	-2.8	102.6	-5.3	104.3	-8.6	106.5
			WB	3.0	64.0	5.1	1.1	-0.7	64.8	-3.6	65.4	-6.5	66.0	-10.1	66.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	35.3	37.4	44.2	49.6	55.9	66.3	73.2	71.5	64.0	51.9	41.7	34.0	(6)
	DBStd	15.13	7.81	8.56	6.56	6.75	6.35	6.74	4.53	3.84	6.51	6.66	7.74	8.43	(7)
	HDD50	1940	456	358	198	87	20	3	0	0	5	54	263	496	(8)
	HDD65	5307	920	774	644	461	286	62	2	2	89	407	700	960	(9)
	CDD50	2735	1	4	20	76	203	493	720	666	425	114	12	1	(10)
	CDD65	625	0	0	0	0	4	102	256	203	58	2	0	0	(11)
	CDH74	11090	0	0	3	43	281	2020	3878	3295	1446	124	0	0	(12)
	CDH80	4971	0	0	0	3	48	855	1947	1557	531	30	0	0	(13)
(14) Wind	WSAvg	5.3	4.0	5.2	6.1	6.8	6.2	6.2	5.1	4.8	4.8	4.8	4.6	4.7	(14)
(15) Precipitation	PrecAvg	13.4	2.4	2.0	1.8	0.9	0.8	0.5	0.2	0.3	0.3	0.8	1.1	2.3	(15)
	PrecMax	25.4	6.6	4.6	6.5	2.5	2.6	2.0	0.8	1.2	2.2	4.0	3.0	7.7	(16)
	PrecMin	6.3	0.4	0.4	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.2	(17)
	PrecStd	4.4	1.7	1.1	1.5	0.6	0.6	0.6	0.2	0.4	0.4	0.9	0.8	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	66.2	72.6	79.3	84.1	95.3	99.2	95.2	91.3	84.1	70.5	59.5	(19)
		MCWB	44.6	45.5	47.6	52.5	53.9	58.7	59.9	57.5	56.8	54.1	47.5	42.9	(20)
	2%	DB	55.3	63.0	67.5	73.4	81.3	91.4	95.0	93.0	88.3	76.9	66.1	55.4	(21)
		MCWB	41.8	43.1	46.1	49.1	52.4	57.7	58.9	57.2	55.2	51.1	46.5	42.3	(22)
	5%	DB	53.8	57.5	63.7	71.7	77.0	89.6	92.6	90.9	85.8	72.9	62.8	53.6	(23)
		MCWB	41.0	41.0	44.2	48.2	50.7	56.3	58.6	56.6	54.5	49.0	44.3	41.2	(24)
	10%	DB	49.5	54.2	59.1	66.0	72.9	84.4	90.4	89.6	82.4	69.6	56.9	48.3	(25)
		MCWB	39.3	40.3	42.6	46.4	49.7	54.7	58.1	56.3	53.8	47.8	41.8	39.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	47.6	49.2	53.6	55.5	61.9	63.4	61.8	60.5	55.8	50.2	47.0	(27)
		MCDB	56.7	61.6	69.0	76.0	77.3	90.2	86.5	84.6	79.4	74.0	66.0	55.8	(28)
	2%	WB	44.0	44.8	46.9	51.1	53.9	59.6	62.0	60.1	58.5	53.3	47.6	44.2	(29)
		MCDB	53.3	58.4	64.6	70.1	75.8	85.5	86.9	83.5	80.3	72.2	62.8	52.1	(30)
	5%	WB	41.7	42.6	45.2	49.2	52.4	57.9	60.8	58.9	56.6	51.4	45.1	42.1	(31)
		MCDB	51.0	55.6	61.8	67.4	73.1	83.1	85.7	83.1	79.3	67.2	59.5	50.8	(32)
	10%	WB	39.6	40.7	43.5	47.2	50.8	56.2	59.6	57.7	55.0	49.5	43.3	39.9	(33)
		MCDB	47.5	52.6	57.3	64.1	69.6	80.6	83.6	83.0	78.9	65.0	55.4	48.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.3	24.6	23.7	26.1	26.5	31.4	33.0	34.0	33.3	30.4	26.1	20.7	(35)
		MCDBR	29.2	31.9	33.0	35.0	34.7	36.9	35.2	36.2	39.0	37.5	34.3	26.4	(36)
		MCWBR	17.0	16.4	16.1	15.8	13.9	12.2	10.6	11.4	14.1	16.5	17.8	14.7	(37)
	5% WB	MCDBR	24.5	29.2	29.6	30.9	31.0	33.6	32.0	31.8	33.2	30.1	30.8	21.9	(38)
		MCWBR	14.8	16.0	14.6	14.4	12.2	11.5	9.5	10.4	12.0	13.9	16.5	13.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.260	0.280	0.284	0.301	0.315	0.319	0.320	0.316	0.300	0.290	0.264	0.260	(40)
	taud		2.555	2.512	2.525	2.485	2.480	2.487	2.516	2.498	2.550	2.570	2.603	2.558	(41)
	Ebn at Noon		297	303	312	310	305	303	301	301	302	295	294	289	(42)
	Edh at Noon		23	27	30	33	34	34	33	33	29	25	22	21	(43)
(44) All-Sky Solar Radiation	RadAvg		750	1035	1465	1921	2272	2614	2549	2312	1898	1349	882	644	(44)
	RadStd		97	116	123	151	184	152	129	103	76	93	57	87	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+175	+79

Nomenclature: See separate page