

ABBEVILLE, LA, USA

WMO: 720587

Lat: 29.976N

Lon: 92.084W

Elev: 50

StdP: 14.67

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00184

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.6	33.7	20.1	15.1	40.0	25.3	19.3	44.0	23.6	60.3	20.4	59.6	4.6	10	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	94.8	78.9	92.7	78.3	91.1	78.5	84.8	88.3	82.3	87.2	81.4	86.3	6.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.8	177.5	88.3	81.4	163.5	83.9	80.6	159.0	83.4	49.1	87.4	46.2	87.2	44.8	86.8	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.7	17.4	15.6	DB	25.0	96.7	5.0	2.2	21.3	98.3	18.4	99.6	15.6	100.8	12.0	102.5	
			WB	23.2	83.3	4.8	0.9	19.8	83.9	17.0	84.4	14.3	84.9	10.8	85.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.2	52.5	58.4	63.2	69.2	76.0	81.4	82.5	81.9	79.2	69.8	59.9	55.6
	DBStd	12.62	10.02	9.55	8.10	5.75	5.23	3.22	2.48	2.80	3.69	7.41	8.76	9.13
	HDD50	196	92	32	9	0	0	0	0	0	0	0	18	45
	HDD65	1345	403	221	133	29	4	0	0	0	0	38	200	317
	CDD50	7196	168	267	417	576	806	941	1008	989	876	615	315	218
	CDD65	2870	14	36	76	155	345	491	543	524	426	188	47	25
	CDH74	26381	22	87	338	987	3139	5149	5711	5212	3766	1671	230	69
	CDH80	10218	0	2	19	110	1071	2266	2457	2221	1549	504	19	0
Wind	WSAvg	5.7	7.1	7.8	7.3	7.5	6.3	4.7	3.7	3.6	3.6	4.8	5.8	6.8
Precipitation	PrecAvg	60.9	5.3	3.8	4.2	4.5	3.9	7.1	6.6	5.4	5.7	4.8	4.8	4.5
	PrecMax	82.9	13.7	8.6	10.4	12.6	11.4	15.8	9.8	10.0	11.9	14.4	14.1	13.2
	PrecMin	37.9	1.1	0.5	0.1	0.2	0.2	1.0	3.1	2.1	2.2	0.5	1.7	1.7
	PrecStd	11.8	3.9	2.5	2.7	3.2	2.8	3.9	1.8	2.0	2.8	4.1	3.1	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.8	79.4	81.9	85.8	91.4	98.6	96.8	95.7	94.5	90.2	82.6	78.6
		MCWB	68.7	71.4	70.5	69.6	75.6	77.1	83.5	80.0	75.5	74.9	73.1	71.6
	2%	DB	73.3	76.9	80.5	82.2	90.1	94.7	93.7	93.8	91.9	87.9	79.4	76.2
		MCWB	68.1	71.2	69.8	71.5	75.5	77.6	79.8	79.0	76.5	75.0	70.5	70.7
	5%	DB	71.8	73.7	78.5	81.3	88.1	91.4	91.7	91.4	90.4	85.8	77.1	73.1
		MCWB	67.3	69.6	69.4	70.9	74.9	77.8	79.7	79.6	76.9	74.3	68.0	70.0
	10%	DB	68.3	72.1	75.3	79.5	86.1	90.1	90.5	90.1	88.4	82.4	74.1	70.2
		MCWB	65.1	69.0	68.8	70.5	74.9	78.0	79.5	79.5	77.1	72.2	67.9	67.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.9	74.3	74.4	78.8	79.9	82.4	87.6	87.1	84.3	81.2	76.8	74.5
		MCDB	74.4	76.6	78.4	80.3	83.2	87.2	92.9	90.3	87.0	84.8	79.7	76.2
	2%	WB	70.8	72.9	73.2	76.3	78.5	81.4	85.8	84.3	81.8	79.4	74.1	72.6
		MCDB	72.5	75.2	77.3	79.1	83.1	86.9	89.3	88.8	86.0	82.7	76.7	74.6
	5%	WB	68.8	71.6	72.2	74.7	77.7	80.8	82.3	82.3	80.4	77.8	72.3	70.6
		MCDB	70.2	73.8	75.5	78.2	83.4	86.4	86.9	87.7	84.9	81.7	74.8	72.5
	10%	WB	65.7	69.9	70.7	73.1	76.8	80.0	81.2	81.3	79.2	76.0	69.8	68.2
		MCDB	67.9	71.4	73.5	77.3	82.9	85.7	86.1	86.3	83.9	80.1	73.3	70.0
Mean Daily Temperature Range	5% DB	MDBR	19.0	17.6	19.2	18.5	17.7	16.6	16.0	16.1	17.9	22.1	21.7	18.2
		MCDBR	18.4	16.3	18.0	18.5	19.1	18.8	17.8	18.0	19.8	21.4	20.3	18.4
		MCWBR	12.9	11.2	10.1	9.5	7.4	6.7	7.0	7.4	8.0	9.9	12.2	13.5
	5% WB	MCDBR	15.3	14.1	14.8	14.5	16.2	15.8	15.7	15.9	16.1	17.0	17.2	17.1
		MCWBR	13.4	11.3	10.3	10.0	7.5	7.1	8.0	8.5	8.5	9.9	13.4	14.2
Clear-Sky Solar Irradiance	taub		0.342	0.357	0.379	0.422	0.450	0.471	0.491	0.484	0.445	0.382	0.360	0.352
	taud		2.504	2.467	2.395	2.275	2.232	2.223	2.196	2.215	2.292	2.445	2.456	2.477
	Ebn at Noon		283	288	288	277	269	262	256	257	264	275	273	272
	Edh at Noon		29	32	37	43	45	45	46	45	40	32	30	28
All-Sky Solar Radiation	RadAvg		931	1089	1489	1809	1999	1960	1857	1757	1613	1433	1080	833
	RadStd		93	159	135	133	114	154	134	154	148	163	103	85

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+220	+148

Nomenclature: See separate page