

CONWAY-HORRY COUNTY AP, SC, USA

WMO: 720613

Lat: 33.828N

Lon: 79.122W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00204

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	27.6	9.2	8.8	31.1	14.1	11.3	32.9	16.7	58.9	14.6	55.3	1.1	20	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	94.8	78.0	91.2	77.1	90.1	76.9	82.1	87.4	80.5	85.3	79.0	84.3	5.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.4	85.4	79.2	151.6	82.2	77.4	142.7	80.7	45.8	88.1	43.8	88.2	42.7	83.1	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.7	12.2	10.7	DB	16.3	97.3	4.7	3.1	13.0	99.5	10.3	101.3	7.7	103.1	4.3	105.3
			WB	15.0	82.1	4.8	0.9	11.6	82.8	8.8	83.3	6.1	83.8	2.6	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.5	45.1	49.3	53.7	62.9	70.8	77.9	80.1	78.9	74.8	64.4	53.2	49.4
	DBStd	14.31	10.03	9.17	9.26	7.02	5.67	4.49	3.38	3.27	4.48	7.37	7.95	9.06
	HDD50	588	218	117	71	2	0	0	0	0	0	2	52	126
	HDD65	2521	618	444	366	119	19	0	0	0	1	100	364	490
	CDD50	5501	67	97	185	390	644	837	934	897	745	450	147	108
	CDD65	1959	2	5	15	56	198	387	469	432	296	83	9	7
	CDH74	17071	11	48	155	560	1689	3602	4463	3666	2176	625	51	25
	CDH80	6548	0	1	20	106	530	1534	1993	1485	768	110	1	0
Wind	WSAvg	3.6	3.4	4.1	4.3	4.6	3.8	3.5	3.6	2.9	3.4	3.2	3.2	3.2
Precipitation	PrecAvg	51.1	4.2	3.5	4.0	3.0	4.0	5.2	6.7	6.5	5.3	3.1	2.7	3.3
	PrecMax	68.6	8.5	9.4	10.8	8.6	11.9	14.1	15.4	16.0	20.4	9.4	6.1	11.4
	PrecMin	37.4	0.9	0.2	0.6	0.1	1.2	0.4	1.6	0.4	0.2	0.0	0.7	0.6
	PrecStd	8.1	2.1	1.9	2.2	1.9	2.2	3.0	3.3	3.5	3.7	2.4	1.5	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	79.2	82.1	86.2	93.4	97.1	97.5	95.0	90.9	87.6	79.2	77.3
		MCWB	65.0	65.5	65.1	70.3	73.0	79.2	77.6	79.3	76.9	75.1	68.4	69.5
	2%	DB	70.3	73.5	78.9	82.3	88.4	93.3	95.0	91.2	89.8	82.2	74.6	72.6
		MCWB	62.9	63.5	63.9	68.5	72.3	77.4	78.1	78.3	76.2	72.0	65.9	66.4
	5%	DB	66.0	70.3	73.4	80.8	86.0	90.6	91.2	90.1	87.8	80.8	71.9	69.9
		MCWB	60.0	61.6	61.5	67.8	72.6	76.4	77.5	77.9	75.5	70.9	65.0	66.0
	10%	DB	62.8	65.7	70.3	77.1	82.0	88.3	90.0	88.1	85.6	77.4	68.3	65.7
		MCWB	58.0	59.2	60.5	65.6	71.1	75.8	77.6	77.1	75.5	69.1	63.0	63.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.6	68.9	68.8	74.7	78.1	83.7	84.2	84.0	80.1	78.8	72.1	71.5
		MCDB	71.9	73.2	74.9	80.6	84.0	93.1	91.7	89.8	83.7	80.6	75.8	75.3
	2%	WB	64.9	66.7	66.9	72.4	76.0	81.3	81.9	81.6	78.8	76.5	69.5	69.3
		MCDB	68.8	73.3	75.0	78.2	83.3	86.8	87.3	85.3	83.3	80.1	71.8	71.4
	5%	WB	62.7	63.9	65.0	70.3	74.3	79.3	79.9	80.1	77.7	73.8	66.9	66.0
		MCDB	64.6	67.3	71.4	76.4	81.1	85.0	85.6	84.2	83.2	78.0	70.5	68.7
	10%	WB	58.6	60.7	63.1	68.5	73.0	77.5	78.6	78.7	76.7	72.0	64.0	62.9
		MCDB	61.5	64.5	67.4	74.3	79.2	83.8	85.0	83.6	82.6	75.8	66.5	64.8
Mean Daily Temperature Range	5% DB	MDBR	21.2	22.3	23.9	24.2	21.3	20.0	19.1	17.6	18.5	21.7	23.4	20.2
		MCDBR	26.8	26.5	27.6	27.2	25.3	22.2	21.6	20.1	21.6	23.2	25.4	23.3
		MCWBR	18.7	16.8	14.5	14.0	11.1	8.7	8.1	8.4	9.9	12.8	16.7	16.8
	5% WB	MCDBR	22.4	24.3	22.7	22.2	20.0	20.3	19.0	17.2	18.3	17.5	20.8	21.0
		MCWBR	18.3	18.4	13.1	12.9	10.5	9.6	8.9	8.5	9.6	10.9	15.7	16.8
Clear-Sky Solar Irradiance	taub	0.323	0.331	0.366	0.399	0.464	0.486	0.533	0.507	0.430	0.396	0.349	0.326	
	taud	2.517	2.493	2.417	2.309	2.184	2.166	2.054	2.118	2.329	2.391	2.481	2.540	
	Ebn at Noon	283	292	288	282	264	257	244	248	264	265	270	275	
	Edh at Noon	27	30	35	41	47	48	53	49	38	33	27	25	
All-Sky Solar Radiation	RadAvg	872	1080	1442	1831	1984	2046	1952	1755	1500	1259	967	773	
	RadStd	52	108	125	122	144	134	121	93	118	140	75	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (51 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+319	+229

Nomenclature: See separate page