

PAMPA MESA VISTA, TX, USA

WMO: 720626

Lat: 35.883N

Lon: 101.033W

Elev: 845

StdP: 91.57

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00213

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-9.1	-17.8	0.9	-7.0	-16.0	1.0	-4.4	13.0	14.6	11.9	12.7	3.2	10	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.0	19.3	37.4	19.4	36.1	19.7	22.5	31.0	21.9	30.7	21.4	30.2	6.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	16.6	24.5	19.9	16.2	24.4	18.9	15.2	24.0	70.6	31.0	68.3	30.6	66.4	30.5	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
12.8	11.6	10.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	-18.4	23.5	1.7	0.9	-19.6	24.2	-20.7	24.7	-21.6	25.2	-22.9	25.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	3.5	4.4	10.3	14.4	19.1	25.9	27.3	26.5	22.5	15.0	8.9	3.5
	DBStd	9.96	5.43	6.50	5.67	5.15	4.96	3.45	3.16	2.96	3.79	5.18	5.30	5.28
	HDD10.0	772	208	176	63	18	2	0	0	0	0	16	80	209
	HDD18.3	2175	459	391	254	136	52	1	1	0	11	127	283	461
	CDD10.0	2659	8	19	73	151	284	476	536	512	376	170	48	6
	CDD18.3	1019	0	1	6	19	76	226	277	254	137	23	1	0
	CDH23.3	13252	2	33	162	394	1111	2904	3602	3066	1534	385	57	2
CDH26.7	7029	0	9	50	153	523	1609	2103	1717	721	134	10	0	
Wind	WSAvg	4.5	3.9	4.3	4.9	5.7	5.1	5.4	4.4	4.0	4.3	4.4	4.4	4.0
Precipitation	PrecAvg	534	15	15	24	49	78	74	73	72	44	39	22	23
	PrecMax	1045	47	39	114	217	251	158	218	133	120	130	117	96
	PrecMin	299	0	0	0	0	12	3	15	11	0	1	0	3
	PrecStd	135	13	12	25	47	46	42	43	32	30	39	25	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	27.3	31.2	33.0	37.4	41.4	41.4	40.2	37.2	32.9	27.8	22.2
		MCWB	9.6	11.4	13.7	14.1	15.5	18.5	19.5	19.9	18.7	15.7	12.5	9.7
	2%	DB	20.0	22.8	27.7	31.1	34.7	38.0	39.1	37.8	35.1	30.2	25.0	17.8
		MCWB	8.5	9.6	13.0	13.7	15.7	18.6	19.8	20.0	19.0	15.8	11.4	8.1
	5%	DB	16.3	19.9	24.8	27.7	32.2	36.2	37.4	36.3	32.8	27.6	22.0	16.0
		MCWB	6.7	8.8	11.6	13.4	15.7	19.6	19.7	20.4	18.9	15.2	11.1	7.2
	10%	DB	12.9	16.0	21.2	25.1	29.9	34.4	36.1	34.8	31.2	25.1	18.0	12.5
		MCWB	5.3	6.8	10.4	13.2	16.1	19.9	20.2	20.1	18.6	14.4	9.5	6.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	13.0	16.4	18.4	21.3	22.9	23.9	23.2	21.7	20.4	14.6	11.9
		MCDB	22.0	24.1	24.1	24.3	27.0	32.1	31.1	31.3	30.1	25.9	20.0	16.2
	2%	WB	8.7	10.5	14.9	16.5	20.1	22.1	22.6	22.4	21.0	18.6	13.1	9.4
		MCDB	18.7	21.4	22.8	23.8	26.2	31.4	30.7	30.9	29.0	24.1	20.9	17.5
	5%	WB	7.2	9.0	13.1	15.3	19.1	21.5	21.9	21.7	20.4	17.3	11.9	7.7
		MCDB	15.9	18.9	21.8	22.1	25.8	30.7	30.6	30.6	28.3	22.7	19.5	14.1
	10%	WB	5.7	7.4	11.4	14.1	17.8	21.0	21.3	21.1	19.8	15.9	10.5	6.2
		MCDB	12.8	16.1	20.3	22.7	24.9	29.8	30.2	30.0	27.5	22.7	18.2	12.5
Mean Daily Temperature Range	5% DB	MDBR	15.6	15.3	16.7	16.1	15.7	15.0	14.3	14.9	14.6	15.7	15.8	14.0
		MCDBR	19.5	21.3	20.9	20.9	19.6	17.1	16.8	16.8	17.2	19.5	19.8	18.4
		MCWBR	10.4	10.4	9.0	8.9	7.7	5.1	4.1	4.4	5.0	8.1	9.3	10.1
	5% WB	MCDBR	19.1	21.0	18.5	15.4	15.4	14.2	13.9	14.9	13.6	14.1	17.3	16.9
		MCWBR	10.3	10.7	8.4	7.6	7.6	5.0	4.4	4.7	4.6	7.3	9.1	9.7
Clear-Sky Solar Irradiance	taub	0.260	0.268	0.299	0.331	0.348	0.384	0.388	0.377	0.345	0.306	0.279	0.261	
	taud	2.584	2.576	2.489	2.415	2.431	2.376	2.399	2.394	2.465	2.558	2.558	2.587	
	Ebn at Noon	960	988	974	952	934	896	889	895	912	928	926	938	
	Edh at Noon	74	84	101	115	115	121	118	116	103	85	76	70	
All-Sky Solar Radiation	RadAvg	3.00	3.79	5.01	6.21	6.93	7.42	7.23	6.43	5.49	4.13	3.19	2.60	
	RadStd	0.26	0.37	0.37	0.38	0.53	0.47	0.32	0.33	0.27	0.48	0.32	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page